



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/253/1590

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.5	162	83	272	15.2	20.8	22.2	-	Meeting the standards.
		Outlet	7.2	9	8	32	2	1.5	1.2	76	
		OLMS	6.8	5.1	3.9	17.4	-	1.6	-	-	
Total 70											

I/C Water Laboratory
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/254/ 1591

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

Dated 30/01/2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 17.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.6	242	157	320	15.2	22.4	21.6	-	Meeting the standards.
		Outlet	7.5	8	6	40	1.2	2.2	1.5	180	
		OLMS	7.2	7.6	5.5	24.6	-	3.6	-	-	
2	Ph-III (10)	Inlet	7.4	250	138	328	17.6	23.2	21.2	-	Meeting the standards.
		Outlet	7.6	7	5	32	1.6	1.6	1.4	95	
		OLMS	7.7	8.2	5.5	26.0	-	3.7	-	-	
Total 30											

Mukherjee

Alkash

I/C Water Laboratory
Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/255/ 1592

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		Outlet	7.6	208	80	264	16.4	23.6	19.8	-	
		OLMS	7.2	6	4	24	1.2	1.8	1.2	79	
Total 15			7.3	7.6	5.0	24.2	-	2.1	-	-	

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/256/ 1593

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.5	220	143	292	16.8	16.2	18.4	-	Not meeting the standard wrt Fecal Coliform.
		Outlet	7.2	7	5	36	1.6	1.3	1.5	1500	
		OLMS	7.1	2.6	2.5	16.7	-	1.5	-	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/257/ 1594

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	7.6	248	160	324	12.4	22.8	24.2	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.3	30	12	64	1.2	2.5	1.4	1500	
		OLMS	7.5	8.3	6.6	30.1	-	5.7	-	-	
Total 12											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.mic.in>)



Report Number: DPCC/W/STP/24-25/258/ 1595

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-1,II (2.2)	Inlet	7.6	220	100	276	14.4	17.5	19.5	-	Not meeting the Standard wrt Fecal Coliform.
			7.1	5	3	20	1.2	1.9	1.6	350	
			7.2	5.8	4.7	21.2	-	1.2	-	-	
		OLMS	7.2	5.8	4.7	21.2	-	1.2	-	-	
Total 2.2											

Signature

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/259/ 1596

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.4	284	180	292	16.8	14.9	18.6	-	Meeting the standards.
		Outlet	7.1	8	6	40	0.8	1.2	1.6	110	
		OLMS	7.6	6.0	4.0	37.8	-	3.5	-	-	
Total 20											

Signature

Signature

I/C Water Laboratory
Dr. NANDITA MOITRA

SSA/Analyst/SLA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/260/ 1597

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	40	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.5	268	160	320	10.8	16.5	19.3	-		
		OLMS	7.8	23	12	76	1.6	1.3	1.1	1300		
		OLMS	8.0	21.8	15.4	104.4	-	8.9	-	-		
Total 40												

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number **DPCC/W/STP/24-25/261/ 1598**

Dated **30/01/2025**

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 22.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	7.7	214	150	276	19.2	17.4	16.4	-	Meeting the standards.
		Outlet	7.2	9	6	32	1.2	1.9	1.2	76	
		OLMS	-	-	-	-	-	-	-	-	
Total 5											OLMS was non functional

MMitra

Akash

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/262/ 1599

Dated: 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

- 1.
2. Name of STP : Rithala
3. Sampling location : Inlet and Outlet of STP
4. Date of Inspection : 02.01.2025
5. Samples collected by : DPCC Lab
6. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Inlet	7.5	198	171	272	16.4	19.4	22.4	-		
		Outlet	7.4	7	6	36	1.6	2.2	1.7	84		
		OLMS	-	-	-	-	-	-	-	-		
2	Ph-II(40)										Meeting the standards	
		Inlet	7.3	194	200	248	16.8	20.1	19.8	-		
		Outlet	7.5	6	5	40	1.2	2.1	1.6	110		
		OLMS	6.9	6.4	4.6	26.0	-	4.6	-	-		
Total 80												

MMitra

Atish

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/263/ 1600

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.9	202	180	292	21.2	18.4	17.8	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	27	16	80	0.8	1.1	1.3	1300	
		OLMS	7.5	15.9	12.1	59.4	-	6.6	-	-	
Total 20											

M. Mittal

Alka D

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnms.nic.in>)



Report Number: DPCC/W/STP/24-25/264/ 1601

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
	20	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standard wrt Fecal Coliform.
		7.9	202	180	292	21.2	18.4	17.8	-		
		Outlet	7.6	9	8	36	1.2	1.2	1.8	950	
		OLMS	7.9	5.5	4.1	25.5	-	1.8	-		
Total 20											

N. Mittal

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

Akshay



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/24-25/265 / 1602

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.4	182	160	244	15.2	19.8	21.8	-	Meeting the standards.
		Outlet	7.6	6	4	24	0.8	1.8	1.5	70	
		OLMS	7.4	28.5	14.0	94.0	-	7.9	-	-	
Total 15											

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/266/ 1603

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
		Outlet	7.5	248	180	236	18.8	20.2	19.7	-	
		OLMS	7.6	8	6	28	1.2	1.9	1.7	58	
		OLMS	7.3	6.1	4.6	17.3	-	2.3	-	-	
Total 10											

M. Mittal

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

Akash



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/267 / 1604

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	7.5	242	220	248	16.8	19.7	20.4	-	Meeting the Standards.
		Outlet	7.4	9	8	36	0.8	2.2	1.6	180	
		OLMS	7.0	7.2	4.8	24.9	-	1.2	-	-	
		Total 30									

Mishra

SSA

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/268/ 1605

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)	Inlet	7.7	246	125	288	16.4	17.9	17.3	-	Meeting the standards.
		Outlet	7.3	8	5	32	1.6	1.6	1.2	84	
		OLMS	7.9	5.9	5.2	27.3	-	4.6	-	-	
2	Ph-II & III (25+10)	Outlet	7.2	6	4	28	1.2	2.1	1.1	150	Meeting the standards
		OLMS	7.9	5.7	6.2	25.5	-	4.6	-	-	
		Total 45									

I/C Water Laboratory KA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/269/1606

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.4	264	120	304	13.6	18.3	22.6	-	Meeting the Standards.
		Outlet	7.8	8	6	36	0.8	1.5	1.4	120	
		OLMS	7.4	8.1	5.5	23.4	-	4.7	-	-	
Total 45											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccoccmms.nic.in>)



Report Number: DPCC/W/STP/24-25/270/1607

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.5	254	180	252	17.6	21.4	22.3	-	Meeting the standards.
		Outlet	7.4	9	6	44	1.6	2.2	1.5	180	
		OLMS	7.5	8.6	5.3	26.2	-	3.9	-	-	
Total 5											

M. Mittal

I/C Water Laboratory

Dr. NANDITA MOLTRA

Scientist-D

SSA/Analyst/SLA

18/01/2025



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/271/ 1608

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

Dated 30/01/2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.8	264	150	280	19.2	19.9	18.7	-	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.3	24	16	68	1.6	1.4	0.9	180	
		OLMS	8.1	17.7	11.6	64.9	-	13.2	-	-	
Total 25											

Not meeting the Standards wrt TSS, BOD & COD.

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccoccmms.nic.in>)



Report Number: DPCC/W/STP/24-25/272/ 1609

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
1	9	Inlet	7.2	232	125	280	13.2	20.9	20.8	-	Meeting the Standards.
		Outlet	7.5	7	4	28	0.4	1.4	1.1	95	
		OLMS	7.4	5.5	3.6	22.0	-	2.3	-	-	
Total 9											

M. N. Sharma
I/G. Water Laboratory
D.P. Water Laboratory
Scientist-D

SSA/Analyst/SLA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/273/

1610

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	7.6	194	80	268	17.2	18.4	21.7	-	Meeting the Standards.
		Outlet	7.5	4	2	16	0.8	1.5	1.3	70	
		OLMS	7.5	0.6	1.3	5.2	-	0.2	-	-	
Total 1											

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/274/ 1611

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.7	272	156	320	14.8	20.5	16.8	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	34	15	60	1.6	1.4	1.5	1700	
		OLMS	7.5	13.9	7.1	34.6	-	6.1	-	-	
Total 15											

M. Mohan

I/C Water Laboratory
Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

M. Mohan



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnmms.nic.in>)



Report Number: DPCC/W/STP/24-25/275/

16/2

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		Outlet	7.6	226	200	244	16	20.7	20.1	-	
		OLMS	7.5	55	32	76	1.6	2.1	1.8	1500	
2	3	Inlet	-	-	-	-	-	-	-	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		Outlet	7.7	236	150	232	15.2	21.7	20.5	-	
		OLMS	7.4	53	34	92	2	2.2	1.9	1700	
Total 5.2			-	-	-	-	-	-	-	-	

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/276/ 1613

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.6	256	120	316	12.4	21.5	18.2	-	
		OLMS	7.1	23	14	64	0.8	1.1	1.2	1100	
		Inlet	7.0	9.9	7.2	27.3	-	14.4	-	-	
2	10 Ph-2	Outlet	7.6	226	200	332	15.2	20.7	17.6	-	Meeting the standards.
		OLMS	7.5	7	5	32	0.8	1.6	1.3	76	
		OLMS	8.4	7.3	5.5	27.0	-	5.7	-	-	
Total 20											

M. N. Sharma
Dr. NANDITA
I/C Water Laboratory
Scientist-D

SSA Analyst SLA
SSA/AnalystSLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/277/1614

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	0.66	Inlet	7.7	292	280	308	18.4	21.1	19.4	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	43	26	68	1.2	2.1	1.6	1200	
		OLMS	6.9	36.2	-	-	-	7.2	-	-	
Total 0.66											BOD & COD Readings not showing in OLMS

I/C Water Laboratory

SSA/Analyst/SLA

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/278/1615

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

Dated

30/01/2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	7.6	286	240	252	14.4	21.5	20.4	-	Plant was closed
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
	16	Outlet	7.5	8	7	32	2.4	1.7	1.8	130	Meeting the Standards.
		OLMS	7.1	10.7	4.9	37.6	-	6.2	-	-	
		Outlet	-	-	-	-	-	-	-	-	
	37	OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
	45	Outlet	-	-	-	-	-	-	-	-	Plant was closed
		OLMS	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 110											OLMS was non functional

I/G Maitra Laboratory
Scientist-D

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/279/ 1616

Dated

30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	40	Inlet	7.7	240	140	332	23.6	21.6	22.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	31	20	64	3.2	3	1.7	1100	
		OLMS	-	-	-	-	-	-	-	-	
2	20	Outlet	7.3	22	13	36	2.4	2.6	1.4	1800	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	-	-	-	-	-	-	-	-	
Total 60											OLMS was non functional

M. M. M.

I/C Water Laboratory
Dr. NANDITA MOITRA

Scientist-D

SSA/Analyst/SLA

18/01/2025



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/280/16/2

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2025

Dated

50/01/2025

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.8	258	171	292	18	15.6	21.6	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.7	57	30	88	1.2	1.3	1.4	2400	
		OLMS	7.6	18.7	12.4	47.6	-	7.7	-	-	
		Total 5									

M. N. Mishra

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D

SSA Analyst/SLA

[Signature]