

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/51/4869

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : New Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 13.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.2	276	205	248	26	30.4	19.2	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.5	38	22	48	3.8	4.5	4.3	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10) (now upgrade with 70 MGD)	Inlet	7.5	208	175	296	12.8	35.8	30.5	Not meeting the standards wrt TSS & BOD.
		Outlet	7.3	22	14	48	2.4	3.4	1.6	
		OLMS	-	-	-	-	-	-	-	
Total 30										

*Remarks: OLMS (Ph-I & II) was stolen. FIR has been filed as informed by Plant In-charge & OLMS (Ph-III) found non-functional.

M. M. M.
I/C LABORATORY
Dr. Nandini Mishra
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/52 *4870*

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.3	180	94	268	20.2	18.12	9.4	Meeting the Standards.
		Outlet	7.1	6	4	44	1.2	4.3	1.8	
		OLMS	6.8	6.63	4.21	38.41	-	8.50	-	
Total 15										

Mitra
I/C LABORATORY

Scientist C



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/53 4871


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.0	204	98	272	20.8	29.4	8.7	Meeting the Standards
		Outlet	7.1	10	8	44	1.8	4.8	1.9	
		OLMS	7.4	4.11	3.46	23.24	-	0.60	-	
Total 2.2										

N. Mitta
I/C LABORATORY
Dr. Nandini Mitta (B.Sc.)
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/54/4872


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.2	256	145	348	28.4	30.4	17.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.6	26	18	64	0.6	1.6	1.8	
		OLMS	7.7	8.14	6.53	51.32	-	3.23	-	
Total 12										

Mita
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/55/4873

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	6.9	264	96	248	29.2	37.4	18.6	Meeting the Standards
		Outlet	7.4	8	6	32	1.8	4.2	1.6	
		OLMS	*	30.99	34.74	69.92	-	*	-	
Total 2.2										

*Remarks: In OLMS, pH and Ammonical Nitrogen readings were not reflected.

Mishra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/54874

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Nilothi Ph-II (NEW)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.3	148	102	312	26.4	28.2	7.2	Meeting the standards.
		Outlet	7.2	8	6	20	0.8	1.9	1.8	
		OLMS	7.1	8.09	8.70	41.14	-	2.17	-	
Total 20										

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/57/4875

Date: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022


1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

3. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.4	236	106	192	18.2	20.2	24.2	Not meeting the standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved phosphate.
		Outlet	7.2	60	42	132	4.6	8.9	7.2	
		OLMS	7.6	65.01	40.81	184.55	-	25.26	-	
Total 40										

M. Mitra

I/C LABORATORY

Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/58/4876

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.8	208	80	204	16.2	20.4	18.3	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.6	56	38	108	4.2	4.6	6.2	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

*Remarks: OLMS was Stolen informed by Plant Incharge.


I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/59/4877


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.5	268	88	212	28.2	18.2	19.4	Meeting the standards.
		Outlet	7.3	8	6	48	1.8	4.6	2	
		OLMS	7.4	11.20	8.96	33.70	-	4.04	-	
Total 80										

N. Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/60/ 4878

Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.6	184	64	184	18.2	20.2	16.2	Not meeting the Standards wrt TSS, BOD COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.2	68	36	96	9.8	7.8	6.2	
		OLMS	7.3	46.23	25.70	181.79	-	21.3	-	
Total 20										

Mishra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/61/4879


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.8	180	120	312	20.4	22.6	18.5	Meeting the Standards
		Outlet	7.3	10	8	40	2.2	2.6	1.4	
		OLMS	7.3	101.79	30.90	99.83	-	1.06	-	
Total 20										

M. M. M. M.
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/22-23/62/4880

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.4	244	135	308	22.6	35.8	25.6	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.2	34	22	68	4.2	7.6	3.6	
		OLMS*	-	-	-	-	-	-	-	
Total 15										

*Remarks: OLMS was found non-operational at the time of Monitoring.

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/63/4881


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.5	128	68	268	3.8	28.6	17.3	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate
		Outlet	7.6	32	22	80	1.8	4.2	3.4	
		OLMS	7.4	85.37	26.08	111.90	-	13.11	-	
Total 10										

M. M. M. M.
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/64/4882


Dated : 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.13	116	110	304	18.2	29.4	20.4	Meeting the Standards.
		Outlet	7.06	8	6	48	1.8	4.6	1.6	
		OLMS	8.0	57.7	6.91	28.50	-	3.50	-	
Total 30										

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/65/4883

Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022


1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.2	308	110	392	18	37.7	28.5	Not meeting the standards wrt TSS, BOD, Ammonical nitrogen & Dissolved phosphate.
		Outlet	7.1	20	16	40	0.6	9.2	2.6	
		OLMS*	-	-	-	-	-	-	-	
Total 25										

*Remarks: During the monitoring, the OLMS was not found installed at the site.

N. Mishra

Dr. I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/66/4884

Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022


1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.3	196	150	300	20.8	28.9	27.8	Not Meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	82	48	136	6.2	2.3	7.8	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

*Remarks: During the monitoring, the OLMS was not found installed at the site.

Mitla

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/67/1885


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.5	156	82	264	5.8	38.5	20.2	Meeting the standards
		Outlet	7.3	8	6	48	2.0	5	2.0	
		OLMS	7.3	7.82	5.44	47.6	-	4.91	-	
Total 5										

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/68/4886


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.9	184	96	248	17.8	22.5	18.4	Not meeting the Standards wrt TSS, BOD, COD & Ammonical Nitrogen.
		Outlet	7.5	38	32	96	5.6	6.2	2	
		OLMS	7.8	32.39	21.87	113.34	-	14.51	-	
Total 25										

Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/69/4887

Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022


1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.5	200	98	248	16	28.7	22.4	Meeting the Standards.
		Outlet	7.2	10	8	48	1.2	2.8	1.8	
		OLMS	7.2	9.26	4.24	42.36	-	4.09	-	
Total 9										

M. Mitra

I/C LABORATORY

Dr. Indira MITRA
Scientist



DELHI POLLUTION CONTROL COMMITTEE (Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/70/4888


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.3	184	100	292	18.6	13.49	19.8	Meeting the Standards.
		Outlet	7.2	6	3	32	0.8	1.2	1.8	
		OLMS	7.8	0.64	0.60	14.16	-	0.95	-	
Total 1										

N. Mitra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/71/4889

Dated : 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.4	136	92	264	10.6	18.2	39.2	Not meeting the standards wrt TSS, BOD, COD Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.2	28	14	64	2.6	5.2	2.9	
		OLMS	7.9	29.41	11.09	151.77	-	5.46	-	
Total 15										

Mishra
I/C LABORATORY

Dr. LALITA DEVI
Scientist



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/72/4890


Dated : 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.4	188	120	304	29.6	18.8	38.2	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.5	34	18	40	5	3.6	3.9	
		OLMS	7.6	5.10	3.78	24.48	-	5.07	-	
2	3	Inlet	7.25	292	110	268	10.2	20.2	28.6	Not Meeting the Standards wrt TSS, BOD & Dissolved Phosphate
		Outlet	7.46	26	16	48	2.2	4.3	2.9	
		OLMS	8.08	5.86	3.59	27.62	-	4.62	-	
Total 5.2										

Mittra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/73 /4891

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.48	112	98	288	16.2	29.4	39.8	Not meeting the standards wrt TSS.
		Outlet	7.02	12	10	36	2.8	4.8	1.3	
		OLMS	7.5	19.98	14.02	125.14	-	7.26	-	
2	10 Ph-2	Inlet	7.28	204	205	436	18.6	36.5	20.3	Not meeting the standard wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate
		Outlet	7.01	44	34	100	4.8	10.6	5.4	
		OLMS	7.5	23.12	15.14	78.96	-	26.0	-	
Total 20										

M. M. M. M.

I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/74/4892

Dated: 11/7/2022


ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	
1	12	Inlet	7.8	252	90	240	16.2	32.4	20	Not meeting the Standards wrt TSS, BOD & Ammocial Nitrogen
		Outlet	7.26	42	20	48	3.2	5.2	1.8	
		OLMS	7.4	25.76	19.72	95.40	-	4.93	-	
	16	Outlet	7.62	20	16	32	2.4	5.0	3	Not meeting the Standards wrt TSS, BOD, Ammocial Nitrogen & Dissolved Phosphate
		OLMS	6.6	6.20	4.65	23.49	-	4.96	-	
	37	Outlet	7.32	32	18	64	1.8	4.5	2.6	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS*	-	-	-	-	-	-	-	
	45	Outlet	7.59	42	14	68	2.8	3.9	1.2	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	6.7	45.00	15	72	-	52.35	-	
	Total 110									

*Remarks: OLMS (37 MGD) was found under maintenance at the time of Monitoring (informed by JE, DJB)

Mittra
I/C LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/03/4894


Dated: 11/7/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	6.68	224	104	404	20.2	19.2	16.1	Not meeting the Standards wrt TSS, BOD & COD
		Outlet	7.06	28	14	56	1.2	2.8	2	
		OLMS	7.0	33.64	19.93	91.04	-	27.86	-	
Total 0.66										

Mishra
I/C LABORATORY
Scientist 'C'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/22-23/75 /4907

Dated: 25/07/2022

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE -2022

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.06.2022
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.4	278	68	220	16.2	22.8	16.9	Not meeting the Standards wrt TSS.
		Outlet	7.08	14	10	36	1.8	3.2	0.8	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.4	278	68	220	16.2	22.8	16.9	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen.
		Outlet	7.38	48	38	84	5.6	6.5	1.8	
		OLMS	7.6	79.02	67.99	218	-	21.25	-	
Total 60										

Remarks: OLMS (40 MGD) was found non-functional at the time of Monitoring

M. Mitra

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'