



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/348/2376

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit **Rithala STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **03.07.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.6	284	190	460	26.8	28.4	6.4	Not meeting the standards w.r.t to TSS,BOD.
		Outlet	7.7	22	16	40	2.4	3.3	0.9	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.6	284	190	460	26.8	28.4	6.4	Meeting the Standards.
		Outlet	7.8	6	4	12	0.4	1.2	0.7	
		OLMS*	7.98	9.09	16.0	86.06	-	6.4	-	
	Total 80									

Remarks-ph-I OLMS was not working.


I/C LABORATORY

Dr. NANDITA MOITRA

Scientist 'C'

SR. SCIENTIFIC ASSISTANT

IT cell



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/353 /2377

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020


1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.07.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	25	Inlet	7.7	232	165	412	26.4	29.4	7.9	Not meeting the Standards w.r.t TSS,BOD.
		Outlet	7.8	28	16	40	2.0	3.7	0.7	
		OLMS*	-	-	-	-	-	-	-	
	Total 25									

Remarks;-OLMS found locked.

Dr. NANDITA MOTTRA
Scientist 'C'
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/363/2378

Date: 18/08/20

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Keshopur STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 17.07.2020
4. Samples collected by DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.7	140	60	148	16.4	21.6	6.6	Not meeting the Standards w.r.t TSS.
		Outlet	7.7	16	10	28	1.2	3.4	0.4	
		OLMS*	-	-	-	-	-	-	-	
2	20	Inlet	7.7	140	60	148	16.4	21.6	6.6	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.8	44	26	64	4.0	6.6	0.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 60									

Remarks;-OLMS was found locked.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/341/2379,

Date: 18/08/22

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit

DELHI GATE STP NEW

2. Sampling location

Inlet and Outlet of STP

3. Date of Inspection

10.07.20

4. Samples collected by

DPCC Lab

5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.3	120	85	212	16.4	18.8	6.9	Meeting the Standards.
		Outlet	7.5	6	3	8	0.4	1.1	0.3	
		OLMS*	7.41	4.11	2.97	34.15	-	3.15	-	
	Total 15									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/342/2380

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit **DELHI GATE STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **10.07.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters			Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)				
				10	10	50	10		5	2	
1	Phase-I, II (2.2)	Inlet	7.4	136	90	220	17.2		19.6	7.4	Meeting the Standards.
		Outlet	7.6	8	4	12	0.8		1.3	0.4	
		OLMS*	-	-	-	-	-	-	-	-	
	Total 2.2										


Remarks-OLMS found under maintenance.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/343/238/

date: 18/08/20

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Keshopur STP new
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
17.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	8.5	280	210	560	29.6	32.4	6.8	Not Meeting the Standards w.r.t TSS.
		Outlet	8.0	12	6	16	0.4	1.2	0.2	
		OLMS*	-	-	-	-	-	-	-	
	Total 12									

Remarks: OLMS was found locked.

I/C LABORATORY
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/344 | 2382

Date: 18/08/2020


ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Sen Nursing Home (SNH)
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
10.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.1	220	160	400	20.4	22.4	7.6	Meeting the Standards .
		Outlet	7.3	4	2	4	0.4	1.8	0.2	
		OLMS*	7.15	4.42	2.9	18	-	4.06	-	
	Total 2.2									

N. Mitra
I/C LABORATORY
DR. NANDITA MOITRA
Scientist 'C'

SR. Scientific Assistant
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/345 / 2383

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit **Nilothi STP-II**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **09.07.20**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	8.1	240	160	400	25.6	27.4	6.0	Meeting the Standards.
		Outlet	8.1	8	4	12	0.4	1.7	0.7	
		OLMS*	7.53	12.28	6.74	23.93	-	3.81	-	
	Total 20									

Remarks: OLMS was found locked.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/346/2384

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Nilothi STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 09.07.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	8.2	120	65	164	14.4	19.2	5.6	Not Meeting the Standards w.r.t TSS, BOD.
		Outlet	8.3	26	12	36	2.8	3.7	1.4	
		OLMS*	-	-	-	-	-	-	-	
	Total 40									

Remarks: OLMS was under maintenance.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/347/2385

date: 18/08/20

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Najafgarh STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
15.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
	5	Inlet	7.6	140	80	200	16.8	19.6	7.2	Not meeting the standards w.r.t to TSS, BOD,&T.P.
		Outlet	7.9	26	14	36	2.4	3.7	2.3	
		OLMS*	7.15	48.08	6.07	54.14	-	15.86	-	
	Total 5									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/348/2386

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Pappankalan STP(old)
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 15.07.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	20	Inlet	7.6	128	65	148	17.2	19.4	5.9	Not meeting the Standards w.r.t TSS,BOD,A.N,COD&T.P.
		Outlet	7.7	36	28	76	4.4	5.9	2.6	
		OLMS*	6.88	42.18	59.60	156.96	-	6.6	-	
	Total 20									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/349 | 2387

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Pappankalan STP-II (new)
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 15.07.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.6	176	120	280	19.6	21.4	7.8	Meeting the Standards.
		Outlet	7.9	8	6	16	0.4	1.3	0.7	
		OLMS*	6.32	6.31	4.18	17.57	-	2.77	-	
	Total 20									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC
ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/350/2388

Date : 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Rohini STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
03.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	15	Inlet	7.3	168/	110	260	22.4	24.6	6.0	Not meeting the Standards w.r.t TSS,BOD.
		Outlet	7.4	26	14	36	0.8	1.9	1.5	
		OLMS*	-	-	-	-	-	-	-	
	Total 15									

Remarks-OLMS found non-functional.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/351/2389

Date : 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.07.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	7.9	248	190	474	26.4	30.4	8.1	Not Meeting the Standards w.r.t TSS,BOD
		Outlet	8.4	18	12	28	1.6	2.7	0.5	
		OLMS*	-	-	-	-	-	-	-	
	Total 10									

Remarks:-OLMS found non-operational.

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/352/2390

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020


1. Name & Address of Ind./Unit
Okhla STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
13.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	30	Inlet	7.8	100	60	160	14.4	16.7	5.9	Meeting the Standards
		Outlet	7.8	6	3	8	0.4	1.2	0.3	
		OLMS*	7.25	10.03	6.35	27.26	-	1.77	-	
	Total 30									

I/C LABORATORY

Dr. MANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/355/2391

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Kapashera STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
16.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.3	156	90	200	18.4	20.2	7.4	Meeting the Standards .
		Outlet	7.4	10	6	16	0.8	1.3	0.2	
		OLMS*	-	-	-	-	-	-	-	
	Total 5									

Remarks-OLMS was under maintenance

I/C LABORATORY

Nandita Moitra
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/356 | 2392

Date: 18/08/20

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Yamuna Vihar STP Ph-III
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
14.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters		Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)	Oil & Grease (mg/l)			
				10	10	50	10	5	2	
1	25	Inlet	8.0	164	120	300	19.6	23.4	7.4	Not meeting the Standards w.r.t TSS,BOD,COD.
		Outlet	8.1	30	24	64	2.0	3.3	1.5	
		OLMS*	7.54	37.45	18.08	124.85	-	13.89	-	
	Total 25									

Mitra
I/C LABORATORY
Dr. NANDAN MOITRA
Scientist 'C'

Sharma
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006.

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/357/2393

Date: 18/08/22

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit
Chilla STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
20.07.20
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	9			10	10	50				
		Inlet	7.7	136	75	188	10	5	2	Meeting the Standards.
		Outlet	7.8	8	6	16	19.6	24.5	7.1	
		OLMS*	7.32	4.44	2.31	18.32	0.8	1.6	0.3	
	Total 9							3.94	-	

Maitra
I/C LABORATORY
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/358/2394

Date: 18/08/22

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Akshardham STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 20.07.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.8	128	65	164	17.2	22.6	7.2	Meeting the Standards.
		Outlet	7.9	4	2	4	0.4	1.2	0.1	
		OLMS*	7.49	1.14	1.68	8.56	-	1.77	-	
	Total 1									

I/C LABORATORY

Mittra
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/359/2395

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Mehrauli STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 16.07.20
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
	15	Inlet	7.6	124	65	160	15.6	16.8	6.0	Not meeting the standards w.r.t TSS, BOD.
		Outlet	7.8	24	16	36	2.0	3.3	1.1	
		OLMS*	7.88	62.38	40.52	84.64	-	19.79	-	
	Total 15									

I/C LABORATORY

Maitra
Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/360/2396

Date : 18/08/22


ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.07.20
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter S COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.6	140	80	180	16.0	18.2	7.1	Not meeting the Standards w.r.t BOD and TSS.
		Outlet	7.9	30	18	44	2.4	3.5	1.5	
		OLMS*	7.8	14.04	8.57	12.88	-	2.55	-	
	3	Inlet	7.5	280	210	560	29.6	32.4	8.6	Not Meeting the Standards w.r.t BOD, TSS.
		Outlet	7.6	26	14	40	1.6	2.9	0.3	
		OLMS*	7.11	13.20	10.05	44.08	-	9.25	-	
	Total 5.2									

Dr. NANDINI MITRA
Scientist 'C'
I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/02/2399

Date: 18/08/22

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Molarband mini STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 13.07.2020
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter S COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2	Inlet	7.4	248	1858	462	26.4	28.4	7.8	Not meeting the Standards w.r.t BOD,TSS.
		Outlet	7.5	26	14	36	1.6	2.4	0.6	
		OLMS*	-	-	-	-	-	-	-	
	Total 2									

Remarks:-OLMS not installed.

I/C LABORATORY
DR. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/362/2398

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit: Okhla STP
2. Sampling location: Inlet and Outlet of STP
3. Date of Inspection: 13.07.20
4. Samples collected by: DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameter S COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	12	Inlet	7.7	96	60	140	15.6	17.4	6.1	Not meeting the Standards w.r.t TSS,BOD&COD.
		Outlet	7.6	40	26	64	2.4	3.6	0.4	
		OLMS	8.67	51.66	18.33	83	-	-	-	
	16	Outlet	7.8	28	16	40	1.6	2.8	0.5	Not meeting the Standards w.r.t TSS,BOD.
		OLMS	7.41	14.73	10.19	46.24	-	3.99	-	
	37	Outlet	7.9	24	14	36	1.2	2.3	0.6	Not meeting the Standards w.r.t TSS,BOD.
		OLMS	7.51	26.18	22.90	81.64	-	3.0	-	
	45	Outlet	7.9	16	8	20	0.8	1.4	0.8	Not meeting the Standards w.r.t TSS.
		OLMS	-	32.85	20.40	103	-	4.72	-	
Total 110										

Dr. NANDITA MOITRA
I/C LABORATORY / Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/361/2399

Date: 18/08/2020

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

1. Name & Address of Ind./Unit Yamuna Vihar STP
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 14.07.2020
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 5.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	8.0	272	210	520	28.4	31.6	8.4	
		Outlet	8.1	38	26	52	4.0	5.2	2.8	Not Meeting the Standards w.r.t BOD, TSS, COD, A.N, & T.P.
		OLMS*	6.78	30.16	15.74	80.28	-	8.68	-	
2	10	Inlet	7.9	164	110	260	18.4	19.8	7.3	Not Meeting the Standards w.r.t TSS, BOD.
		Outlet	8.2	24	18	44	2.8	3.7	0.9	
		OLMS*	-	-	-	-	-	-	-	
	Total 20									

I/C LABORATORY

Dr. NANDITA MOITRA
Scientist 'C'

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Date: 18/08/2020

Report Number : DPCC/W/STP/20-21/340/2400

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY-2020

- 1 Name & Address of Ind./Unit **Coronation Pillar STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **06.07.20**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Ph-I,II(20)	Inlet	7.3	336	260	640	26.4	28.6	7.2	Not meeting the Standards w.r.t BOD,TSS.
		Outlet	7.5	26	18	44	2.0	3.9	1.5	
		OLMS*	-	-	-	-	-	-	-	
	Ph-III(10)	Inlet	7.9	264	140	380	26.8	27.3	7.5	Not meeting the standards w.r.t TSS, BOD,COD&A.N.
		Outlet	7.9	40	28	84	4.0	6.6	1.5	
		OLMS*	-	-	-	-	-	-	-	
	Total 30									

Dr. NANDITA MOITRA
I/C LABORATORY Scientist 'C'

SR. SCIENTIFIC ASSISTANT

[Signature]