

DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/93/ 624

Date 13/08/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Vasant Kunj STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **15.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate As P (mg/l)	
			5.5-9.0	50	30	250	10	50	5	
1	Plant-I(2.2)	Inlet	7.2	316	260	720	36.4	32.6	6.8	Meeting the standards
		Outlet	7.6	32	26	76	2.8	3.2	1.8	
		OLM	7.3	36.1	9.8	60.9	-	9.5	-	
	Plant-II(3.0)	Inlet	7.6	104	85	180	14.4	26.4	4.8	Meeting the Standards.
		Outlet	7.4	30	24	64	1.2	2.4	1.2	
		OLM	6.7	11.5	5.6	30.4	-	5.4	-	
	Total 5.2									

Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/91 | 622

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Rohini STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **16.07.19**
- 4 Sample collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			5.5-9.0	10	10	250	10	50	5	
1	15	Inlet	7.7	204	160	460	29.6	27.9	5.9	Not meeting the standards w.r.t TSS and BOD.
	Total 15	Outlet	7.9	28	20	64	1.2	1.8	0.9	

REMARKS: OLMS was in found locked at the time of DPCC monitoring.

I/C
LABORATORY

N. Mitta

[Signature]
SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/85/616

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Narela STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **12.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	10	Inlet	8.0	184	165	520	28.4	26.8	6.3	Not meeting the Standards w.r.t TSS and BOD.
	Total 10	Outlet	7.9	52	46	136	4.8	4.6	2.2	

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/88 /619

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Okhla STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **11.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
		5.5-9.0	50	30	250	10	50	5		
1	Plant-I(12)	Inlet	8.0		130	400	26.4	32.1	6.0	Meeting the Standards
		Outlet	8.1	156 20	16	56	1.6	2.3	0.8	
	Plant-II(16)	Inlet	8.0	156	130	400	26.4	32.1	6.0	Meeting the Standards.
		Outlet	8.2	16	12	40	1.2	2.8	1.2	
	Plant-III(30)	Inlet	-	-	-	-	-	-	-	Non-operational due to under Rehabilitation.
		Outlet	-	-	-	-	-	-	-	
	Plant-IV(37)	Inlet	8.0	156	130	400	26.4	32.1	6.0	Meeting the Standard.
		Outlet	8.0	20	16	52	0.8	4.7	1.3	
	Plant-V(45)	Inlet	8.0	156	130	400	26.4	32.1	6.0	Meeting the Standard.
		Outlet	8.0	26	80	46	0.8	1.8	0.7	
Total 140										
There is only one inlet for Plant I, II, III, IV and V.										


REMARKS: OLMS is not present in STP.

I/C
LABORATORY

N. Mishra

SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/90 / 621

Date 13/08/2019


ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Pappankala STP -II**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	20	Inlet	7.8	88	64	182	16.0	15.6	5.2	Not meeting the standards
		Outlet	8.1	16	12	32	0.8	0.4	0.3	
	Total 20	OLMS	6.9	9.7	2.1	24.6	-	1.7	-	W.r.t TSS and BOD.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/87/618

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit
Nilothi STP -II
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
17.07.19
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P(mg/l) 5	
1	20	Inlet	7.8	146	135	380	30.4	29.6	6.3	Meeting the standards.
	Total 20	Outlet	7.5	8	6	20	0.4	1.6	0.6	

REMARKS: OLMS was in found locked at the time of DPCC monitoring.

M. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/89 /620

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Pappankala STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	20	Inlet	8.0	188	135	386	24.4	23.8	6.0	Not meeting the standards w.r.t TSS and BOD.
		Outlet	7.9	54	42	120	4.8	2.3	1.6	
	Total 20		7.5	37.7	21.8	139.	-	15.2	-	

REMARKS: OLMS was in found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/86 / 617

Date 13/08/2018

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019


- 1 Name & Address of Ind./Unit **Nilothi STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	40 Total 40	Inlet Outlet	7.6 7.9	186 56	135 34	396 96	32.4 4.4	30.6 4.1	6.2 1.2	Not meeting the standards w.r.t TSS and BOD

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/84 / 615

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019


- 1 Name & Address of Ind./Unit **Najafgarh STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	5	Inlet	7.8	216	180	540	28.4	27.8	6.3	Not meeting the Standards w.r.t TSS and BOD.
	Total 5	Outlet	8.0	56	46	140	4.8	4.6	1.3	

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/83 / 614

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Mehrauli STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **15.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters							Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	
			5.5-9.0	50	30	250	10	50	
								5	
1	15	Inlet	7.3	216	175	524	30.4	27.9	Meeting the standards.
		Outlet	7.6	24	20	64	1.2	2.0	
	Total 15	OLMS	7.32	24.3	21.7	128.7	-	14.8	
								-	

REMARKS: OLMS was ~~not~~ found locked at the time of DPCC monitoring.

N. Mitta
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

9



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/82 / 613

date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Keshopur STP New**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results


Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			5.5-9.0	30	20	250	10	50	5	
1	12	Inlet	7.8	196	140	380	24.4	23.9	5.6	Not meeting the standards w.r.t TSS and BOD.
		Outlet	7.5	32	26	80	3.2	2.9	1.6	
	Total 12									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

N. Mitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

[Signature]



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/81 / 612

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Kapashera**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P(mg/l) 5	
1	23	Inlet	7.6	128	95	280	24.4	23.6	5.8	Not Meeting the standards w.r.t TSS and BOD
		Outlet	7.7	20	16	56	0.8	1.2	0.4	
		OLMS	7.3	8.9	5.0	31.3	-	3.2	-	
	Total 23									

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006
Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/80/611

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit
- 2 Sampling location
- 3 Date of Inspection
- 4 Samples collected by
- 5 Parameters analyzed and results

Delhi Gate STP

Inlet and Outlet of STP

12.07.19

DPCC Lab

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	2.2	Inlet	7.3	228	190	580	32.4	30.6	6.4	Meeting the standards.
		Outlet	7.4	6	4	16	0.4	1.6	0.3	
	Total 2.2									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/79/610

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY - 2019

- 1 Name & Address of Ind./Unit
Delhi Gate STP New
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
12.07.19
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	15	Inlet	7.0	212	165	480	29.6	28.6	5.9	Meeting the Standards.
		Outlet	7.3	10	8	32	0.8	2.0	0.4	
	Total 15									

REMARKS: OLMS was in
found locked at the time of
DPCC monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/78/609

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY- 2019

- 1 Name & Address of Ind./Unit
Coronation Pillar STP
- 2 Sampling location
Inlet and Outlet of STP
- 3 Date of Inspection
08.07.19
- 4 Samples collected by
DPCC Lab
- 5 Parameters analyzed and results

Sr. No	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	Phase-I,II(20)	Inlet	7.6	180	130	360	26.4	28.4	7.1	Not meeting the standards w.r.t to BOD.
		Outlet	7.8	48	38	96	4.4	6.2	3.2	
		OLMS	7.2	77.5	39.8	141.0	-	24.9	-	
	Ph-III(10)	Inlet	7.7	240	165	428	28.4	28.6	6.5	Not meeting the w.r.t TSS and BOD.
		Outlet	8.0	78	46	124	6.4	5.9	3.8	
		OLMS	-	58.5	30.9	131.6	-	26.5	-	
	Total 30									

Remarks: OLMS was under maintenance

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/MINI STP/19-20/98 104/608

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit
2. Sampling location
3. Date of Inspection
4. Samples collected by
5. Parameters analyzed and results

STP Molarband

Inlet and Outlet of STP

11.07.19

DPCC Lab

Sr. No.	Installed Capacity (MLD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	2	Inlet	7.3	288	230	660	32.8	32.6	6.4	Not meeting the standards w.r.t BOD
		Outlet	7.6	48	36	96	4.0	3.9	2.3	
	Total 2									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/100/631

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019


1. Name & Address of Ind./Unit **Yamuna Vihar STP**
2. Sampling location **Inlet and Outlet of STP**
3. Date of Inspection **16.07.19**
4. Samples collected by **DPCC Lab**
5. Parameters analyzed and results

5. Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	Parameters								
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate As P(mg/l)	Remarks
			5.5-9.0	50	30	250	10	50	5	
1	Plant-I(10)	Inlet	7.6	156	120	364	26.4	25.9	5.6	Not Meeting the standards w.r.t TSS and BOD
		Outlet	7.4	62	46	136	4.8	4.2	1.6	
	Plant-II(10)	Inlet	7.5	156	135	400	26.4	26.2	6.5	Not Meeting the standards w.r.t TSS and BOD
		Outlet	7.4	68	54	172	5.2	4.8	1.9	
	Total 20									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006


Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/99/630

Date 13/08/2018

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit Yamuna Vihar STP- Ph III
2. Sampling location Inlet and Outlet of STP
3. Date of Inspection 16.07.19
4. Samples collected by DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			5.5-9.0	30	20	250	10	50	5	
1	25	Inlet	7.2	180	145	462	28.8	27.6	6.3	Not meeting the w.r.t Standards TSS and BOD.
		Outlet	7.5	86	34	144	2.4	2.2	1.3	
	Total 25	OLMS	7.2	40.8	36.8	119.9	-	20.9	-	
I/C <i>Misha</i> LABORATORY  SR. SCIENTIFIC ASSISTANT										

Te



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/98/629

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

- 1 Name & Address of Ind./Unit **Keshopur STP**
- 2 Sampling location **Inlet and Outlet of STP**
- 3 Date of Inspection **17.07.19**
- 4 Samples collected by **DPCC Lab**
- 5 Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
			5.5-9.0	50	30	250	10	50	5	
1	Plant-I(40)	Inlet	7.8	196	140	380	24.4	23.9	5.6	Not meeting the Standards w.r.t BOD.
		Outlet	7.6	42	34	96	3.6	3.2	1.4	
	Plant-II(20)	Inlet	7.8	196	140	380	24.4	23.9	5.6	Not meeting the standards w.r.t BOD.
		Outlet	7.4	46	38	120	4.0	3.8	1.9	
	Total 60									
	There is only one inlet for Plant-II & Plant-III.									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/97/628

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit
Chilla STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
18.07.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			5.5-9.0	10	10	250	10	50	5	
1	9	Inlet	7.7	112	90	270	14.4	13.6	4.2	Not meeting the standards w.r.t TSS and BOD.
		Outlet	7.8	16	12	36	1.2	1.0	0.3	
	Total 9									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

I/C
LABORATORY

SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/96 / 627

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit
Kondli STP New
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
16.07.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			5.5-9.0	10	10	250	10	50	5	
1	45	Inlet	7.6	168	140	420	24.4	23.6	5.6	Not meeting the Standards w.r.t TSS and BOD.
		Outlet	7.5	20	14	46	1.6	1.5	0.9	
	Total 45									

REMARKS: OLMS was found locked at the time of DPCC monitoring.

N. Maitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/19-20/95

1626

Date 13/08/2019

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit
Rithala STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
16.07.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		STP Standard	pH 5.5-9.0	TSS (mg/l) 50	BOD (mg/l) 30	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	Plant-I(40)	Inlet	7.7	228	165	480	32.4	31.2	6.8	Not meeting the standards w.r.t TSS and BOD.
		Outlet	7.6	58	46	132	4.4	3.6	1.2	
	Plant-II(40)	Inlet	7.7	228	165	480	32.4	31.6	6.8	Meeting the Standards.
		Outlet	7.6	28	22	60	3.6	2.8	1.0	
	Total 80									

There is only one inlet for Plant-II & Plant-III.

REMARKS: OLMS was found locked at the time of DPCC monitoring.

N. Mishra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/19-20/94/625

Date 13/08/2018

ANALYSIS REPORT OF STP FOR THE MONTH OF JULY -2019

1. Name & Address of Ind./Unit
Akshardham STP
2. Sampling location
Inlet and Outlet of STP
3. Date of Inspection
16.07.19
4. Samples collected by
DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH 5.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 250	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 50	Dissolved Phosphate as P (mg/l) 5	
1	1	Inlet	7.1	172	130	360	16.4	15.8	5.2	Meeting the Standards.
		Outlet	7.4	2	1	4	ND	ND	ND	
	Total 1									

REMARKS: OLMS was in found locked at the time of DPCC monitoring.

Maitra
I/C LABORATORY

[Signature]
SR. SCIENTIFIC ASSISTANT