



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/141/1308

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 12.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	INLET	7.9	204	75	220	12.4	21.9	22.3	-	Meeting the standards.
		OUTLET	7.4	6	4	48	0.8	2.3	1.5	130	
		OLMS	7.2	6.8	1.0	6.7	-	1.8	-	-	
Total 70											

N. Mishra
I/C Water Laboratory
Dr. Nandita Mishra
Scientist 'D'

Shashi
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/142/1309

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 12.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.7	228	125	268	12	23.4	25.4	-	Not meeting the standards wrt TSS, BOD, COD & Faecal Coliform.
		Outlet	7.4	22	16	80	1.2	2.2	1.7	1300	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
2	Ph-III (10)	Inlet	7.5	202	100	260	14.8	24.3	24.9	-	Not meeting the standards wrt TSS,BOD, COD & fecal coliform.
		Outlet	7.6	26	14	76	2	1.8	1.6	790	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
Total 30											

Milka
I/C Water Laboratory

Dr. Nandita Moltra
Scientist 'D'

[Signature]
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/143/1310

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.3	180	117	252	16.4	23.7	12.6	-	Meeting the Standards.
		Outlet	7.6	7	6	28	2.8	2.8	1.2	92	
		OLMS	7.4	6.7	2.7	22.4	-	3.4	-	-	
Total 15											

N. Mohita
I/C Water Laboratory

Dr. Nandita Mohita
Scientist 'D'

Shash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/144/ 1311

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.5	196	150	260	14.4	21.4	12.2	-	Meeting the Standards.
		Outlet	7.2	6	5	32	2.4	2.6	1.1	140	
		OLMS	7.3	5.0	2.0	15.1	-	1.1	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Nandita Mohita
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/145/1312

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.3	210	120	264	15.6	22.3	21.7	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.6	27	14	72	1.2	2.1	1.4	2100	
		OLMS	7.7	8.4	6.5	31.0	-	4.2	-	-	
Total 12											

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/146/1313

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.4	188	150	244	13.6	24.8	14.6	-	Meeting the Standards
		Outlet	7.1	7	5	36	1.2	2.2	0.8	120	
		OLMS	7.2	5.3	2.9	14.9	-	2.0	-	-	BOD reading not shown in OLMS
Total 2.2											

N. Mitta
I/C Water Laboratory

Dr. Nandita Molitra
Scientist 'D'

Anan
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/147/1314

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Fecal Coliform MPN/100ml 230	
1	20	Inlet	7.4	220	150	320	14.4	15.8	12.7	-	Meeting the standards.
		Outlet	7.2	5	3	44	1.6	1.8	1.6	81	
		OLMS	7.6	5.0	4.1	37.4	-	4.9	-	-	
Total 20											

Maitra
I/C Water Laboratory
Dr. Nandita Maitra
Scientist 'D'

Abhishek
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/148/1315

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.6	276	160	352	19.2	18.2	21.5		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	34	18	88	2.4	1.6	1.2	2200	
		OLMS	7.9	20.1	13.3	109.2	-	9.9	-	-	
Total 40											

N. Molra
I/C Water Laboratory
Dr. Nandita Molra
Scientist 'D'

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/149/1316

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.2	212	175	268	15.6	24.5	19.7	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	22	14	72	2.4	2.6	1.5	2200	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 5											

N. Maitra
I/C Water Laboratory

Dr. Nandita Maitra
Scientist 'D'

Shree
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/150/1317

Dated: 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.3	176	120	292	18.4	21.6	20.7	-	Meeting the standards
		Outlet	7.8	7	4	32	1.6	1.9	1.1	95	
		OLMS	-	-	-	-	-	-	-	-	OLMS was not installed
2	Ph-II(40)	Inlet	7.1	212	125	316	13.6	14.9	17.9	-	Meeting the standards
		Outlet	7.5	8	6	44	1.2	1.9	1.5	130	
		OLMS	7.4	9.3	7.1	38.7	-	7.4	-	-	
Total 80											

Mitra
I/C Water Laboratory
Dr. Nandita Mishra
Scientist 'D'

Sharma
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/151/1318

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.3	208	117	276	16	22.1	22.4	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.
		Outlet	7.5	35	18	68	2	2.4	1.4	1800	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 20											

Nandita
I/C Water Laboratory

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/152/1319

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.3	208	117	276	16	22.1	22.4	-	Meeting the Standards.
		Outlet	7.6	6	4	24	0.8	1.8	1.8	220	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 20											

Nandita
I/C Water Laboratory

Shree
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/153/1320

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.6	236	133	332	14.8	22.5	12.8	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	23	16	68	1.6	2.7	1.8	2100	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
Total 15											

N. Mohita
I/C Water Laboratory

Dr. Nandita Mohita
Scientist 'D'

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/154/1321

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.9	228	160	268	17.6	17.7	15.3	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	53	18	76	2.4	1.6	1.2	2200	
		OLMS					-	-	-		
Total 10											

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/155/1322

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.6	244	180	320	15.6	18.5	15.4	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	13	16	84	2.8	2.3	2.8	1700	
		OLMS	7.3	7.7	4.3	24.6	-	0.9	-	-	
Total 30											

N. Nanda

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/156/1323

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.5	236	150	272	13.2	24.8	21.3	-	Meeting the standards.
		Outlet	7.2	7	6	28	2.8	2.3	1.4	180	
		OLMS	7.9	6.4	5.2	19.6	-	1.5	-	-	
2	Ph-II & III (25+10)	Outlet	7.6	6	5	24	2.4	3.5	1.6	150	Meeting the standards
		OLMS	7.6	7.1	8.1	36.1	-	2.0	-	-	
Total 45											

I/C Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/157/1324

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.4	196	134	252	15.2	21.2	24.6	-	Meeting the Standards.
		Outlet	7.5	8	7	36	3.2	2.1	1.7	95	
		OLMS	7.3	27.8	11.6	73.8	-	14.5	-	-	
Total 45											

Nandita
I/C Water Laboratory

Dr. Nandita Moltra
Scientist 'D'

Abhishek
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommms.nic.in>)



Report Number: DPCC/W/STP/24-25/158/1325

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.4	224	160	296	18.8	22.4	12.8		Meeting the standards.
		Outlet	7.6	6	5	8	1.2	2.2	1.3	130	
		OLMS	7.5	8.2	4.9	43.9	-	2.9	-	-	
Total 5											

Nandita
I/C Water Laboratory

Dr. Nandita Molra
Scientist 'D'

Analyst
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/159/1326

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.4	216	150	312	11.2	16.6	26.3	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Colifrom.
		Outlet	7.6	28	16	72	1.2	1.7	1.4	1600	
		OLMS	7.9	20.3	11.3	55.6	-	20.0	-	-	
Total 25											

Nandita
I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/160/1327

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/ 100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.2	192	167	256	10.4	22.3	12.2	-	Meeting the Standards.
		Outlet	7.7	7	5	28	2.4	2.1	1.6	80	
		OLMS	7.2	7.9	6.1	33.7	-	1.7	-	-	
Total 9											

Nandita
I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/161/1328

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.5	160	134	240	17.6	16.8	11.8	-	Meeting the Standards.
		Outlet	7.8	6	4	24	1.6	1.4	1.8	74	
		OLMS	7.6	0.8	1.6	6.6	-	0.2	-	-	
Total 1											

Naitra
I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

Shash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/162/1329

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/ 100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.2	220	140	308	13.6	13.4	26.5	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	32	17	84	1.2	2.3	1.3	1400	
		OLMS	7.6	23.7	8.9	59.6	-	13.9	-	-	
Total 15											

Mishra

I/C Water Laboratory

Dr. Nandita Moltra

Scientist 'D'

SSA

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/163/1330

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.4	184	114	296	15.2	18.1	25.9	-	Not meeting the standards wrt TSS,BOD, COD & Fecal Coliform.
		Outlet	7.3	57	28	128	2.8	1.4	1.1	930	
		OLMS	7.0	8.7	5.5	43.3	-	7.7	-	-	
2	3	Inlet	7.5	172	125	312	14.8	17.7	24.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	61	30	108	3.6	1.8	1.7	790	
		OLMS	7.5	8.6	5.8	36.5	-	9.0	-	-	
Total 5.2											

Nandita
I/C Water Laboratory

Alka
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/164/1331

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 24.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.2	204	175	280	12	13.4	21.8	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform OLMS was non functional
		Outlet	7.5	19	17	68	1.6	2.5	1.3	2400	
		OLMS	-	-	-	-	-	-	-	-	
2	10 Ph-2	Inlet	7.6	212	180	284	14.8	15.2	20.2	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	17	15	64	0.4	2.2	1.5	540	
		OLMS	7.4	8.9	5.9	30.6	-	5.0	-	-	
Total 20											

Mitra
I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

Sharma
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/165/1332

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.8	196	150	276	12.8	22.6	14.7	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	28	16	96	1.6	1.7	1.4	1400	
		OLMS	7.3	38.1	-	-	-	14.0	-	-	BOD & COD Readings not shown in OLMS
Total 0.66											

Nandita
I/C Water Laboratory

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/166/1333

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.4	272	140	304	17.2	19.8	13.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	52	20	52	1.6	1.6	1.9	1400	
		OLMS	7.1	24.0	10.3	73.3	-	14.2	-	-	
	16	Outlet	7.5	32	8	36	0.8	0.5	1.1	140	Meeting the Standards.
		OLMS	7.4	9.1	7.1	31.5	-	3.4	-	-	
	37	Outlet	7.2	67	22	68	1.2	0.9	1.4	1600	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	7.2	23.6	15.7	63.0	-	12.6	-	-	
	45	Outlet	7.5	62	18	64	2.4	1.3	1.7	1800	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	6.8	21.3	12.8	61.2	-	9.2	-	-	
	Total 110										

Nandita
I/C Water Laboratory

Dr. Nandita Mohtra
Scientist 'D'

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/167/1334

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.8	222	150	280	20	22.8	22.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	23	14	64	1.6	3.1	1.7	790	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
2	20	Outlet	7.2	21	21	60	1.2	3.4	1.3	1300	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 60											

Naitra
I/C Water Laboratory

Dr. Naitra Moitra

Scientist 'D'

Arach
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/168/1335

Dated 11/10/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER-2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.09.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.3	244	167	320	13.6	17.5	22.8	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	62	35	96	1.6	1.9	1.6	2200	
		OLMS	7.6	18.6	12.8	68.7	-	14.7	-	-	
Total 5											

Nandita
I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

Abhishek
SSA/Analyst/SLA