



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/283/1651

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	70 MGD	Inlet	7.6	164	87	228	14.4	10.6	11.2	230	Meeting the standards.	
		Outlet	7.3	8	7	20	1.6	0.8	0.7	70		
		OLMS	-	-	-	-	-	-	-	-		OLMS was non functional.
Total 70												

KC Sharma Laboratory
B-5, Sharda

SSA/Analyst/SLA

Sharma

Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/284/1652

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

Dated 11/3/2025

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.7	244	163	324	16.8	10.3	10.7		Meeting the standards.
		Outlet	7.6	9	7	44	0.8	1.1	0.8	170	
		OLMS	7.4	9.6	6.2	30.1	-	4.5	-	-	
2	Ph-III (10)	Inlet	7.5	258	143	332	14.8	11.0	10.2		Meeting the standards.
		Outlet	7.7	8	6	36	1.6	0.9	0.8	90	
		OLMS	7.7	6.5	4.2	20.8	-	1.2	-	-	
Total 30											

I/C Water Laboratory

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/285/1653

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.5	216	100	276	17.2	10.7	10.4		Meeting the Standards.
		Outlet	7.4	7	3	20	0.8	0.8	0.7	84	
		OLMS	7.3	6.6	3.0	22.7	-	3.0	-	-	
Total 15											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/286/1654

Dated 11/2/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.4	298	160	324	12.8	8.9	9.7	-	Not meeting the standard wrt Fecal Coliform.
		Outlet	7.2	8	6	32	1.2	0.7	0.7	1200	
		OLMS	7.0	3.2	2.8	17.3	-	1.6	-	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/287/1655

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	12	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
			7.3	246	140	320	14.4	11.8	12.3		
			7.1	32	13	72	0.8	0.8	0.6	1700	
			7.4	9.5	7.3	38.8	-	1.6	-	-	
Total 12											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/288/1656

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.4	206	150	344	14.8	9.8	9.9		Not meeting the standards wrt fecal coliform
		Outlet	7.5	5	4	40	0.8	0.8	0.8	440	
		OLMS	7.4	6.1	5.7	23.2	-	1.5	-	-	
Total 2.2											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/24-25/289/1657

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.3	274	120	288	16	7.8	9.6		Meeting the standards.
		Outlet	7.6	6	4	32	0.8	0.6	0.5	95	
		OLMS	7.6	6.7	4.3	38.8	-	3.5	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/290/1658

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	40	Inlet	7.7	288	140	324	11.6	8.8	9.2		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.9	27	14	72	1.6	0.7	0.8	1200		
		OLMS	7.8	21.7	14.7	100.5	-	11.5	-	-		
Total 40												

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/291/1659

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	5	Inlet	7.9	248	133	284	21.6	8.2	7.7	230	Meeting the standards.	
		Outlet	7.8	8	6	36	1.2	0.9	0.8			
		OLMS	-	-	-	-	-	-	-			
Total 5											OLMS was non functional	

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/292/1660

Dated: 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

- 1.
2. Name of STP : Rithala
3. Sampling location : Inlet and Outlet of STP
4. Date of Inspection : 18.02.2025
5. Samples collected by : DPCC Lab
6. Parameters analyzed and results

Parameters											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	Meeting the standards
1	Ph-I(40)	Inlet	7.3	196	167	416	21.2	9.3	9.6		
		Outlet	7.2	8	7	28	1.2	0.9	0.6	80	
		OLMS	-	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.4	272	120	296	19.2	5.9	8.8		Meeting the standards
		Outlet	7.3	5	4	36	0.4	1.1	0.9	140	
		OLMS	7.9	9.2	6.0	36.0	-	5.2	-	-	
Total 80											

I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/293/1661

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.7	274	160	388	20.4	10.1	9.0		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	24	12	76	0.8	0.6	0.7	1500	
		OLMS	7.6	23.9	14.3	79.0	-	7.6	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/294/1662

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	7.7	274	160	388	20.4	10.1	9.0		Not meeting the Standards wrt Fecal Coliform.
		Outlet	7.5	9	6	40	1.2	0.7	0.6	840	
		OLMS	8.3	5.8	3.9	25.5	-	1.9	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/24-25/295/1663

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	15	Inlet	7.1	168	150	350	18.8	10.3	11.7			Meeting the standards.
		Outlet	7.3	8	5	28	1.2	0.8	0.7	70		
		OLMS							-	-		
Total 15												

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/24-25/296/1664

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	10	Inlet	6.5-9.0	10	10	50	10	5		2	230	Meeting the standards.
		Outlet	7.2	230	167	344	16.8	9.3	10.7		50	
		OLMS	7.4	6	5	32	0.8	0.6	0.5			
Total 10			7.4	7.4	4.6	21.9	-	2.7	-	-		

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/297/1665

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	7.6	248	175	352	21.2	9.3	10.9		Meeting the Standards.
		Outlet	7.2	8	7	32	1.2	0.9	0.6	170	
		OLMS	7.7	6.4	5.9	25.2	-	1.4	-	-	
Total 30											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)




Report Number: DPCC/W/STP/24-25/298/1666

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I (10)	Inlet	7.5	210	160	324	12.4	9.8	10.1		Meeting the standards.	
		Outlet	7.4	5	4	28	2	0.7	0.8	95		OLMS was non functional.
		OLMS	-	-	-	-	-	-	-	-		
2	Ph-II & III (25+10)	Outlet	7.6	7	6	24	0.8	1.3	0.7	120	Meeting the standards.	
		OLMS	-	-	-	-	-	-	-	-		OLMS was non functional.
Total 45												

Dr.  Shalini
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/299/1667

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2025

1. Name of STP : Koncili New
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	Ph-IV (45)	Inlet	7.5	230	120	280	17.6	9.1	10.4		Meeting the Standards.
		Outlet	7.6	6	4	28	1.2	0.9	0.8	150	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional.
Total 45											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta

Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/300/1668

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	7.6	250	175	396	17.2	10.6	11.2		Meeting the standards.
		Outlet	7.5	9	7	36	1.2	1.1	0.9	170	
		OLMS	7.3	8.4	4.7	31.7	-	3.4	-	-	
Total 5											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/301/1669

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.2	264	140	284	19.2	10.7	8.9	230	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.7	32	14	64	1.6	0.8	0.9	150	
		OLMS	7.2	18.1	11.9	64.7	-	14.3	-	-	
Total 25											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/24-25/302/1670

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	9	Inlet	7.3	212	140	352	14.4	10.2	10.1		Meeting the Standards.
		Outlet	7.4	8	6	40	2	0.8	0.7	84	
		OLMS	7.5	6.5	4.3	25.9	-	3.2	-	-	
Total 9											

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/303/1671

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	1	Inlet	7.4	180	120	308	18.4	10.7	10.2		Meeting the Standards.
		Outlet	7.3	6	4	24	1.2	0.8	0.8	76	
		OLMS	7.6	0.7	1.5	5.8	-	0.2	-	-	
Total 1											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta

Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/304/1672

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
1	15	Inlet	7.6	274	163	336	14.4	10.2	8.2		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.3	32	17	76	1.6	0.8	0.7	1400		
		OLMS	7.2	15.4	7.8	37.9	-	4.3	-	-		
Total 15												

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta

Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/305/1673

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Vasant Kuni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	2.2	Inlet	7.7	262	220	464	16.4	10.1	9.9	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.6	56	35	68	1.6	1.1	0.8	1400		
		OLMS	8.1	6.9	4.7	32.4	-	6.6	-	-		
2	3	Inlet	7.8	210	186	380	16	10.7	10.4		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.5	54	36	88	1.2	0.9	0.7	1600		
		OLMS	7.7	9.4	6.2	30.9	-	7.8	-	-		
Total 5.2												

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/306/1674

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 21.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		7.8	256	120	308	13.6	10.4	8.7			
		Outlet	7.4	29	16	68	0.8	0.6	0.6	950	
		OLMS	7.8	11.4	8.2	30.9	-	16.4	-	-	
2	10 Ph-2	Inlet	7.3	226	140	328	16	9.3	8.2		Meeting the standards.
		Outlet	7.7	8	6	32	0.8	0.7	0.7	84	
		OLMS	7.3	8.1	6.1	30.1	-	6.4	-	-	
		Total 20									

Dr. Shweta Singh
Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/307/1675

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)		Fecal Coliform MPN/100ml
1	0.66	Inlet	7.3	294	160	340	10	5	9.1		Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.5	33	25	72	1.6	0.1	0.6	1100	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											OLMS was non functional

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/308/1676

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

Dated 11/3/2025

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
16		Inlet	7.4	280	200	452	23.6	11.2	10.7		
		Outlet	7.1	6	5	36	1.6	0.8	0.8	140	
		OLMS	7.3	12.2	5.7	42.9	-	7.4	-	-	
Total 16											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/309/1677

Dated 11/3/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 14.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	40		6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.	
		Inlet	7.6	248	133	324	18.4	11.6	11.8			
		Outlet	7.1	28	18	60	1.2	1.0	0.8	1300		
		OLMS	-	-	-	-	-	-	-	-		
2	20	Outlet	7.3	25	14	56	1.6	1.1	0.6	1600	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.	
		OLMS	-	-	-	-	-	-	-	-		-
Total 60											OLMS was non functional	

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/310/1678

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

Dated 11/3/2025

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.02.2025
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	5	Inlet	7.7	268	183	424	18.4	10.1	9.8		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.	
		Outlet	7.6	62	33	92	1.6	0.8	0.7	2200		
		OLMS	7.6	21.0	13.9	53.4	-	8.6	-	-		
Total 5												

I/C Water Laboratory

Dr. Shweta Gupta

Incharge (Water Laboratory)

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/311/1679

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

Dated 11/3/2025

6. Name of STP : Sonia Vihar
7. Sampling location : Inlet and Outlet of STP
8. Date of Inspection : 21.02.2025
9. Samples collected by : DPCC Lab
10. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	7	Inlet	7.9	248	160	332	11.6	9.8	8.5	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	37	17	72	1.2	0.6	0.9	460	
		OLMS	-	-	-	-	-	-	-	-	
Total 7											OLMS Not installed

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/24-25/312/1680

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY -2025

Dated 11/3/2025

11. Name of STP : Okhla
12. Sampling location : Inlet and Outlet of STP
13. Date of Inspection : 17.02.2025
14. Samples collected by : DPCC Lab
15. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	7.4	280	200	452	23.6	11.2	10.7	-	Meeting the Standards.
		Outlet	7.5	6	5	28	0.8	0.8	0.7	140	
		OLMS	-	-	-	-	-	-	-	-	
Total 124											OLMS Not installed

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Shweta Gupta
Incharge (Water Laboratory)