



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/01/2951

Dated: 09/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Name & Address of Ind./Unit : Coronation Pillar STP
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 11.01.2021
4. Samples collected by : DPCC, Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	Parameters COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Remarks
1	Ph-I,II(20)	Inlet	7.0	192	108	160	10.8	35.5	17.0	Not meeting the Standards w.r.t TSS, BOD, COD & A.N.
		Outlet	7.2	40	18	92	7.2	5.3	1.7	
		OLMS*	-	-	-	-	-	-	-	
2	Ph-III(10)	Inlet	7.3	152	88	132	8.4	33.4	7.7	Not meeting the standards w.r.t TSS, BOD, COD, A.N & DP.
		Outlet	7.1	96	60	128	6.4	7.8	4.4	
		OLMS*	-	-	-	-	-	-	-	
Total 30										
Remarks: Ph-I, II & III OLMS was not working										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/02 | 2952

Dated : 09/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Delhi Gate STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
				10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.0	268	126	260	32.4	34.5	17.0	Not meeting the Standards w.r.t. TSS
		Outlet	7.0	12	4	28	0.4	3.5	1.2	
		OLMS*	7.08	4.21	4.78	24.74	-	1.03	-	
Total 15										

SCIENTIST "D"

Maitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/04 / 2953

Dated : 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Keshopur STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	12	Inlet	7.3	352	330	480	36.0	54.7	17.1	Not meeting the standard w.r.t TSS.
		Outlet	7.2	18	4	24	0.8	4.1	1.5	
		OLMS*	7.35	8.52	4.19	23.11	-	2.70	-	
Total 12										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/03/ 2954

Dated : 9/02/21

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Name & Address of Ind./Unit : DELHI GATE STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 06.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II(2.2)	Inlet	7.1	252	136	212	24.0	34.8	20.5	Meeting the Standards.
		Outlet	6.5	8	2	32	0.4	3.7	1.7	
		OLMS*	7.67	7.39	3.91	19.61	-	1.76	-	
Total 2.2										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/05/2955

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Sampling location : Inlet and Outlet of STP
2. Name & Address of Ind./Unit : SEN Nursing Home (SNH)
3. Date of Inspection : 06.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
						COD (mg/l)				
				10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.1	184	106	208	20.8	34.5	15.3	Meeting the Standards.
		Outlet	6.8	10	6	24	1.6	3.0	1.3	
		OLMS*	6.89	4.37	5.42	21.14	-	1.74	-	
Total 2.2										

SCIENTIST "D"

N. Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/06/2956

Dated : 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Name & Address of Ind./Unit : Nilothi STP-II
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.1	160	110	260	11.6	22.8	6.0	Not meeting the Standards w.r.t TSS.
		Outlet	7.3	12	5	24	1.2	2.6	1.4	
		OLMS*	6.58	7.25	7.24	50.31	-	1.31	-	
Total 20										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/07/2957

dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Name & Address of Ind./Unit : Nilothi STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters				Remarks
						COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	40			10	10	50	10	5	2	
		Inlet	7.3	156	100	240	7.2	32.4	16.4	Not meeting the standards w.r.t to TSS, BOD, COD, A.N & DP.
		Outlet	7.4	58	32	80	4.4	6.9	3.1	
		OLMS*	6.95	85.60	63.28	210.26	-	22.34	-	
Total 40										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/08 / 2958

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Najafgarh STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.1	528	190	268	39.6	54.8	16.3	Not meeting the standards w.r.t to TSS BOD, A.N & DP.
		Outlet	7.0	22	16	32	3.2	6.8	2.3	
		OLMS*	7.38	32.93	18.32	65.03	-	-	-	
Total 5										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/09/2959

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Rithala STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	Phase-I(40)	Inlet	7.1	280	118	248	24.8	34.9	17.1	Not meeting the standards w.r.t to TSS, BOD, COD, A.N. & DP
		Outlet	7.1	104	98	200	6.4	17.2	8.9	
		OLMS*	7.09	86.56	45.65	165.81	-	7.09	-	
2	Ph-II(40)	Inlet	7.1	280	118	200	24.8	34.9	17.1	Not meeting the standards w.r.t to TSS, BOD, COD, & DP
		Outlet	7.2	16	12	80	2.0	3.3	2.8	
		OLMS*	7.74	13.68	9.42	66.29	-	6.70	-	
Total 80										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/10/2960

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Pappankalan STP(Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.2	148	85	184	9.2	24.8	6.1	Not meeting the Standards w.r.t TSS, BOD, A.N, COD & DP.
		Outlet	7.4	68	38	96	8.0	5.8	2.6	
		OLMS*	7.37	29.29	20.15	34.14	-	-	-	
Total 20										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/11 / 296/

Dated : 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Pappankalan STP-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	20	Inlet	7.1	276	115	260	24.0	28.9	14.8	Meeting the Standards.
		Outlet	7.2	10	8	28	2.0	3.6	1.8	
		OLMS*	-	7.68	4.82	29.79	-	-	-	
Total 20										

SCIENTIST "D"

N. Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/20-21/12) 2962

Dated : 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Rohini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	15	Inlet	6.6	396	160	216	36.0	33.2	16.6	Not meeting the Standards w.r.t TSS.
		Outlet	7.2	14	8	32	2.0	3.5	1.6	
		OLMS*	7.42	20.32	12.07	54.27	-	10.20	-	
Total 15										

SCIENTIST "D"

Nandita Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/13 / 2963

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Narela STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10	Inlet	8.1	172	125	184	19.6	34.9	16.8	
		Outlet	7.1	28	13	88	2.4	3.4	1.8	
		OLMS*	-	-	-	-	-	-	-	Not Meeting the Standards w.r.t TSS, BOD & COD.
Total 10										

Remarks: OLMS was found non-operational.

SCIENTIST "D"

SCIENTIST "C"

Nandita Moitra
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/14 / 2964

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Okhla STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	30	Inlet	7.3	252	185	360	24.0	62.8	11.9	Meeting the Standards.
		Outlet	7.3	8	6	30	0.4	2.7	1.1	
		OLMS*	7.28	3.93	7.20	32.20	-	0.08	-	
Total 30										

SCIENTIST "D"

SCIENTIST "C"

Nandita
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/15/2965

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Kondli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.4	352	82	192	36.4	72.8	16.8	Not meeting the Standards w.r.t TSS, COD & A.N.
		Outlet	7.2	16	4	64	2.8	6.7	1.9	
		OLMS*	7.33	16.66	10.96	35.61	-	-	-	
Total 25										

SCIENTIST "D"

Nandita Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/16/2966

Dated: 09/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Kondli STP New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Remarks
				10	10	50	10	5	2	
1	45	Inlet	7.5	368	138	416	38.4	48.7	14.9	Not Meeting the Standards w.r.t TSS, BOD, COD, A.N. & DP.
		Outlet	7.4	100	24	108	8.0	10.8	9.6	
		OLMS*	-	-	-	-	-	-	-	
Total 45										

Remarks: OLMS was found locked

SCIENTIST "D"

N. Moitra
N. Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/17/2967

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Kapasahera STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	5	Inlet	7.1	452	175	260	32.8	64.2	15.8	Meeting the Standards.
		Outlet	7.3	8	4	22	0.8	3.8	1.1	
		OLMS*	-	-	-	-	-	-	-	
Total 5										

Remarks: OLMS was found non-operational.

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/18/2968

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	25	Inlet	7.6	540	160	452	21.6	39.7	8.4	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P
		Outlet	7.1	70	25	76	6.8	8.8	6.9	
		OLMS*	-	31.84	18.42	78.41	-	-	-	
Total 25										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/19 | 2969

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Chilla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	9	Inlet	7.5	260	150	296	19.2	56.2	11.8	Meeting the Standards.
		Outlet	7.8	8	2	36	0.8	4.8	1.3	
		OLMS*	7.16	7.67	4.87	15.11	-	-	-	
Total 9										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/20 | 2970

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Akshardham STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitr ogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	1	Inlet	7.5	32	17	48	5.2	11.8	5.0	Meeting the Standards.
		Outlet	7.8	6	4	16	0.4	1.2	0.7	
		OLMS*	-	0.77	1.48	14.08	-	-	-	
Total 1										

SCIENTIST "D"

N. Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/21/2971

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Mehrauli STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
m	15	Inlet	7.18	120	88	156	13.2	28.4	13.5	Meeting the standards
		Outlet	7.3	6	3.5	24	0.4	1.7	0.9	
		OLMS*	7.17	8.27	7.44	34.55	-	2.94	-	
Total 15										

SCIENTIST "D"

SCIENTIST "C"

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/22 / 2972

Dated 19/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Vasant Kunj STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 15.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	2.2	Inlet	7.3	252	104	272	17.6	52.0	18.5	.Not Meeting the Standards w.r.t TSS, BOD & COD, A.N.
		Outlet	7.2	28	20	64	2.4	5.2	1.6	
		OLMS*	7.41	8.24	17.19	52.61	-	4.18	-	
2	3	Inlet	7.1	168	98	228	13.2	24.0	15.8	Not Meeting the Standards w.r.t DP.
		Outlet	7.2	10	4	40	2.4	4.9	2.1	
		OLMS*	7.68	8.19	7.42	23.99	-	1.93	-	
Total 5.2										

SCIENTIST "D"

N. Moitra
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/23/2973

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Yamuna Vihar STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 13.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.6	284	124	344	19.6	35.0	9.4	Not meeting the standards w.r.t TSS.
		Outlet	7.3	12	3	36	1.6	3.3	1.4	
		OLMS*	7.17	23.36	10.22	47.48	-	-	-	
2	10 Ph-2	Inlet	7.5	280	100	184	11.6	48.4	6.9	Meeting the Standards.
		Outlet	7.1	10	4	24	1.6	1.2	1.9	
		OLMS*	-	-	-	-	-	-	-	
Total 20										
Parameters OLMS* are not to be analyzed										

Remarks: OLMS was not working.

SCIENTIST "D"

N. Mehta
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/24/2974

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Okhla STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
1	12	Inlet	7.29	164	10 90	50 220	10 17.6	5 42.7	2 10.5	Not meeting the Standards w.r.t TSS & BOD,COD, A.N & D.P.
		Outlet	7.29	96	42	104	8.4	10.8	3.9	
		OLMS	-	-	-	-	-	-	-	
	16	Outlet	7.37	16	10	48	1.2	2.1	1.7	Not meeting the Standards w.r.t TSS, BOD.
		OLMS	7.41	14.53	11.80	34.95	-	3.43	-	
	37	Outlet	7.3	70	42	184	6.4	9.6	2.9	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & DP.
		OLMS	-	-	-	-	-	-	-	
	45	Outlet	7.32	36	22	56	4.8	5.4	1.9	Not meeting the Standards w.r.t TSS, BOD, COD, A.N.
		OLMS	-	-	-	-	-	-	-	
Total 110										
Remarks: OLMS (12, 37 & 47 MGD) was not working due to electricity failure										

Remarks: OLMS (12, 37 & 47 MGD) was not working due to electricity failure.

SCIENTIST "D"

N. Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/20-21/25/2975

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021


1. Name & Address of Ind./Unit : Keshopur STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

STP Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	40	Inlet	7.1	112	64	160	9.6	18.4	12.1	Not meeting the Standards w.r.t TSS,BOD,COD, A.N & D.P.
		Outlet	7.1	42	29	76	5.6	5.8	4.6	
		OLMS*	7.88	120.37	67.76	245.51	-	319.24	-	
2	20	Inlet	7.1	680	280	500	38.4	77.4	15.9	Not meeting the Standards w.r.t TSS, BOD, COD, A.N & D.P.
		Outlet	7.3	174	78	160	9.8	17.8	5.4	
		OLMS*	7.23	124.37	86.16	183.02	-	23.44	-	
Total 60										

I/C LABORATORY

SR. SCIENTIFIC ASSISTANT

Nandita
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number : DPCC/W/STP/20-21/01/2976

Dated: 9/02/2021

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2021

1. Name & Address of Ind./Unit : Molarband Mini STP
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 20.01.2021
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	pH 6.5-9.0	TSS (mg/l)	BOD (mg/l)	Parameters COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Remarks
				10	10	50	10	5	2	
1	0.66	Inlet	7.3	376	210	136	32.0	69.7	16.5	Not meeting the Standards w.r.t TSS, BOD & COD.
		Outlet	7.5	16	12	80	2.8	4.7	2.0	
		OLMS*	7.36	32.91	18.02	50.69	-	2.53	-	
Total 0.66										

SCIENTIST "D"

Nandita
Dr. Nandita Moitra
Scientist 'D'

SCIENTIST "C"