



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

WASTE WATER QUALITY STATUS OF DRAIN

Date- 26/02/26

REPORT NO: DPCC/W/D/2026/42-63/2628

Date of Sampling: - 04.02.2026

S.No.	Sampling location	BOD (mg/l)	COD (mg/l)	TSS (mg/l)	pH
	Standards	30	250	100	5.5- 9.0
1.	Sonia Vihar Drain	40	192	112	7.6
2.	Najafgarh Drain	65	172	90	7.4
3.	Magazine Road Drain	NO FLOW			
4.	Sweeper Colony Drain				
5.	Khyber Pass Drain				
6.	Metcalf House Drain				
7.	ISBT Drain	80	284	168	7.2
8.	Tonga Stand Drain	NO FLOW			
9.	Moat (Vijay Ghat) Drain				
10.	Shastri Park Drain	50	168	258	7.6
11.	Kailash Nagar Drain	45	148	180	7.4
12.	Civil Mill Drain	NO FLOW			
13.	Power House/Delhi Gate Drain	90	236	136	7.1
14.	SEN Nursing Home Drain	150	452	152	7.2
15.	Drain No. 12A	NO FLOW			
16.	Drain No. 14				
17.	Barapulla Drain	70	212	70	7.3
18.	Maharani Bagh Drain	90	332	60	7.8
19.	Abul Fazal Drain	50	160	30	7.7
20.	Shahdara Drain	100	288	240	7.3
21.	RME/RD - 180	100	280	176	7.5
22.	Jaitpur Drain	50	180	40	7.3

Scientist B

I/C WATER LAB



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



WASTE WATER QUALITY STATUS OF DRAIN

date- 26/02/26

REPORT NO: DPCC/W/D/2026/64-75/ 2629

DATE OF SAMPLING: 05.02.2026

S. No	Name of Drain	Coordinates	BOD (in mg/l)	COD (in mg/l)	TSS (in mg/l)	pH	Tapping Status
Standard			30	250	100	5.5-9.0	
I. Additional New Location of Drains in Delhi							
A	Najafgarh Drains						
1.	Supplementary Drain	N 28.711166 E 77.227446	70	200	276	7.8	
2.	DD 6 Drain	N 28.857277 E 77.123535	50	168	216	7.3	Untapped
3.	Mungeshpur Drain	N 28.626779 E 77.018498	70	248	450	7.5	Untapped
4.	Bupania Drain	N 28.661968 E 76.953698	60	184	260	7.4	Untapped
B.	Najafgarh Jheel						
5.	Najafgarh Jheel Upstream		32.0	88	66	7.6	
6.	L3 Drain		115.0	360	272	7.1	Untapped
7.	L2 Drain		95.0	352	284	7.4	Untapped
8.	L1 Drain		90.0	304	302	7.2	Untapped
9.	Najafgarh Jheel Downstream		55.0	144	166	7.3	
C.	UP Drains out falling into Shahadra Drain						
10.	Banthala Drain	N 28.709745 E 77.287447	70	244	500	7.6	Untapped
11.	Indrapuri Drain	N 28.7098 E 77.286677	190	512	510	7.1	Untapped
12.	Sahibabad Drain	N 28.62606 E 77.33105	180	480	250	6.9	Untapped

Scientist B

I/C WATER LAB

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**WASTE WATER QUALITY STATUS OF DRAIN***Date- 26/02/26*REPORT NO: DPCC/W/D/2026/76-81/ *2630*

DATE OF SAMPLING: 04.02.2026

S. No	Name of Drain	Coordinates	BOD (in mg/l)	COD (in mg/l)	TSS (in mg/l)	pH	Tapping Status
Standard			30	250	100	5.5-9.0	
II. Drains Out falling into Agra Canal							
13.	Agra Canal Jaitpur	N 28.56246 E 77.29149	45	168	124	7.0	-
14.	Drain Near LPG Bottling Plant	N 28.53779 E 77.30593	No Flow				Tapped
15.	Sarita Vihar Pool	N 28.5424277 E 77.3090855	60	176	56	7.5	-
16.	Drain Near Sarita Vihar Bridge (Mathura Road)	N 28.52511 E 77.29232	No Flow				Tapped
17.	Tuglakabad Drain	N 28.5114 E 77.31199	120	304	118	7.8	Tapped
18.	Molarband Drain	N 28.50106 E 77.31402	Tapped				

Scientist B**I/C WATER LAB**