



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomc.nic.in>)



Report Number: DPCC/W/STP/24-25/1/829

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 12.04.2024
4. Sample collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	Parameters								Remarks
		pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	70 MGD	STP Standard	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
		Inlet	7.8	232	160	360	17.5	23.6	23.4	
		Outlet	7.4	6	4	20	3.5	3.2	0.8	
		OLMS	7.5	6.5	7.5	34.9	-	1.6	-	
Total 70										

M. Mittal

Dr. Manjori Mohita
Scientist D

MC LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocoms.nic.in>)



Report Number: DPCC/W/STP/24-25/21/830

Dated 8/5/2024

1. Name of STP
2. Sampling location
3. Date of inspection
4. Samples collected by
5. Parameters analyzed and results

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

Coronation Pillar
Inlet and outlet of STP
12.04.2024
DPCC Lab

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-1,II (20)	Inlet	7.4	256	160	352	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	28	20	55	10.8	24.8	12.6	
		OLMS	7.6	12.7	8.4	42.3	3.6	3.4	2.2	
		Inlet	7.2	220	60	184	-	5.3	-	
2	Ph-1,II (10)	Outlet	7.3	38	18	64	23.2	19.8	22.6	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		OLMS	-	-	-	4	2.6	2.4		
			-	-	-	-	-	-		
Total 30										OLMS was non-functional

Dr. Mandita Mohita
Jr. Lab. In-charge



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kushmore Gate, Delhi 110006
(Visit us at <https://www.dpccnctmss.nic.in>)



Report Number: DPCC/W/STP/24-25/3/821

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-I, II (15)	Inlet	7.2	10	10	50	10	5	2	Meeting the Standards.
		Outlet	7.3	7	5	16	2.4	4.2	1.1	
		OLWS	7.4	6.9	6.4	24.5	-	0.8	-	
		Total 15								

Mukta
Dr. K. LABODHAR
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/4/832

Dated: 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
Ph-1 & II (2.2)		Inlet	7.3	216	150	344	17.6	23.6	14.9	Meeting the Standard.
		Outlet	7.4	10	5	28	3.2	2.8	1.5	
		OLMG	7.3	5.9	2.4	17.9	-	1.3	-	
Total 2.2										

W/C LABORATORY
Dr. Vandita Mishra
Scientist 'D'

Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/5/823

Dated: 8/27/2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphata as P(mg/l)	
1	12	Inlet	7.6	228	125	320	15.4	32.4	25.4	Not Meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	20	12	68	0.8	1.9	2.2	
		OLMS	7.7	9.4	7.1	30.6	-	4.5	-	
Total 12										

Dr. Vandana Mishra
IC LABORATORY
Scientist-Dr



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STW/24-25/6/834

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Phase-1, II (2.2)	Inlet	7.5	256	120	336	16.4	21.8	25.1	Meeting the Standards
		Outlet	7.7	9	7	32	2.8	3.6	1.5	
		OLMS	7.5	5.2	3.2	24.3	-	1.5	-	
Total 2.2										

Dr. Ashwini Kumar
Scientist-III



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/M/STP/24-25/7/835

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.1	164	75	224	12.8	17.8	27.8	Missing the standards
		Outlet	7.2	8	4	36	1.2	1.3	1.4	
		OLWS	7.9	7.2	6.7	46.6	-	2.5	-	
		Total 20								

M. Maitra

LABORATORY

Dr. Mandita Maitra

Sample ID



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccnmns.nic.in>)



Report Number: DPCC/M/STP/24-25/8/ 836

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (Mgd)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40		6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & COD.
		Inlet	7.4	232	80	256	10.8	20.7	24.6	
		Outlet	7.2	28	14	54	2.4	1.8	1.2	
		CLMS	8.3	31.4	20.7	176.4	-	15.5	-	
Total <C										

M. Kumar

I/C LABORATORY

LIFE LABORATORY

Subsector 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccnm.nic.in>)



Report Number DPCC/W/STP/24-25/9/837

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.3	220	120	424	15.6	28.5	24.1	Not meeting the standards wrt TSS, BOD and COD, Dissolved Phosphate.
		Outlet	7.1	38	20	92	1.2	3.4	4.2	
		GLMS	8.2	21.3	15.5	92.4	-	16.1	-	
Total 5										

M. Jaiswal
W/C LABORATORY
Dr. Manojita Mohita
Secretary D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctnms.nic.in>)



Report Number: DPCC/W/STP/24-25/10/828

Dated: 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-1(40)	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-11(40)	Inlet	7.3	264	160	288	13.6	19.8	20.5	Meeting the standards
		Outlet	7.2	9	6	32	2.4	2.6	1.2	
		OLMS	7.9	8.7	6.4	49.1	-	5.8	-	
Total 80										

Signature
Dr. Naigraha
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccoccmms.nic.in>)



Report Number: DPCC/W/STP/24-25/11/839

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 02.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	20	Inlet	7.5	284	140	272	16.4	24.6	32.6	Not meeting the Standards wrt TSS, BOD COD & Dissolved Phosphate.
		Outlet	7.2	27	12	54	2.4	2.2	3.6	
		OLWS	7.4	24.4	16.2	109.9	-	14.9	-	
Total 20										

I/C LABORATORY

[Signature]

Dr. Vandana Mishra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccnctnms.nctn.in>)



Report Number: DPCC/W/STP/24-25/12/840

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 02.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
20		6.5-9.0	10	10	50	10	5	2	Meeting the Standards.	
		Inlet	7.5	294	140	272	16.4	24.6		32.6
		Outlet	7.4	7	4	24	0.8	3.4		1.2
		OLMS	7.4	6.5	5.2	33.0	-	1.7		-
Total 20										

W/C LABORATORY

Dr. Mandita Mohita

Sd/- 8/5/24



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110016

(Visit us at <https://www.dpccomms.nctn>)



Report Number DPCO/W/STP/24 25/13/841

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 12.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	15	Inlet	7.4	384	140	392	14.4	25.4	15.2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.2	24	12	88	5.2	4.5	3.4	
		OLMS	7.7	26.0	7.0	52.6	-	11.3	-	
Total 15										

Dr. Anurag Mittal
Sole Director

I/C LABORATORY

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/24-25/24/ 842

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of inspection : 23.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	232	90	208	13.6	17.7	13.8	
		OLMS	7.3	27	14	52	2.4	2.2	2.6	
Total 10		OLMS	-	-	-	-	-	-	-	OLMS was non-functional

Dr. Manjita Mohita

INC LABORATORY

Signature of



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommission.in>)



Report Number: DPCC/W/STP/24-25/15/243

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters										Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	30	Inlet	7.8	164	100	304	10.8	25.4	30.4	Meeting the Standards.
		Outlet	7.2	8	5	28	0.8	3.2	1.4	
		OLMS	8.1	5.9	3.9	23.7	-	0.8	-	
Total 30										

[Signature]

EC LABORATORY
Dr. Nandita Mishra

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccenmms.nic.in>)



Report Number: DPCC/W/STP/24-25/16/844

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2	Meeting the standards.
		Outlet	7.6	168	100	252	22.8	32.6	27.6	
		OLMS	7.3	8	6	32	1.2	4.2	1.6	
2	Ph-II & III (25+10)	Outlet	7.9	6.4	3.1	18.6	-	1.5	-	Meeting the standards
		OLMS	7.1	7	5	20	2.8	3.8	1.2	
		OLMS	7.8	13.5	8.5	58.1	-	7.8	-	
Total AS										

M. Mohita
I/C LABORATORY
Scientist 'P'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctmns.nic.in>)



Report Number: DPCC/W/S/T/24-25/171845

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-IV (45)	Inlet	7.3	255	150	284	15.4	30.8	25.4	Not Meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.1	38	14	108	3.2	4.2	1.5	
		OWTS	7.4	11.0	13.7	44.3	-	7.1	-	
Total 45										

M. Mohan
I/C LABORATORY
Sandeepa Mohita
Scientist, IP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcconline.nic.in>)



Report Number: DPCC/W/STP/24-25/18/846

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	5	Inlet	7.3	180	100	255	5.6	25.8	23.6	Meeting the standards.
		Outlet	7.4	7	5	36	2.4	2.6	1.8	
		OLMS	7.5	8.9	6.1	42.3	-	5.2	-	
Total 5										

I/C LABORATORY

Dr. Anurita Moitra
Dr. Anurita Moitra

Signature ID



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccoccmn.nic.in>)



Report Number: DPCC/W/STP/24-25/19/847

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	Parameters							Remarks
		PH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	25	STP Standard 6.5-9.0	10	10	50	10	5	2	Met. meeting the Standards wrt TSS, BOD & Dissolved phosphate.
		Inlet	7.1	384	190	408	13.6	24.4	
		Outlet	7.4	38	20	36	2.4	4.2	
		OLMS	8.3	22.4	14.7	56.4		17.7	
Total 25									

Signature
Dr. Manjula Motra
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctmss.nic.in>)



Report Number: DPCC/W/STP/24-25/20/848

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	9	Inlet	7.5	168	88	152	13.6	24.8	17.2	Meeting the Standards.
		Outlet	7.2	8	6	28	3.2	3.4	0.8	
		OLWS	7.5	11.8	8.3	44.3	-	4.5	-	
Total 9										



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/24-25/21/ 849

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	1	Inlet	7.4	114	80	196	14.4	22.8	19.6	Meeting the Standards.
		Outlet	7.8	6	5	24	1.2	2.6	1.2	
		DIMS	-	-	-	-	-	-	-	
Total 1										O-MS was non-functional

Akshita
Dr. Vandita Mohiya
Scientist 'G'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.apccouncils.nic.in>)



Report Number: DPCC/W/STP/24-25/22/ 80

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	15	Inlet	7.6	164	120	336	6.8	18.6	23.4	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.4	28	20	68	2.8	3.2	0.8	
		OLMS	7.3	15.6	12.8	73.6	-	11.8	-	
Total 15										

Signature

I/C LABORATORY
Dr. Ranjita Mishra

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBI Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcocomms.nct.in>)



Report Number: DPCC/W/STP/24-25/23/ 851

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.2	256	200	304	10.8	23.4	24.6	
		OLWS	7.1	27	20	48	2.4	2.6	3.8	
2	3	Inlet	7.4	5.9	5.9	25.4	-	6.3	-	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	228	160	264	9.2	15.8	32.6	
		OLWS	7.7	38	16	88	1.2	3.6	2.4	
Total 5.2			7.4	6.9	4.9	76.4	-	12.5	-	

Dr. Nandita Moitra

Director, DP



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-23/24/852

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 03.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	10 Pn-1	Inlet	6.5-9.0	10	10	50	10	5	2	Not meeting the standards wrt TSS, BOD, COD & Dissolved phosphate.
			7.5	164	126	366	5.6	12.8	29.2	
		Outlet	7.3	28	22	60	3.2	2.6	2.7	
2	10 Pn-2	OLWS	7.8	-	7.5	41.3	-	17.5	-	TSS reading not shown in OLWS
		Inlet	7.4	232	120	272	10.8	22.4	23.9	
		Outlet	7.5	27	18	52	4	3.2	3.3	
Total 20		OLWS	8.2	20.6	11.3	57.9	-	7.6	-	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate..

Dr. Meghna Mohita
SUPERVISOR
LABORATORY



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dppccouncils.nic.in>)



Report Number: DPCQ/W/STP/24-25/25/853

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

Dated: 8/5/2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
	12	Inlet	6.5-9.0	10	10	50	10	5	2	Plant was non-functional due to under maintenance
		Outlet	7.3	256	160	352	12.8	28.6	22.8	
		OLMS	-	-	-	-	-	-	-	
		Outlet	-	-	-	-	-	-	-	
	16	Outlet	7.5	7	4	44	2.6	3.4	1.2	Meeting the Standards.
		OLMS	-	-	-	-	-	-	-	
1	37	Outlet	7.2	36	20	75	3.6	2.8	0.8	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.4	35.8	19.3	69.0	-	16.5	-	
	45	Outlet	7.4	20	15	64	2.4	3.2	1.6	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.3	13.6	10.6	53.4	-	12.0	-	
Total 110										

Mandira

I/C LABORATORY
Dr. Mandira Moitra

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSRT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/26/ 854

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 25.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGd)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	40		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Inlet	7.3	168	120	312	17.6	27.8	24.3	
		Outlet	7.5	28	16	64	2.4	16.4	7.4	
		OLMS								
2	20	Dugout	7.1	20	18	76	1.2	4.3	1.3	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	-	-	-	-	-	-	-	
Total 60										OLMS was Non functional

Signature

I/C LABORATORY
Dr. Nandita Mohita
Superintendent



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccnctnms.nic.in>)



Report Number: DPCC/W/STP/24-25/27/855

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

Dated 8/5/2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 04.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5		6.5-9.0	10	10	50	10	5	2	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Inlet	7.5	188	80	176	23.2	22.9	20.6	
		Outlet	7.3	40	20	60	2.4	3.4	3.2	
		DLPS	7.3	29.5	21.7	58.3	-	11.9	-	
Total 5										

M. Kishan
I/C LABORATORY
Dr. Manisha Mittal
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/28/856

Dated 8/5/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.04.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	0.66	Inlet	7.4	220	140	352	17.6	19.8	21.7	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.5	48	20	64	3.6	2.4	4.2	
		OWS	7.7	28.4	18.7	118.3	-	17.8	-	
Total 0.66										

M. Nandita
Sr. Nandita Motira
W/LABORATORY
Scientist D