



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF SEPTEMBER 2025

Report Number: DPCC/W/CETP/25-26/66/2216

Dated: 03/10/2025

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

BADLI CETP (12 MLD)

Inlet and Outlet of CETP

08.09.2025

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.1	5.5-9.0	7.2	6-9	8.04
2	TSS	210	600	54	100	13.5
3	COD	344	750	112	250	29.01
4	BOD (3 days at 27° C)	150	300	35	30	10.7
5	Oil & Grease	11.6	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	8.5	50	3.4	50	-
7	Sulphide	3.1	5.0	1.2	2.0	-
8	Phosphate	0.7	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: - 2.708 MLD

Shweta
I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)

[Signature]
Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/67/2217/03-10-25


Dated: 03/10/25

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 08.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :


S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.2	6-9	6.55
2	TSS	196	600	36	100	49.65
3	COD	456	750	88	250	127
4	BOD (3 days at 27° C)	200	300	24	30	16.68
5	Oil & Grease	16.8	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	6.6	50	1.7	50	-
7	Sulphide	2.6	5.0	1.6	2.0	-
8	Phosphate	1.3	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 4.835 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF SEPTEMBER 2025


Report Number: DPCC/W/CETP/25-26/68/ GTK/2218


Dated: 03/10/2025

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.2	6-9	OLMS was Non-functional
2	TSS	440	600	66	100	
3	COD	608	750	124	250	
4	BOD (3 days at 27° C)	220	300	38	30	
5	Oil & Grease	10.8	20.0	3.2	10.0	
6	Ammonical Nitrogen as N	9.3	50	1.5	50	
7	Sulphide	4.5	5.0	1.9	2.0	
8	Phosphate	3.5	15.0	0.8	5.0	

All values are in mg/l except pH
Flow: 1.98 MLD


I/C Water Laboratory
Dr. Shweta
Incharge (Water Laboratory)


Scientist B/ Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/69 / 2219

Dated: 03/10/25

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	7.21
2	TSS	290	600	28	100	55.5
3	COD	584	750	80	250	100
4	BOD (3 days at 27° C)	200	300	25	30	12.6
5	Oil & Grease	14.8	20.0	4.8	10.0	-
6	Ammonical Nitrogen as N	8.2	50	3.7	50	-
7	Sulphide	3.9	5.0	1.5	2.0	-
8	Phosphate	2.0	15.0	1.0	5.0	-

All values are in mg/l except pH

Flow: 6.00 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/70/2220

Dated: 03/10/25

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.1	6-9	7.37
2	TSS	236	600	38	100	43.63
3	COD	384	750	60	250	95.99
4	BOD (3 days at 27° C)	130	300	23	30	14.12
5	Oil & Grease	9.6	20.0	6.0	10.0	-
6	Ammonical Nitrogen as N	7.5	50	1.8	50	-
7	Sulphide	4.8	5.0	2.3	2.0	-
8	Phosphate	3.0	15.0	0.8	5.0	-

All values are in mg/l except pH

Flow: 2.435 MLD

I/C Water LaboratoryDr. Shweta Gupta
Incharge (Water Laboratory)
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF SEPTEMBER 2025


Report Number: DPCC/W/CETP/25-26/71/2221

Dated: 03/10/25


1. Name & Address of Ind. / Unit : **LAWRENCE ROAD (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.1	6-9	7.70
2	TSS	176	600	40	100	13.28
3	COD	592	750	96	250	69.29
4	BOD (3 days at 27° C)	240	300	33	30	20.79
5	Oil & Grease	26.0	20.0	3.6	10.0	-
6	Ammonical Nitrogen as N	8.2	50	5.2	50	-
7	Sulphide	2.8	5.0	1.2	2.0	-
8	Phosphate	4.9	15.0	0.6	5.0	-

All values are in mg/l except pH
Flow: 1.39 MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B / Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/72 / 2222

Dated: 03/10/25

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	7.3	6-9	7.63
2	TSS	200	600	48	100	28.6
3	COD	368	750	116	250	105
4	BOD (3 days at 27° C)	180	300	28	30	22.2
5	Oil & Grease	21.2	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	10.2	50	3.1	50	-
7	Sulphide	2.5	5.0	1.3	2.0	-
8	Phosphate	3.4	15.0	1.3	5.0	-

All values are in mg/l except pH

FLOW: 5.6 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF SEPTEMBER 2025


Report Number: DPCC/W/CETP/25-26/73/2223

Dated: 03/10/25

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.1	6-9	8.18
2	TSS	220	600	42	100	17.6
3	COD	592	750	64	250	60.3
4	BOD (3 days at 27° C)	240	300	22	30	11.1
5	Oil & Grease	11.5	20.0	2	10.0	-
6	Ammonical Nitrogen as N	10.8	50	3.5	50	-
7	Sulphide	4.2	5.0	1.5	2.0	-
8	Phosphate	2.6	15.0	0.5	5.0	-

All values are in mg/l except pH
Flow: 4.16 MLD


I/C Water Laboratory
Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)**ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/74/2224

Dated: 03/10/25

1. Name & Address of Ind. / Unit : **MANGOLPURI CETP (2.4 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.1	6-9	7.19
2	TSS	256	600	38	100	5.7
3	COD	384	750	68	250	56.2
4	BOD (3 days at 27° C)	130	300	20	30	6.4
5	Oil & Grease	14.4	20.0	4.0	10.0	-
6	Ammonical Nitrogen as N	8.2	50	1.0	50	-
7	Sulphide	3.3	5.0	1.3	2.0	-
8	Phosphate	1.8	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: 1.66MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF SEPTEMBER 2025

Report Number: DPCC/W/CETP/25-26/75/2225

Dated: 03/10/25

1. Name & Address of Ind. / Unit : **NANGLOI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.2	6-9	7.54
2	TSS	316	600	58	100	13.3
3	COD	376	750	72	250	62.3
4	BOD (3 days at 27° C)	180	300	24	30	9.5
5	Oil & Grease	12.8	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	8.7	50	2.0	50	-
7	Sulphide	3.4	5.0	1.6	2.0	-
8	Phosphate	3.4	15.0	1.2	5.0	-

All values are in mg/l except pH

Flow: 3.252 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF SEPTEMBER 2025

Report Number: DPCC/W/CETP/25-26/76/2226


Dated: 03/10/25

1. Name & Address of Ind. / Unit : NARELA CETP (22.5 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 19.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.5	6-9	7.40
2	TSS	232	600	20	100	5.3
3	COD	384	750	48	250	29.5
4	BOD (3 days at 27° C)	170	300	15	30	5.5
5	Oil & Grease	14.0	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	10.0	50	1.7	50	-
7	Sulphide	5.6	5.0	2.1	2.0	-
8	Phosphate	1.9	15.0	1.3	5.0	-

All values are in mg/l except pH

Flow: 8.364MLD


I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)


Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**LIFE**
Lifestyle for
Environment**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF SEPTEMBER 2025**

Report Number: DPCC/W/CETP/25-26/77/2227

Dated: 03/10/25

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 19.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.3	6-9	7.55
2	TSS	188	600	30	100	21.49
3	COD	344	750	52	250	41.55
4	BOD (3 days at 27° C)	140	300	18	30	10.39
5	Oil & Grease	18.0	20.0	4.4	10.0	-
6	Ammonical Nitrogen as N	9.3	50	1.0	50	-
7	Sulphide	2.9	5.0	1.5	2.0	-
8	Phosphate	2.0	15.0	1.1	5.0	-

All values are in mg/l except pH

Flow: 35.074 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF SEPTEMBER 2025

Report Number: DPCC/W/CETP/25-26/78/2228

Dated: 03/10/25

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 22.09.2025
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	7.4	6-9	7.71
2	TSS	144	600	60	100	30.68
3	COD	424	750	92	250	216.99
4	BOD (3 days at 27° C)	190	300	24	30	28.84
5	Oil & Grease	16.8	20.0	4.8	10.0	-
6	Ammonical Nitrogen as N	5.4	50	2.0	50	-
7	Sulphide	4.2	5.0	2.5	2.0	-
8	Phosphate	3.5	15.0	0.7	5.0	-

All values are in mg/l except pH

Flow: 2.42 MLD

I/C Water Laboratory

Dr. Shweta Gupta
Incharge (Water Laboratory)

Scientist 'B'/Analyst