



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/27/06


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 16.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I,II (20)	Inlet	7.3	296	135	368	12.8	23.5	13.5	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.4	36	24	44	2.4	3.1	2.6	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
2	Ph-III (70)	Inlet	7.2	252	185	288	17.6	26.4	36.2	Meeting the standards.
		Outlet	7.1	10	8	32	1.6	2.2	1.4	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 90										

Dr. Nandini Bhatnagar
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/28/07

dated : 06/06/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II(15)	Inlet	7.5	216	130	272	13.2	30.9	12.5	Meeting the Standards.
		Outlet	7.6	6	4	12	1.6	2.5	0.9	
		OLMS	7.1	3.7	6.59	29.14	-	5.69	-	
Total 15										

Nandita
I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/29/08


Dated : 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	Phase-I,II(2.2)	Inlet	7.4	204	120	272	14.8	28.5	14.6	Meeting the Standard.
		Outlet	7.6	8	6	16	2	3.1	1.2	
		OLMS	7.5	5.06	4.78	15.43	-	-	-	
Total 2.2										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/30/09

Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


5. Parameters Analyzed and Results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.3	264	145	384	13.2	33.1	24.6	Not Meeting the standards wrt TSS, BOD & COD.
		Outlet	7.5	28	18	52	2	3.4	1	
		OLMS	7.4	7.85	5.73	29.64	-	2.72	-	
Total 12										

Nandita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/31/10


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I,II (2.2)	Inlet	7.2	212	110	256	12	32.6	24.4	Meeting the Standards
		Outlet	7.5	10	8	32	1.6	3.6	1.3	
		OLMS	7.4	5.16	3.06	24.10	-	2.5	-	
Total 2.2										

N. Mitra
I/C LABORATORY
Dr. Nandana Montra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Date: 06/06/2023


Report Number: DPCC/W/STP/23-24/32/ 11

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Nilothe New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	20	Inlet	7.1	208	102	320	13.6	17.5	16.6	Meeting the standards
		Outlet	7.2	10	8	32	2	3.4	1.1	
		OLMS	7.6	9.99	6.38	43.59	-	2.37	-	
Total 20										


Dr. Nandini Mohan
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/33/12


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.5	156	86	288	12.4	17.5	26.2	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.3	44	24	52	2.4	2.3	1.6	
		OLMS	7.7	88.27	53.02	261.01	-	28.69	-	
Total 40										

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/23-24/35 /13


Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Phase-I(40)	Inlet	-	-	-	-	-	-	-	Plant was under Rehabilitation
		Outlet	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	
2	Ph-II(40)	Inlet	7.2	248	135	280	14.8	10.8	16.5	Not Meeting the Standards wrt TSS & BOD.
		Outlet	7.4	20	14	44	2.8	3.4	2	
		OLMS	7.6	11.33	7.55	34.32	-	11.54	-	
Total 80										


Dr. Nandita Mishra
N/C LABORATORY
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/23-24/34/114


Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.2	240	150	400	12.4	35.4	22.5	Not meeting the standards wrt TSS, BOD, COD and Dissolved Phosphate.
		Outlet	7.5	34	20	72	1.2	3.8	3.4	
		OLMS	7.4	20.30	22.7	87	-	14.6	-	
Total 5										

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/36/15


Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	1.0	5	2	
1	20	Inlet	7.4	200	104	256	14.4	19.5	28.4	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.1	28	17	40	3.2	3.6	2.8	
		OLMS	7.4	7.08	5.13	29.93	-	1.70	-	
Total 20										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/37/116


Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
	20	Inlet	7.4	200	104	256	14.4	19.5	28.4	Meeting the Standards.
Outlet		7.3	8	6	28	0.8	2.3	1.4		
OLMS		7.7	33.29	28.65	140	-	13.3	-		
Total 20										

M. Mitra
I/C LABORATORY
Dr. Nandita Mohan
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number DPCC/W/STP/23-24/38 **117**


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.5	316	170	304	16.4	22.6	18.4	Not meeting the Standards wrt TSS, BOD, COD, Ammonical Nitrogen & Dissolved Phosphate.
		Outlet	7.3	22	15	68	3.6	4.1	3.1	
		OLMS	7.5	17.15	18.88	142.57	-	11.36	-	
Total 15										

N. Mitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/39/18


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10	Inlet	7.6	204	75	144	8.4	20.4	15.9	Not meeting the standards wrt TSS, BOD & COD.
		Outlet	7.3	30	17	56	2.8	1.6	2	
		OLMS	7.4	16.35	12.42	74.30	-	10.48	-	
Total 10										

I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/40 /19


Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	30	Inlet	7.3	208	115	272	14.4	19.5	23.1	Meeting the Standards.
		Outlet	7.4	6	4	24	1.2	1.5	1.6	
		OLMS	-	-	-	-	-	-	-	OLMS was non-functional
Total 30										

Dr. Nandini Bhatnagar
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/41/20

Date: 06/06/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	Ph-I (10)	Inlet	7.6	188	90	272	24.4	39.5	34	Meeting the standards..
		Outlet	7.4	8	6	32	2	2.4	2.1	
		OLMS	7.6	17.09	11.19	38.85	-	19.09	-	
2	Ph-III (10)	Outlet	7.5	10	5	40	2.8	2.1	1.8	Meeting the standards.
		OLMS	7.6	21.7	36.7	115.2	-	120.46	-	
Total 20										

Dr. N. Chandra
Dr. N. CHANDRA
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/42/21

Dated : 06/06/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	45	Inlet	7.6	260	140	256	17.6	29.6	27.1	Not Meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.4	54	32	104	4.8	3.4	3.1	
		OLMS	7.0	-	90	-	-	2.15	-	TSS & COD readings not shown in OLMS
Total 45										

I/C LABORATORY

Dr. Nandita Mehta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/44/22

Dated: 06/06/2023


ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	25	Inlet	7.1	372	160	256	17.2	22.4	29.7	Not meeting the Standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.5	22	16	44	3.6	3.5	2.6	
		OLMS	7.3	21.83	13.44	79.99	-	11.67	-	
Total 25										

N. Mitta

I/C LABORATORY
Dr. Nandita Mehta
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/23-24/43/23


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.6	228	76	240	4	28.6	18.2	Meeting the standards
		Outlet	7.3	10	8	24	2	3.5	1.9	
		OLMS	7.5	8.16	4.39	41.99	-	2.13	-	
Total 5										


I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated : 06/06/2023

Report Number: DPCC/W/STP/23-24/45 *124*

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	9	Inlet	7.2	144	58	144	12	22.5	14.9	Meeting the Standards.
		Outlet	7.6	10	5	24	1.6	2.2	0.6	
		OLMS	7.2	7.32	5.1	31.06	-	-	-	
Total 9										

Nandita

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated: 06/06/2023


Report Number: DPCC/W/STP/23-24/46/25

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 08.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	1	Inlet	7.6	180	70	208	16.4	18.5	20.6	Meeting the Standards.
		Outlet	7.4	6	4	16	0.8	2.3	1.3	
		OLMS	7.4	0.94	1.4	7.8	-	0.03	-	
Total 1										

N. Mittal
I/C LABORATORY
Dr. Nandita Mittal
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/47/26

Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :


Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	15	Inlet	7.5	196	135	252	8	16.1	28.6	Not meeting the standards wrt TSS, BOD, COD & dissolved phosphate.
		Outlet	7.2	32	21	72	2.4	3.1	2.1	
		OLMS	7.7	12.83	10.32	53.19	-	11.79	-	
Total 15										

N. Moitra

I/C LABORATORY

Dr. Nandita Moitra

Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/48 /27


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	2.2	Inlet	7.4	224	140	288	13.2	22.7	29	Not meeting the standards wrt TSS, BOD & Dissolved Phosphate.
		Outlet	7.2	32	19	40	2.4	2.9	3.9	
		OLMS	8.2	6.71	5.65	27.97	-	11.31	-	
2	3	Inlet	7.1	220	150	272	6	19.5	27.9	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	42	26	80	1.6	4.3	2.1	
		OLMS	7.8	8.27	5.60	27.96	-	9.34	-	
Total 5.2										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/49/28


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :										
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	10 Ph-1	Inlet	7.4	192	110	144	8.4	17.5	26.4	Not meeting the standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.1	30	21	52	2.8	3.4	2.2	
		OLMS	7.3	13.81	8.98	59.14	-	15.84	-	
2	10 Ph-2	Inlet	7.1	264	135	288	7.6	20.9	22.6	Not meeting the standard wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.3	34	16	64	2.4	2.4	3	
		OLMS	7.6	10.89	4.98	45.76	-	9.36	-	
Total 20										

Nandita
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Report Number: DPCC/W/STP/23-24/50/29


Dated: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 18.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	12	Inlet	7.6	264	155	288	10.8	29.6	20.9	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.5	38	23	72	2.4	1.9	1.6	
		OLMS	7.6	8.12	4.23	29.41	-	11.70	7.6	
	16	Outlet	7.4	6	5	24	1.6	3.1	1.4	Meeting the Standards.
		OLMS	7.7	14.05	5.24	29.79	-	12.12	-	
	37	Outlet	7.1	32	19	56	2.8	3.5	1.6	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	7.5	45.30	25.14	147.98	-	24.16	-	
	45	Outlet	7.8	38	22	64	2	4	1.1	Not meeting the Standards wrt TSS, BOD & COD.
		OLMS	-	-	-	-	-	-	-	
Total 110										

N. Mehta
I/C LABORATORY
Dr. Nandita Mohra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

dated: 06/06/2023


Report Number: DPCC/W/STP/23-24/51/30

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 19.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	40	Inlet	7.5	196	135	304	17.6	22.4	18.5	Not meeting the Standards wrt TSS, BOD & COD.
		Outlet	7.5	42	23	96	2.8	3.5	1.2	
		OLMS	7.5	92.0	76	282	-	24.81	-	
2	20	Inlet	7.5	196	135	304	17.6	22.4	18.5	Not meeting the Standards wrt TSS, BOD, COD, Ammonical nitrogen & dissolved phosphate.
		Outlet	7.2	28	18	68	3.2	7.6	6.4	
		OLMS	7.6	95.59	120.23	433.01	-	23.54	-	
Total 60										

Nandita
I/C LABORATORY
Dr. Nandita Mohra
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>

Dated : 06/06/2023


Report Number: DPCC/W/STP/23-24/52/31

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 17.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	5	Inlet	7.4	168	60	160	7.2	23.5	34.7	Not meeting the Standards wrt TSS, BOD, COD & Dissolved Phosphate.
		Outlet	7.2	30	18	48	3.6	2.4	3.1	
		OLMS	7.2	17.64	14.00	41.16	-	13.00	-	
Total 5										

N. Moitra
I/C LABORATORY
Dr. Nandita Moitra
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi)

4th Floor, I.S.B.T. Building, Kashmere Gate, Delhi - 110006

Website : <http://www.dpcc.delhigovt.nic.in>


Report Number: DPCC/W/STP/23-24/2/32

Date: 06/06/2023

ANALYSIS REPORT OF STP FOR THE MONTH OF MAY-2023

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 16.05.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
			6.5-9.0	10	10	50	10	5	2	
1	0.66	Inlet	7.4	288	120	336	18	25.4	17.6	Not meeting the Standards wrt TSS, BOD, COD & Dissolved phosphate.
		Outlet	7.1	24	14	56	3.4	1.9	2.6	
		OLMS	8.0	23.2	16.0	92.6	-	12.49	-	
Total 0.66										


I/C LABORATORY

Dr. Nandita Moitra
Scientist 'D'