



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF FEBRUARY 2026

Report Number: DPCC/W/CETP/25-26/131/ 2661/6.3.26

Dated:

1. Name & Address of Ind. / Unit : **NANGLOI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 02.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.8	5.5-9.0	7.1	6-9	7.5
2	TSS	308	600	45	100	6.5
3	COD	368	750	80	250	63.1
4	BOD (3 days at 27° C)	120	300	26	30	9.6
5	Oil & Grease	14.4	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	22.4	50	3.5	50	-
7	Sulphide	4.2	5.0	1.6	2.0	-
8	Phosphate	9.6	15.0	2.2	5.0	-

All values are in mg/l except pH

Flow: 2.953 MLD

I/C Water Laboratory

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF FEBRUARY 2026**

Report Number: DPCC/W/CETP/25-26/132 /2662/8.3.26

Dated:

1. Name & Address of Ind. / Unit
2. Sampling location
3. Date of Sampling
4. Sample analyzed and results
5. Parameters analyzed and result

MANGOLPURI CETP (2.4 MLD)

Inlet and Outlet of CETP

02.02.2026

DPCC LAB

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.2	6-9	7.76
2	TSS	787	600	70	100	78.8
3	COD	568	750	64	250	348.0
4	BOD (3 days at 27° C)	230	300	25	30	50.6
5	Oil & Grease	13.6	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	24.2	50	6.0	50	-
7	Sulphide	3.2	5.0	1.5	2.0	-
8	Phosphate	6.9	15.0	2.9	5.0	-

All values are in mg/l except pH

Flow: 1.49 MLD

I/C Water Laboratory

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF FEBRUARY 2026****Report Number:** DPCC/W/CETP/25-26/133/2663/6.3.26**Dated:**

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 03.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.3	6-9	OLMS was Non-functional
2	TSS	412	600	120	100	
3	COD	488	750	156	250	
4	BOD (3 days at 27° C)	180	300	40	30	
5	Oil & Grease	12	20.0	2	10.0	
6	Ammonical Nitrogen as N	16.9	50	3.4	50	
7	Sulphide	4.7	5.0	3.6	2.0	
8	Phosphate	9.2	15.0	1.4	5.0	

All values are in mg/l except pH

Flow: 1.91 MLD

I/C Water Laboratory

Scientist B Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)

**ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF FEBRUARY 2026**Report Number: DPCC/W/CETP/25-26/134/ 2664/6.3.26

Dated:

1. Name & Address of Ind. / Unit : **OKHLA CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 12.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.7	5.5-9.0	8.1	6-9	5.375
2	TSS	200	600	45	100	32.825
3	COD	560	750	68	250	142.375
4	BOD (3 days at 27° C)	210	300	24	30	22.8125
5	Oil & Grease	12.8	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	19.8	50	5.8	50	-
7	Sulphide	3.6	5.0	1.2	2.0	-
8	Phosphate	11.7	15.0	1.4	5.0	-

All values are in mg/l except pH

Flow: 2.177MLD

I/C Water Laboratory

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)**ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF FEBRUARY 2026**

Report Number: DPCC/W/CETP/25-26/137/ 2665/6.3.26

Dated:

1. Name of CETP : **JHILMIL CETP (16.8 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 16.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.6	5.5-9.0	6.8	6-9	8.19
2	TSS	408	600	54	100	47.93
3	COD	312	750	72	250	122.69
4	BOD (3 days at 27° C)	120	300	25	30	16.10
5	Oil & Grease	10.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	23	50	7.1	50	-
7	Sulphide	2.6	5.0	1.8	2.0	-
8	Phosphate	1.4	15.0	0.2	5.0	-

All values are in mg/l except pH

Flow: 3.18 MLD

I/C Water Laboratory

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)

**ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF FEBRUARY 2026**

Report Number: DPCC/W/CETP/25-26/138/2666/6.3.26

Dated:

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 18.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	5.8	5.5-9.0	6.5	6-9	7.68
2	TSS	710	600	54	100	14.0
3	COD	536	750	60	250	38.9
4	BOD (3 days at 27° C)	200	300	23	30	6.1
5	Oil & Grease	15.6	20.0	4	10.0	-
6	Ammonical Nitrogen as N	23.7	50	5.4	50	-
7	Sulphide	3.8	5.0	2	2.0	-
8	Phosphate	6.6	15.0	0.3	5.0	-

All values are in mg/l except pH
Flow: 4.85 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF FEBRUARY 2026

Report Number: DPCC/W/CETP/25-26/139/ 2667/6.3.26

Dated:

1. Name & Address of Ind. / Unit : **LAWRENCE ROAD (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 18.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.2	5.5-9.0	6.9	6-9	9.00
2	TSS	815	600	72	100	6.11
3	COD	432	750	104	250	115.58
4	BOD (3 days at 27° C)	170	300	28	30	17.37
5	Oil & Grease	16	20.0	2	10.0	-
6	Ammonical Nitrogen as N	24.2	50	7.2	50	-
7	Sulphide	4.6	5.0	2.2	2.0	-
8	Phosphate	6.4	15.0	0.9	5.0	-

All values are in mg/l except pH

Flow: 1.34 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF FEBRUARY 2026

Report Number: DPCC/W/CETP/25-26/140/2668/4.3.26


Dated:

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 18.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.7	5.5-9.0	6.8	6-9	7.7
2	TSS	330	600	50	100	43.42
3	COD	584	750	88	250	95.52
4	BOD (3 days at 27° C)	210	300	24	30	14.05
5	Oil & Grease	16.8	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	31.9	50	2.1	50	-
7	Sulphide	4.1	5.0	1.6	2.0	-
8	Phosphate	2.7	15.0	1.6	5.0	-

All values are in mg/l except pH

Flow: 2.096 MLD


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF FEBRUARY 2026

Report Number: DPCC/W/CETP/25-26/141/ 2669/6.3.26

Dated:

- | | |
|-----------------------------------|----------------------------|
| 1. Name & Address of Ind. / Unit | BADLI CETP (12 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 24.02.2026 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	5.6	5.5-9.0	6.7	6-9	8.36
2	TSS	320	600	88	100	35.1
3	COD	640	750	120	250	54.5
4	BOD (3 days at 27° C)	240	300	37	30	19.5
5	Oil & Grease	8.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	20.6	50	2.1	50	-
7	Sulphide	4.2	5.0	1.2	2.0	-
8	Phosphate	6.1	15.0	1.5	5.0	-

All values are in mg/l except pH

Flow: 1.606 MLD

N. Mitra

I/C Water Laboratory

[Signature]

Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccommms.nic.in>)

**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF FEBRUARY 2026**

Report Number: DPCC/W/CETP/25-26/142/ 2670/6.3.20

Dated:

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 25.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.2	5.5-9.0	7.2	6-9	7.16
2	TSS	444	600	72	100	11.3
3	COD	576	750	88	250	74.2
4	BOD (3 days at 27° C)	210	300	27	30	15.6
5	Oil & Grease	13.2	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	25.4	50	7.1	50	-
7	Sulphide	4.5	5.0	2.2	2.0	-
8	Phosphate	11.4	15.0	1.6	5.0	-

All values are in mg/l except pH

FLOW: 5.33 MLD

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF FEBRUARY 2026

Report Number: DPCC/W/CETP/25-26/143/2671/6.3.26

Dated:

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 25.02.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.3	5.5-9.0	6.9	6-9	7.89
2	TSS	316	600	36	100	31.1
3	COD	480	750	88	250	144.6
4	BOD (3 days at 27° C)	180	300	23	30	17.3
5	Oil & Grease	15.2	20.0	2	10.0	-
6	Ammonical Nitrogen as N	23.2	50	4.1	50	-
7	Sulphide	3.6	5.0	1.3	2.0	-
8	Phosphate	5.9	15.0	2.3	5.0	-

All values are in mg/l except pH
Flow: 4 MLD

I/C Water Laboratory

Scientist B /Analyst