



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/169/ 1369

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.6	114	60	220	14.4	23.4	23.1	-	Meeting the standards.
		Outlet	7.2	7	3	40	1.2	1.9	1.2	150	
		OLMS	7.7	9.0	5.2	38.7	-	1.8	-	-	
Total 70											

N. Mishra
Nandita Mohita
Scientist 'D'

I/C Water Laboratory

Abhinav
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/170/ 1370

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.7	232	140	288	16.4	21.6	24.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	23	13	72	2.4	2.6	1.3	1200	
		OLMS	8.2	9.5	5.9	29.9	-	0.2	-	-	
2	Ph-III (10)	Inlet	7.3	212	117	272	12	22.6	22.3	-	Not meeting the standards wrt TSS,BOD, COD & fecal coliform.
		Outlet	7.1	32	15	68	1.6	1.7	1.5	760	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
Total 30											

I/C Water Laboratory

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/171/ 1371

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.4	196	120	268	15.6	24.2	14.2	-	Meeting the Standards.
		Outlet	7.2	6	5	24	2.4	2.2	1.5	150	
		OLMS	7.5	6.7	2.7	22.4	-	15.8	-	-	
Total 15											

Mukha
I/C Water Laboratory

SSA/Analyst/SLA

Dr. Hemanta Mohanta
Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/172/ 1372

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters Analyzed and Results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.3	198	117	276	16.4	23.6	16.2	-	Meeting the Standards.
		Outlet	7.2	8	7	28	1.2	2.6	1.6	95	
		OLMS	7.3	5.0	2.7	16.0	-	1.4	-	-	
Total 2.2											

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/173/ 1373

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.5	212	125	284	19.2	24.2	22.5	-	Not meeting the standards wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.1	29	17	84	2.4	2.6	1.9	2200	
		OLMS	7.5	8.6	8.6	30.0	-	4.8	-	-	
Total 12											

N. Mitta
I/C Water Laboratory

D. Narasimha Moitra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/174/ 1374

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.6	194	140	276	19.2	26.1	16.6	-	Meeting the Standards
		Outlet	7.3	8	7	32	1.6	1.9	0.6	140	
		OLMS	6.9	7.4	4.7	21.3	-	1.9	-	-	
Total 2.2											

N. Nigam

I/C Water Laboratory

Dr. Nandita Mohan
Secretary

Abhishek

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/175/ 1375

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters Analyzed and Results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Fecal Coliform MPN/100ml 230	
1	20	Inlet	7.6	226	160	232	13.6	14.8	13.6	-	Meeting the standards.
		Outlet	7.4	8	6	48	1.6	1.8	1.5	95	
		OLMS	7.7	5.8	3.8	37.1	-	4.2	-	-	
Total 20											

N. Mitta
I/C Water Laboratory
Dr. Nandita Mitta
Scientist 'D'

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/176/1376

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

STP and effluent quality											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.4	266	180	308	20.8	17.4	22.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	33	20	84	0.8	1.8	1.5	1600	
		OLMS	7.7	21.1	12.8	107.5	-	31.5	-	-	
Total 40											

M. M. M. M.

I/C Water Laboratory
Dr. Nehru Institute
Scientist 'D'

A. K. S.

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number DPCC/W/STP/24-25/177/ 1377

Dated 07/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)			
			6.5-9.0	10	10	50	10	5	2	230		
1	5	Inlet	7.4	234	225	236	23.6	23.3	20.2	-	Meeting the standards.	
		Outlet	7.3	9	8	40	1.6	2.7	1.7	120		
		OLMS	7.0	20.8	14.6	76.9	-	11.8	-	-		
Total 5												

Mittra
I/C Water Laboratory

Sharma
SSA/Analyst/SLA

Dr. Manisha Mittal
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/178/ 1378

Dated: 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.6	188	160	248	13.6	19.8	21.7	-	Meeting the standards
		Outlet	7.2	7	5	28	1.2	1.6	1.4	110	
		OLMS	-	-	-	-	-	-	-	-	OLMS was not installed
2	Ph-II(40)	Inlet	7.1	198	100	260	11.2	23.4	22.4	-	Meeting the standards
		Outlet	7.5	6	4	36	1.6	2.2	1.7	140	
		OLMS	7.4	7.7	5.4	28.9	-	4.9	-	-	
Total 80											

N. Mitta

I/C Water Laboratory

Dr. Namita Mitta
Scientist 'D'

Akash

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/179/ 1379

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Pappankalan (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.4	204	125	204	12.8	20.3	21.5	-	Not meeting the Standards wrt TSS, BOD COD & Fecal Coliform.
		Outlet	7.2	34	14	72	2.0	2.5	1.9	1400	
		OLMS	7.7	20.6	13.3	81.1	-	9.9	-	-	
Total 20											

N. Mittal
I/C Water Laboratory

Arora
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/180/ 1380

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 22.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.4	204	125	204	12.8	20.3	21.5	-	Meeting the Standards.
		Outlet	7.5	6	4	28	1.2	1.9	1.5	180	
		OLMS	7.5	6.5	4.4	27.7	-	10.6	-	-	
Total 20											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Namita Mohan
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/24-25/181/ 1381

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.2	204	140	268	132	21.9	22.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	26	12	56	2.0	2.3	1.4	1800	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional
Total 15											

N. Mohita

I/C Water Laboratory

Dr. Nandita Mohita
Scientist 'D'

SSA

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/182/ 1382

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 07.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.6	242	200	256	15.2	19.7	19.9	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	30	18	60	1.6	1.6	1.5	1400	
		OLMS	-	-	-	-	-	-	-	-	OLMS was not functional.
Total 10											

N. Mittal

I/C Water Laboratory

Dr. Namrata Mittal
Scientist 'D'

Akash

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/183/ 1383

Dated

05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.5	248	134	312	17.2	24.4	21.2	-	Meeting the Standards.
		Outlet	7.2	7	4	20	1.6	2.1	1.7	240	
		OLMS	7.2	6.9	3.8	24.2	-	0.9	-	-	
Total 30											

I/C Water Laboratory

Dr. Nandita Mohan

SECRETARY

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/184/ 1384

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.4	248	133	300	15.6	26.2	23.1	-	Meeting the standards.
		Outlet	7.2	6	5	32	1.6	2.1	1.8	150	
		OLMS	7.4	10.8	5.0	24.2	-	0.2	-	-	
2	Ph-II & III (25+10)	Outlet	7.3	8	7	28	1.2	2.7	1.5	120	Meeting the standards
		OLMS	7.6	61.1	10.1	158.0	-	0	-	-	
Total 45											

N. Kishor
Nandita Moura
Scientist 'D'
I/C Water Laboratory

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/185/1386

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.2	208	140	296	14.2	23.4	22.8	-	Meeting the Standards.
		Outlet	7.4	7	6	36	2.8	2.6	1.4	92	
		OLMS	7.3	12.6	7.0	1.4	-	14.7	-	-	
Total 45											

I/C Water Laboratory

Dr. Nandita Molra
Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/186/1386

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.8	178	140	284	10.8	23.7	18.5	-	Meeting the standards.
		Outlet	7.4	9	8	44	0.8	1.8	1.3	170	
		OLMS	7.5	9.1	6.1	41.0	-	12.0	-	-	
Total 5											

N. Mittal
I/C Water Laboratory

Dr. Manjita Mohan
Scientist 'D'

A. Singh
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/187/ 11387

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.4	156	134	292	18.4	15.6	26.4	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Colifrom.
		Outlet	7.6	28	18	60	2.4	1.6	1.4	1400	
		OLMS	7.2	20.0	11.3	54.3	-	19.2	-	-	
Total 25											

N. Mitta
I/C Water Laboratory

Dr. Nandita Mishra
Scientist 'D'

SSA
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/188/11388

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.3	198	143	284	18.4	22.6	12.4	-	Meeting the Standards.
		Outlet	7.6	5	4	24	1.6	2.1	1.1	84	
		OLMS	7.2	7.2	5.5	30.5	-	1.2	-	-	
Total 9											

I/C Water Laboratory

Scientist 'D'

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccmms.nic.in>)



Report Number: DPCC/W/STP/24-25/189/1389

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.7	186	150	264	19.2	17.2	15.2	-	Meeting the Standards.
		Outlet	7.4	7	6	28	0.8	1.8	0.7	70	
		OLMS	7.5	0.9	1.7	7.6	-	0.2	-	-	
Total 1											

N. Mittal
I/C Water Laboratory

Dr. Nandita Mohan
Scientist 'D'

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/190/11390

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.3	252	160	324	15.6	16.9	19.6	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	24	18	76	2.0	1.1	2.1	1300	
		OLMS	7.5	21.9	8.2	55.1	-	14.3	-	-	
Total 15											

Misha

I/C Water Laboratory

Dr. Nandita Mishra
Scientist 'D'

Akash

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/191/1391

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.5	258	140	320	14.4	18.4	19.5	-	Not meeting the standards wrt TSS,BOD, COD & Fecal Coliform.
		Outlet	7.4	34	26	84	2.4	2.1	1.5	920	
		OLMS	7.0	7.8	5.2	37.6	-	5.7	-	-	
2	3	Inlet	7.2	224	160	316	16.8	17.5	18.5	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	35	28	68	1.6	1.2	0.9	810	
		OLMS	7.1	8.4	5.7	35.9	-	8.4	-	-	
Total 5.2											

N. Mishra
I/C Water Laboratory

A. Singh
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/192/1392

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 11.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.2	184	125	256	12.4	14.8	22.2	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.5	38	12	56	3.2	2.4	1.6	2500	
		OLMS	6.8	12.1	7.8	38.0	-	17.0	-	-	
2	10 Ph-2	Inlet	7.3	192	120	296	20	16.6	20.8	-	Meeting the Standards.
		Outlet	7.6	8	6	28	2.8	2.6	1.8	150	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 20											

N. Mishra
I/C Water Laboratory
Dr. Nandita Mishra
Scientist ID

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/24-25/193/11393

Dated

05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.5	248	167	288	24.4	20.4	16.4	-	Not meeting the standard wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.3	33	20	56	2.8	1.8	1.2	1600	
		OLMS	7.2	31.6	18.4	102.0	-	13.5	-	-	
Total 0.66											

M. Mitra

I/C Water Laboratory

Dr. Nandita Moitra

Scientist 'D'

Akash

SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/194/11394

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 10.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12	Inlet	7.7	264	160	328	19.6	24.8	20.6	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		Outlet	7.2	24	13	60	3.2	2.8	1.8	2300	
		OLMS	-	-	-	-	-	-	-	-	
	16	Outlet	7.8	8	7	36	1.6	1.7	0.6	84	Meeting the Standards.
		OLMS	7.2	8.9	7.0	30.9	-	3.3	-	-	
	37	Outlet	7.5	30	15	76	3.2	2.4	1.4	1500	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		OLMS	-	-	-	-	-	-	-	-	
	45	Outlet	7.4	26	14	68	2.0	2.1	1.2	2100	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform. OLMS was non functional
		OLMS	-	-	-	-	-	-	-	-	
Total 110											

N. Mishra
I/C Water Laboratory

Akash
SSA/Analyst/SLA



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/24-25/195/

11395

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 14.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.6	248	175	304	24.4	24.3	23.1	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	27	16	72	1.2	3.8	1.3	760	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
2	20	Outlet	7.2	39	23	60	0.8	3.1	1.6	1200	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		OLMS	-	-	-	-	-	-	-	-	OLMS was non functional
Total 60											

I/C Water Laboratory

SSA/Analyst/SLA

Dr. Nandita Mohan
Scientist 'D'



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/24-25/196/1396

Dated 05/11/2024

ANALYSIS REPORT OF STP FOR THE MONTH OF OCTOBER-2024

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.10.2024
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	206	140	308	13.6	22.4	22.8	-	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.1	53	32	64	1.2	1.6	1.2	1700	
		OLMS	7.5	17.6	11.7	63.2	-	13.5	-	-	
Total 5											

N. Mitta

I/C Water Laboratory

Dr. Nandita Moitra
Scientist 'D'

SSA

SSA/Analyst/SLA