

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)

**ANALYSIS REPORT OF NARAINA CETP (21.6 MLD) FOR THE MONTH OF JANUARY 2026**


Report Number: DPCC/W/CETP/25-26/ 118 /2548

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : **NARAINA CETP (21.6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 02.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.8	5.5-9.0	7.3	6-9	7.18
2	TSS	419	600	60	100	11.7
3	COD	432	750	88	250	72.2
4	BOD (3 days at 27° C)	180	300	28	30	15.2
5	Oil & Grease	14.4	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	8.1	50	3.1	50	-
7	Sulphide	3.2	5.0	1.6	2.0	-
8	Phosphate	5.7	15.0	3.3	5.0	-

All values are in mg/l except pH
FLOW: 5.16 MLD


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF MAYAPURI CETP (12 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/ 119 / **2549**

Dated: **30/01/2026**

1. Name & Address of Ind. / Unit : MAYAPURI CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 02.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.5	5.5-9.0	7.3	6-9	7.37
2	TSS	427	600	56	100	40.9
3	COD	432	750	76	250	153.5
4	BOD (3 days at 27° C)	170	300	24	30	18.6
5	Oil & Grease	12	20.0	2.4	10.0	-
6	Ammonical Nitrogen as N	16.2	50	5.3	50	-
7	Sulphide	4.2	5.0	1.3	2.0	-
8	Phosphate	6.3	15.0	1.8	5.0	-

All values are in mg/l except pH
Flow: 3.973 MLD

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF OKHLA CETP (24 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/ 120 /2550

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : OKHLA CETP (24 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 08.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.1	5.5-9.0	7.3	6-9	6.15
2	TSS	280	600	56	100	32.16
3	COD	648	750	64	250	141.43
4	BOD (3 days at 27° C)	240	300	25	30	22.69
5	Oil & Grease	24	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	14.5	50	3.5	50	-
7	Sulphide	3.9	5.0	2.2	2.0	-
8	Phosphate	6.1	15.0	3.0	5.0	-

All values are in mg/l except pH

Flow: 2.241MLD

I/C Water Laboratory

Scientist 'B'/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)

**ANALYSIS REPORT OF BAWANA CETP (35 MLD) FOR THE MONTH OF JANUARY 2026**Report Number: DPCC/W/CETP/25-26/121 / **2551**Dated: **30/01/2026**

1. Name & Address of Ind. / Unit : **BAWANA CETP (35 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.9	5.5-9.0	7.2	6-9	7.04
2	TSS	346	600	18	100	27.1
3	COD	464	750	44	250	50.1
4	BOD (3 days at 27° C)	170	300	14	30	12
5	Oil & Grease	18.4	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	11.4	50	3.1	50	-
7	Sulphide	4.9	5.0	1.3	2.0	-
8	Phosphate	4.3	15.0	1.9	5.0	-

All values are in mg/l except pH

Flow: 29.72 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF NARELA CETP (24 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/122 / **2552**

Dated: **30/01/2026**

1. Name & Address of Ind. / Unit : **NARELA CETP (22.5 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 09.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.2	6-9	7.94
2	TSS	278	600	10	100	7.0
3	COD	416	750	28	250	29.9
4	BOD (3 days at 27° C)	170	300	8	30	5.4
5	Oil & Grease	13.6	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	12.0	50	1.8	50	-
7	Sulphide	4.7	5.0	1.2	2.0	-
8	Phosphate	7.1	15.0	1.7	5.0	-

All values are in mg/l except pH

Flow: 7.963MLD

Shukla

I/C Water Laboratory

Scientist B/Analyst

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF BADLI CETP (12 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/123 /2553


Dated: 30/01/2026

- | | |
|-----------------------------------|--------------------------|
| 1. Name & Address of Ind. / Unit | BADLI CETP (12 MLD) |
| 2. Sampling location | Inlet and Outlet of CETP |
| 3. Date of Sampling | 12.01.2026 |
| 4. Sample analyzed and results | DPCC LAB |
| 5. Parameters analyzed and result | |

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.5	5.5-9.0	7.3	6-9	
2	TSS	320	600	48	100	
3	COD	472	750	80	250	
4	BOD (3 days at 27° C)	200	300	27	30	
5	Oil & Grease	17.6	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	8.8	50	3.1	50	-
7	Sulphide	4.8	5.0	1.4	2.0	-
8	Phosphate	7.2	15.0	2.2	5.0	-

All values are in mg/l except pH

Flow: - 2.33 MLD


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



ANALYSIS REPORT OF JHILMIL CETP (16.8 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/ 124 /2554

Dated: 30/01/2026

1. Name of CETP : JHILMIL CETP (16.8 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 12.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.2	5.5-9.0	7.1	6-9	8.44
2	TSS	533	600	70	100	49.73
3	COD	672	750	84	250	127.31
4	BOD (3 days at 27° C)	250	300	28	30	16.71
5	Oil & Grease	13.6	20.0	3.2	10.0	-
6	Ammonical Nitrogen as N	13.2	50	3.6	50	-
7	Sulphide	4.2	5.0	1.8	2.0	-
8	Phosphate	9.6	15.0	3.0	5.0	-

All values are in mg/l except pH

Flow: 5.38 MLD

I/C Water Laboratory

Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)


**ANALYSIS REPORT OF GTK CETP (6 MLD) FOR THE MONTH OF JANUARY 2026**Report Number: DPCC/W/CETP/25-26/125 / **2555**Dated: **30/01/2026**

1. Name & Address of Ind. / Unit : **GTK CETP (6 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13. 01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.3	5.5-9.0	7.4	6-9	OLMS was Non-functional
2	TSS	528	600	88	100	
3	COD	568	750	128	250	
4	BOD (3 days at 27° C)	210	300	42	30	
5	Oil & Grease	23.6	20.0	3.6	10.0	
6	Ammonical Nitrogen as N	13.0	50	5.8	50	
7	Sulphide	4.2	5.0	2.1	2.0	
8	Phosphate	8.0	15.0	3.5	5.0	

All values are in mg/l except pH

Flow: 1.88 MLD


I/C Water Laboratory


Scientist B/Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)**ANALYSIS REPORT OF WAZIRPUR CETP (24 MLD) FOR THE MONTH OF JANUARY 2026**

Report Number: DPCC/W/CETP/25-26/ 126/2556

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : **WAZIRPUR CETP (24 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.2	6-9	7.73
2	TSS	375	600	36	100	20.6
3	COD	368	750	80	250	59.3
4	BOD (3 days at 27° C)	130	300	28	30	9.4
5	Oil & Grease	9.2	20.0	1.2	10.0	-
6	Ammonical Nitrogen as N	12.0	50	4.2	50	-
7	Sulphide	3.4	5.0	1.6	2.0	-
8	Phosphate	6.8	15.0	2.8	5.0	-

All values are in mg/l except pH

Flow: 6.08MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF LAWRENCE ROAD CETP (12 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/ 127/2557

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : **LAWRENCE ROAD (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS*
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.4	5.5-9.0	7.5	6-9	OLMS was Non-functional
2	TSS	400	600	98	100	
3	COD	488	750	156	250	
4	BOD (3 days at 27° C)	200	300	43	30	
5	Oil & Grease	20	20.0	2.8	10.0	
6	Ammonical Nitrogen as N	12.3	50	2.9	50	
7	Sulphide	4.6	5.0	2.2	2.0	
8	Phosphate	9.8	15.0	2.3	5.0	

All values are in mg/l except pH

Flow: 1.44 MLD

I/C Water Laboratory

Scientist 'B'/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



ANALYSIS REPORT OF SMA CETP (12 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/128/ 2558

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : SMA CETP (12 MLD)
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 13.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.3	5.5-9.0	7.2	6-9	7.56
2	TSS	396	600	58	100	43.25
3	COD	560	750	68	250	95.14
4	BOD (3 days at 27° C)	230	300	27	30	13.99
5	Oil & Grease	16.0	20.0	1.6	10.0	-
6	Ammonical Nitrogen as N	14.2	50	2.9	50	-
7	Sulphide	4.3	5.0	1.4	2.0	-
8	Phosphate	7.6	15.0	2.7	5.0	-

All values are in mg/l except pH

Flow: 2.145 MLD

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccmms.nic.in>)



ANALYSIS REPORT OF NANGLOI CETP (12 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/129/ 2559

Dated: 30/01/2026

1. Name & Address of Ind. / Unit : **NANGLOI CETP (12 MLD)**
2. Sampling location : Inlet and Outlet of CETP
3. Date of Sampling : 15.01.2026
4. Sample analyzed and results : DPCC LAB
5. Parameters analyzed and result :

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	6.4	5.5-9.0	7.1	6-9	7.54
2	TSS	293	600	70	100	8.2
3	COD	584	750	60	250	62.9
4	BOD (3 days at 27° C)	210	300	22	30	9.6
5	Oil & Grease	12.8	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	11.5	50	6.1	50	-
7	Sulphide	4.5	5.0	1.1	2.0	-
8	Phosphate	7.1	15.0	2.0	5.0	-

All values are in mg/l except pH

Flow: 3.155 MLD

I/C Water Laboratory

Scientist B/Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



ANALYSIS REPORT OF MANGOLPURI CETP (2.4 MLD) FOR THE MONTH OF JANUARY 2026

Report Number: DPCC/W/CETP/25-26/130/ 2560

Dated: 30/01/2026

1. Name & Address of Ind. / Unit

MANGOLPURI CETP (2.4 MLD)

2. Sampling location

Inlet and Outlet of CETP

3. Date of Sampling

15.01.2026

4. Sample analyzed and results

DPCC LAB

5. Parameters analyzed and result

S. No	Parameter	Inlet		Final Outlet		OLMS
		Water Quality	EPA Standards	Water Quality	EPA Standards	
1	pH	7.6	5.5-9.0	7.4	6-9	7.66
2	TSS	360	600	40	100	9.6
3	COD	680	750	60	250	59.0
4	BOD (3 days at 27° C)	240	300	20	30	8.6
5	Oil & Grease	11.2	20.0	2.8	10.0	-
6	Ammonical Nitrogen as N	8.7	50	2.5	50	-
7	Sulphide	4.1	5.0	1.5	2.0	-
8	Phosphate	7.6	15.0	1.8	5.0	-

All values are in mg/l except pH

Flow: 1.427 MLD

I/C Water Laboratory

Scientist 'B'/Analyst