



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/01/2818

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I,II (20)	Inlet	7.7	10	10	50	10	5	2	230	Meeting the standards
		Outlet	7.4	8	7	36	1.6	2.7	0.7	150	
		OLMS	7.85	6.61	4.86	23.49	-	1.49	-	-	
		Inlet	7.4	214	165	416	10.8	12.4	12.4	-	
2	Ph-III (10)	Outlet	7.3	7	6	32	1.2	2.4	1.0	170	Meeting the standards
		OLMS	7.49	8.08	6.7	26.94	-	1.62	-	-	
		Total 30									

Mukherjee

I/C Water Laboratory

Dr. Nandita Mohita

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/02/2819

Dated 6/8/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results												
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)			
1	70 MGD	Inlet	7.7	176	140	352	9.6	9.3	5.9			Meeting the standards
		Outlet	7.9	7	6	32	1.2	2.8	0.8		76	
		OLMS	7.63	5.84	3.63	27.42	-	1.85	-		-	
Total 70												

I/C Water Laboratory

DR. NANDINI AGRIJA
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/26-27/03/2820

Dated: 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Inlet	7.5	156	145	368	9.2	11.9	6.6			
		Outlet	7.8	6	5	32	1.6	2.8	0.8	120		
		OLMS	7.62	7.43	6.20	32.00	-	1.81	-	-		
2	Ph-II(40)		7.7	160	155	336	10	10.5	7.4		Meeting the standards	
		Inlet	7.7	160	155	336	10	10.5	7.4			
		Outlet	7.3	7	6	28	1.2	2.9	0.7	140		
		OLMS	7.54	7.59	5.69	40.65	-	4.61	-	-		
Total 80												

Amisha

I/C Water Laboratory

08/05/2026
Secy, DPCC



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number DPCC/W/STP/26-27/04/2821

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.3	192	140	292	10.4	10.3	4.7		Meeting the standards
		Outlet	7.2	8	7	24	1.2	3.5	0.6	180	
		OLMS	7.72	7.91	7.17	34.65	-	3.86	-	-	
Total 15											

I/C Water Laboratory

Mishra

Dr. NANDITA KHOTTA
Executive Engineer



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/05/2822

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

- | | | |
|------------------------------------|---|-------------------------|
| 1. Name of STP | : | Delhi Gate (Old) |
| 2. Sampling location | : | Inlet and Outlet of STP |
| 3. Date of sampling | : | 09.04.2026 |
| 4. Samples collected by | : | DPCC Lab |
| 5. Parameters analyzed and results | : | |

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.4	176	140	364	12	12.1	9.2		Not meeting the Standards wrt. TSS, BOD & Fecal coliform
		Outlet	7.1	18	12	40	1.6	3.4	0.8	1500	
		OLMS	7.56	3.27	5.32	18.94	-	1.89	-	-	
Total 2.2											

I/C Water Laboratory

Mukta

Dr. NANDITA KOTIA
Sd/-



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/ 06/12823

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.2	152	130	340	12.4	10.4	5.4	-	Meeting the standards
		Outlet	7.6	8	7	28	1.2	1.7	0.7	120	
		OLMS	7.59	6.63	6.25	22.99	-	0.20	-	-	
Total 15											

I/C Water Laboratory

Signature



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/26-27/07/12824

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Sen Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.5	196	140	360	11.2	9.8	8.3	-	Meeting the standards
		Outlet	7.3	7	6	20	1.2	1.6	0.9	140	
		OLMS	7.87	6.87	5.66	27.53	-	3.40	-	-	
Total 2.2											

I/C Water Laboratory

Murli

DPCC/W/STP/26-27/07/12824

SECRET



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/08/2825

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards	
			7.3	154	110	308	10.4	10.5	8.5			
		Outlet	7.5	4	3	12	1.2	1.5	0.7	76		
		OLMS	7.62	0.56	1.68	8.96	-	0.62	-	-		
Total 1												

I/C Water Laboratory

M. K. Sharma

DPCC
Secretariat



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/26-27/091/2826

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	9	Inlet	7.1	168	115	352	13.6	9.3	8.7		Meeting the Standards
		Outlet	7.6	6	5	12	1.6	3.2	0.6	95	
		OLMS	7.62	8.22	7.73	25.09	-	1.97	-	-	
Total 9											

M. White

I/C Water Laboratory

DPCC/STP/26-27/091/2826
Sd/-



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/26-27/10/2827

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I (10)	Inlet	7.4	164	130	368	10.8	10.5	8.4		Meeting the Standards
		Outlet	7.7	8	7	24	1.6	2.0	0.9	170	
		OLMS	7.83	3.80	4.60	22.50	-	4.62	-	-	
2	Ph-II & III (25+10)	Outlet	7.8	6	4	32	0.8	1.2	1.7	150	Meeting the Standards
		OLMS	7.58	7.50	8.30	29.90	-	3.59	-	-	
Total 45											

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/26-27/11/2828

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-IV (45)	Inlet	7.1	164	140	368	12.4	9.7	5.2		Meeting the Standards	
		Outlet	7.2	9	8	40	0.8	2.9	0.8	180		
		OLMS	7.52	8.90	7.89	31.90	-	4.50	-	-		
Total 45												

I/C Water Laboratory

Mishra

Dr. NANDITA MOITRA

Scientist D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <http://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/ 12 / 2836

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		7.6	220	170	348	11.6	9.7	7.4	-		
		Outlet	7.4	8	7	36	1.2	2.1	0.6	140	
		OLMS	7.53	8.54	6.94	36.6	-	2.4	-	-	
Total 124											

Murta

I/C Water Laboratory



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/26-27/131/2830

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
16		Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards
			7.6	220	170	348	11.6	9.7	7.4		
			7.4	8	7	28	1.6	2.8	1.1	170	
		Outlet	7.51	9.45	7.76	36.36	--	4.36	-	-	
		OLMS									
Total 16											

I/C Water Laboratory

M. K. Singh

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/14/2831

Dated 68/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards
			7.3	176	150	380	11.2	11.5	13.9		
		Outlet	7.1	7	6	24	1.6	3.2	0.6	130	
		OLMS	7.50	8.13	7.04	28.75	--	1.37	-	-	
Total 30											

I/C Water Laboratory

Write

Dr. NANDITA HOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccenms.nic.in>)



Report Number: DPCC/W/STP/26-27/15/12832

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 68/05/2026

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	7	Inlet	6.5-9.0 7.3	10 190	10 150	50 392	10 10.4	5 10.5	2 9.4	230	Meeting the standards	
		Outlet	7.4	7	6	24	1.2	1.2	0.7	140		
		OLMS	7.41	08	4.2	26.7	-	3.3	-	-		
Total 7												

I/C Water Laboratory

M. K. Sharma

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/26-27/161/2833

Dated 68/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	25	Inlet	7.4	196	145	368	10.8	10.9	10.3		Not meeting the Standard wrt TSS, BOD, Ammonical nitrogen, Dissolved phosphate & fecal coliform
		Outlet	7.6	15	13	32	1.2	5.2	2.3	8400	
		OLMS	7.46	22.78	17.09	67.40	-	17.61	-	-	
Total 25											

I/C Water Laboratory

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocms.nic.in>)



Report Number: DPCC/W/STP/26-27/141/2834

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, Dissolved phosphate & Fecal Coliform	
		7.7	164	150	360	9.6	9.0	10.0				
		Outlet	7.5	18	14	44	1.2	3.2	2.7	1700		
		OLMS	-	-	-	-	-	-	-	-		
2	15 Ph-2	Inlet	7.3	182	140	296	12	16.8	8.5		Meeting the Standards	
		Outlet	7.7	8	7	36	1.6	3.8	1.4	130		
		OLMS	7.41	4.91	4.25	22.84	-	3.12	-	-		
		Total 20										

I/C Water Laboratory

M. K. Sharma



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/181/2835

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	15	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD, Dissolved phosphate & Fecal Coliform.
			7.5	186	150	436	10.8	10.5	11.3	-	
		Outlet	7.3	16	14	44	1.6	2.4	2.8	11000	
		OLMS	7.56	9.06	7.66	36.71	-	4.04	-	-	
Total 15											

I/C Water Laboratory

Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/ 19/2836

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 6/8/2026

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	-	Not meeting the Standards wrt TSS, BOD, COD, Dissolved phosphate & Fecal Coliform.
		Outlet	7.5	216	190	424	11.6	12.4	12.4	-	
		OLMS	7.3	33	19	72	1.2	2.7	2.5	16000	
Total 5			7.89	23.39	17.41	67.18	-	4.35	-	-	

I/C Water Laboratory

N. N. N. N.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/20/2837

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	2.2	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS,BOD,COD,Dissolved Phosphate & Fecal Coliform.	
			7.5	208	140	440	12	9.9	9.4	-		
		Outlet	7.3	16	13	68	1.2	3.8	2.4	18000		
			OLMS	8.11	7.86	9.82.	39.03	-	3.79	-		-
2	3	Inlet	7.2	196	165	424	16	10.9	10.3	-	Not meeting the standards wrt TSS,BOD,,Dissolved Phosphate & Fecal Coliform.	
			7.3	18	16	40	1.6	2.0	2.3	8400		
		Outlet	7.3	18	16	40	1.6	2.0	2.3	8400		
			OLMS	7.75	8.25	9.75	42.52	-	3.50	-		-
Total 5.2												

M. White

I/C Water Laboratory

Dr. NANDYA MOHAPATRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/ 21 / 2838

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 08/05/2026

1. Name of STP : Pappankalan Ph-I (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.1	184	135	388	12	10.6	8.7	230	Meeting the standards
		Outlet	7.6	8	6	32	1.2	3.2	0.6	180	
		OLMS	8.08	8.86	7.49	31.69	-	1.89	-	-	
Total 20											

I/C Water Laboratory

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocommis.nic.in>)



Report Number: DPCC/W/STP/26-27/ 22/2889

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
	20	Inlet	7.1	184	135	388	12	10.6	8.7	230	Meeting the standards
		Outlet	7.5	7	6	24	1.6	1.6	0.7	110	
		OLMS	8.29	5.91	4.65	27.45	-	2.15	-	-	
Total 20											

I/C Water Laboratory

M. Nita

Dr. NANDITA SINGH
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocems.nic.in>)



Report Number DPCC/W/STP/26-27/ 23/2846

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

Dated 68/05/2026

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards
			7.9	184	125	348	10.8	11.9	9.4		
		Outlet	7.2	8	5	40	1.2	1.2	0.6	84	
		OLMS	7.57	9.80	6.00	31.00	-	2.73	-	-	
Total 5											

I/C Water Laboratory

N. Mithra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/24/2841

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	60	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards
			7.3	180	160	364	11.2	10.3	8.4		
		Outlet	7.2	7	6	36	1.2	3.5	0.9	79	
			OLMS	7.84	7.72	6.33	26.43	-	4.83	-	
2	20	Outlet	7.1	8	7	24	1.6	3.5	0.9	150	Meeting the standards
		OLMS	7.74	8.71	6.37	30.25	-	4.41	-	-	
Total 60											

I/C Water Laboratory
Mishra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, JSBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/25/2842

Dated 6/8/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12 (MGD)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards
			7.9	192	130	384	9.6	11.9	9.4		
		Outlet	7.2	7	6	24	1.2	2.0	0.6	110	
		OLMS	7.58	5.26	4.21	19.44	-	1.6	-	-	
Total 12											

I/C Water Laboratory

Mhila

Dr. RAJENDRA K. GUPTA
Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/26-27/26/2848

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Nilothi (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :
- 6.

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	60	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards	
		Outlet	7.1	208	140	328	9.2	10.5	12.2			
		OLMS	7.4	7	6	40	1.6	3.4	0.8	150		
			7.70	7.98	5.70	32.17	-	3.00	-	-		
Total 60												

I/C Water Laboratory

Nikhil

DPCC W/STP/26-27/26/2848
Signed-D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/27/2844

Dated 68/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.3	196	150	364	11.2	11.5	6.9		Meeting the Standards
		Outlet	7.2	8	7	32	1.2	2.6	0.6	180	
		OLMS	7.75	5.74	7.30	47.50	-	3.72	-	-	
Total 20											

I/C Water Laboratory

M. K. Singh

DR. ANAND K. SINGH
Secretary



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/26-27/28/2845

Dated 08/05/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF APRIL-2026

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 22.04.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	10	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
			7.5	170	130	336	10.4	10.5	9.4			
		Outlet	7.4	8	7	44	1.6	2.4	0.7	79		
		OLMS	8.70	8.10	6.60	30.00	-	2.51	-	-		
Total 10												

I/C Water Laboratory

M. K. Mittal

Dr. MANOJ K. VOTRA
Scientist-D