



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCCW/STP/26-27/61/2978

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	25	Inlet	7.5	216	140	408	12.8	10.9	11.5		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.4	22	16	60	1.2	3.9	0.8	7900	
		OLMS	7.71	22.07	18.50	58.46	-	15.32	-	-	
Total 25											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)

Report Number: DPCC/W/STP/26-27/62/2979

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Yamuna Vihar |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 08.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	10	Inlet	7.1	168	120	336	11.6	10.5	10.2		Not meeting the Standards wrt TSS, BOD, Dissolved Phosphate & Fecal Coliform.
		Outlet	7.8	20	12	48	1.6	2.8	2.5	1400	
		OLMS	7.69	14.12	8.62	39.86	-	16.22	-	-	
2.	15	Inlet	7.6	192	120	308	12.4	14.2	8.7		Meeting the standards.
		Outlet	7.5	8	8	44	0.8	3.8	1.1	180	
		OLMS	7.54	4.79	5.18	22.45	-	3.80	-	-	
Total 25											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/63/ **2980**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Sonia Vihar**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **08.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	7	Inlet	7.2	186	120	392	10.4	10.7	7.9		Meeting the standards.
		Outlet	7.3	7	6	24	1.2	2.3	0.7	110	
		OLMS	6.57	6.40	7.20	33.50	-	4.45	-	-	
Total 7											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/64/2981

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Coronation Pillar |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 09.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I,II (20)	Inlet	7.3	182	160	392	11.6	10.2	9.9		Meeting the standards.
		Outlet	7.2	8	7	28	1.6	2.3	1.2	140	
		OLMS	7.83	8.13	5.99	28.88	-	1.44	-	-	
2.	Ph-III (10)	Inlet	7.7	138	190	416	9.6	8.9	10.5		Meeting the standards
		Outlet	7.9	9	4	24	0.8	2.0	0.6	170	
		OLMS	7.60	8.53	6.17	30.20	-	1.99	-	-	
Total 30											

Mishra
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/65/ **2982**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Coronation Pillar |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 09.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	70	Inlet	7.4	176	140	360	10	8.9	7.9		Meeting the standards
		Outlet	7.2	8	5	36	1.6	2.1	0.8	130	
		OLMS	-	-	-	-	-	-	-	-	OLMS is not functional
Total 70											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/66/ **2983**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Rithala |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 09.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I (40)	Inlet	7.8	162	240	380	11.2	10.2	10.5		Meeting the standards.
		Outlet	7.2	6	4	40	1.6	2.0	0.6	150	
		OLMS	7.58	7.12	6.12	26.57	-	1.40	-	-	
2.	Ph-II (40)	Inlet	7.4	186	140	352	10.8	10.8	7.9		Meeting the standards.
		Outlet	7.7	8	6	20	1.2	2.5	0.9	110	
		OLMS	7.59	8.21	7.03	33.43	-	4.36			
Total 80											

Maitra

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCCW/STP/26-27/67/2984

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	15	Inlet	7.3	184	168	316	10	10.6	8.6		Meeting the standards
		Outlet	7.2	9	7	32	0.8	2.5	1.1	140	
		OLMS	7.84	8.11	7.19	36.17	-	2.45	-	-	
Total 15											

Nandita
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/68/2985

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	124	Inlet	7.2	198	160	364	11.2	10.8	9.4		Meeting the standards.
		Outlet	7.5	9	8	40	1.6	2.7	1.6	130	
		OLMS	7.57	6.91	5.92	26.98	-	2.96	-	-	
Total 124											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/69/ **2986**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Okhla**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **11.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	16	Inlet	7.2	198	160	364	11.2	10.8	9.4		Meeting the standards
		Outlet	7.3	6	5	28	1.2	2.8	0.8	110	
		OLMS	7.67	11.47	9.41	44.11	-	5.29	-	-	
Total 16											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/70/2987

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 11.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	30	Inlet	7.7	206	170	396	9.6	10.6	11.0		Meeting the standards.
		Outlet	7.4	9	7	28	1.2	2.8	0.8	160	
		OLMS	7.71	5.96	6.80	28.16	-	1.60	-	-	
Total 30											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/71/2988

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I&II (2.2)	Inlet	7.2	184	140	364	10	10.7	8.7		Meeting the standards.
		Outlet	7.5	7	6	40	1.6	2.2	1.3	120	
		OLMS	7.51	5.21	0.7	18.38	-	1.84	-	-	
Total 2.2											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/72/ **2989**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Delhi Gate (New)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **15.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I&II (15)	Inlet	7.4	194	114	312	10.8	9.5	9.9		Meeting the standards
		Outlet	7.1	8	5	28	1.2	2.1	0.7	190	
		OLMS	7.58	6.94	6.66	23.29	-	0.2	-	-	
Total 15											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/73/2990

Dated: 68/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Sen Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I,II (2.2)	Inlet	7.6	206	118	388	10.8	11.2	10.0		Meeting the standards.
		Outlet	7.1	7	6	28	1.2	2.4	0.7	140	
		OLMS	7.46	7.31	4.72	24.06	-	3.78	-	-	
Total 2.2											

Nandita
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/74/2991

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	1	Inlet	7.1	196	140	312	10.8	10.8	10.5		Meeting the standards.
		Outlet	7.4	6	3	32	1.2	1.9	0.8	81	
		OLMS	7.59	0.77	1.99	10.59	-	0.86	-	-	
Total 1											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/75/ **2992**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Chilla**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **15.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	9	Inlet	7.4	190	131	340	11.6	9.7	8.7		Meeting the standards.
		Outlet	7.6	7	6	32	1.6	3.2	1.4	180	
		OLMS	7.62	7.05	6.94	25.58	-	2.71	-	-	
Total 9											

Nandita
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/76/ **2993**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Kondli**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **15.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Ph-I (10)	Inlet	7.5	206	156	364	12.4	10.6	10.7		Meeting the standards.
		Outlet	7.6	8	6	36	1.2	2.8	0.7	210	
		OLMS	7.53	5.50	8.70	22.90	-	2.93	-	-	
2.	Ph-II&III (20+15)	Outlet	7.2	6	4	28	1.6	2.1	0.8	130	Meeting the standards.
		OLMS	7.53	7.0	7.70	28.10	-	3.21	-	-	
Total 45											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/26-27/77/2994

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	45	Inlet	7.4	176	140	360	10	8.9	7.9		Meeting the standards.
		Outlet	7.2	8	5	36	1.6	2.1	0.8	130	
		OLMS	7.49	7.58	6.24	26.76	-	4.46	-	-	
Total 45											

Nandita
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE

Lifestyle for Environment

Report Number: DPCC/W/STP/26-27/781/2995

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Pappankalan Ph-I (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	30	Inlet	7.8	198	118	388	12	11.5	9.4		Meeting the standards.
		Outlet	7.6	6	4	40	1.2	2.8	0.7	180	
		OLMS	7.43	8.73	6.43	28.12	-	1.80	-	-	
Total 30											

Maitra

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/79/2996

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	20	Inlet	7.8	198	118	388	12	11.5	9.4		Meeting the standards.
		Outlet	7.1	7	6	32	0.8	1.9	0.8	150	
		OLMS	7.42	6.13	5.1	28.9	-	1.79	-	-	
Total 20											

Nandita
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/80/2997

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	5	Inlet	7.3	192	106	348	9.2	11.0	8.6		Meeting the standards.
		Outlet	7.1	8	4	44	1.6	1.8	0.8	84	
		OLMS	7.32	9.00	6.30	29.50	-	2.03	-	-	
Total 5											


I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/81/2998

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	15	Inlet	7.6	210	132	436	13.6	12.1	13.4		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	27	16	80	1.2	3.1	1.4	15000	
		OLMS	7.36	24.22	20.35	71.38	-	4.52	-	-	
Total 15											

Nandita Moitra
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/82/ **2999**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Keshopur**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **18.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	60	Inlet	7.3	198	150	344	12.8	11.1	11.1		Meeting the standards
		Outlet	7.7	7	5	28	0.8	3.1	0.8	84	
		OLMS	7.69	8.05	6.69	31.06	-	2.37	-	-	
2.	20	Outlet	7.5	6	4	32	1.6	2.7	0.5	180	Meeting the standards
		OLMS	7.39	6.9	5.19	20.76	-	1.85	-	-	
Total 80											

Nandita
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/83/ 3000

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Keshopur STP (New) |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 18.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	12	Inlet	7.5	188	122	340	10.4	10.8	10.7		Meeting the standards.
		Outlet	7.2	8	7	24	1.2	2.1	0.7	130	
		OLMS	7.68	10.05	8.48	40.83	-	4.53	-	-	
Total 12											

Nandita
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/84/ **3001**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Nilothi (Old)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **18.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	60	Inlet	7.6	194	128	368	9.6	10.1	10.5		Meeting the standards.
		Outlet	7.7	7	5	40	1.2	2.6	0.7	190	
		OLMS	7.50	9.20	6.5	27.17	-	2.5	-	-	
Total 60											

Nandita

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCCW/STP/26-27/85/ **2002**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Nilothi (New)**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **18.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	20	Inlet	7.1	204	146	344	10.8	10.3	10.0		Meeting the standards.
		Outlet	7.6	9	8	32	1.6	1.8	0.7	110	
		OLMS	7.49	7.9	4.16	40.10	-	4.28	-	-	
Total 20											

Nandita
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/86/3003

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	15	Inlet	7.3	188	150	360	11.6	12.0	11.6		Not meeting the Standards wrt TSS, BOD, Dissolved Phosphate & Fecal Coliform.
		Outlet	7.6	18	14	44	1.2	3.3	2.3	16000	
		OLMS	7.92	9.40	7.64	37.28	-	5.00	-	-	
Total 15											

Nandita
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/87/3004

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

- | | | | |
|----|---------------------------------|---|-------------------------|
| 1. | Name of STP | : | Vasant Kunj |
| 2. | Sampling location | : | Inlet and Outlet of STP |
| 3. | Date of sampling | : | 19.06.2026 |
| 4. | Samples collected by | : | DPCC Lab |
| 5. | Parameters analyzed and results | : | |

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	2.2	Inlet	7.7	204	148	416	11.2	10.3	13.4		Not meeting the Standards wrt TSS, BOD, COD, Dissolved Phosphate & Fecal Coliform.
		Outlet	7.4	20	14	72	1.6	3.7	2.6	18000	
		OLMS	8.37	10.35	8.48	41.94	-	4.67	-	-	
2.	3	Inlet	7.5	210	124	408	12.4	11.4	9.6		Not meeting the Standards wrt TSS, BOD, Dissolved Phosphate & Fecal Coliform.
		Outlet	7.2	22	16	28	1.2	2.7	2.7	8400	
		OLMS	8.10	10.64	9.16	50.25	-	4.14	-	-	
Total 5.2											

[Signature]
 W/C Water Laboratory
DR. NANDITA MOITRA
 Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



LiFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/88/3005

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	5	Inlet	7.4	254	110	404	12.8	12.8	8.5		Meeting the standards.
		Outlet	7.1	8	7	48	1.6	2.2	0.7	95	
		OLMS	7.92	8.25	2.52	32.55	-	1.54	-	-	
Total 5											

I/C Water Laboratory

Nandita
Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/26-27/89/ **3006**

Dated: **08/07/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : **Narela**
2. Sampling location : **Inlet and Outlet of STP**
3. Date of sampling : **19.06.2026**
4. Samples collected by : **DPCC Lab**
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	10	Inlet	7.6	174	132	352	10.8	13.5	10.6		Meeting the standards.
		Outlet	7.2	8	5	32	0.8	3.0	0.9	76	
		OLMS	7.61	6.9	6.52	24.78	-	1.09	-	-	
Total 10											

[Signature]
I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/26-27/90/3007

Dated: 08/07/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JUNE-2026

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.06.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	0.66	Inlet	-	-	-	-	-	-	-	-	Sample was not taken due to rehabilitation
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D