



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/331/2734

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I (10)	Inlet	7.6	170	140	344	13.6	9.9	9.6	-	Meeting the Standards.	
		Outlet	7.2	9	6	20	1.2	2.3	0.5	220		
		OLMS	7.68	4.80	4.0	22.60	-	4.28	-	-		
2	Ph-II & III (25+10)	Outlet	7.1	7	5	32	0.8	1.3	0.8	180	Meeting the Standards.	
		OLMS	7.52	9.50	7.30	32.80	-	5.00	-	-		
Total 45												

M. K. K.

I/C Water Laboratory

D. NAVDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/332/2785

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	7	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.	
		Outlet	7.3	182	145	432	13.6	9.2	7.4			
		OLMS	7.2	5	6	28	1.2	1.3	0.8	150		
Total 7			7.86	1.90	4.80	11.20	-	2.90	-	-		

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/333/9736

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Ghitorni
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
			7.3	212	195	444	11.2	8.5	9.9	-	
			7.1	16	13	52	1.6	3.1	0.6	17000	
		Outlet									
		OLMS	9.30	21.33	15.87	61.26	-	3.97	-	-	
Total 5											

I/C Water Laboratory

DR NANDITA MCFRRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/334/2237

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Parameters											Remarks
Sr. No.	Installed Capacity (MGD)	STP Standard	pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.2	180	155	464	12	10.5	7.4	-	Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.1	15	13	40	2	3.2	1.4	28000	
		OLMS	8.92	17.84	11.58	52.20	-	5.58	-	-	
Total 15											

M. N. Mittal

I/C Water Laboratory

Dr. NANDINI MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/335/2738

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	2.2	Inlet	7.5	216	130	480	13.6	12.0	10.2		Not meeting the standards wrt TSS, BOD COD & Fecal Coliform.	
		Outlet	7.4	13	12	68	2.4	3.4	0.7	11000		
		OLMS	8.57	15.46	13.28	45.72	-	5.86	-	-		
2	3	Inlet	7.1	182	155	436	9.6	10.5	10.5		Not meeting the standards wrt TSS, BOD & Fecal Coliform.	
		Outlet	7.2	16	14	44	2.8	1.4	0.9	8900		
		OLMS	8.51	8.97	11.58	50.84	-	4.09	-	-		
Total 5.2												

Mishra

I/C Water Laboratory

Dr. NANDIYA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/836/2789

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Pappankalan Ph-1 (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.4	194	140	384	12.8	10.3	12.0	-	Meeting the standards.
		Outlet	7.1	7	5	28	1.6	3.1	0.9	170	
		OLMS	7.71	8.75	6.23	27.59	-	2.24	-	-	
Total 20											

I/C Water Laboratory

Dr. NANDITA MOITRA

Signature: D

Maitra



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/337/2740

Dated | 3/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
20		Inlet	7.4	194	140	384	12.8	10.3	12.0		Meeting the standards.
		Outlet	7.1	5	6	20	1.2	0.9	0.8	140	
		OLMS	7.64	5.79	4.29	26.23	-	2.13	-	-	
Total 20											

I/C Water Laboratory

Almita

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number DPCC/W/STP/25-26/338/2741

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 06.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters						Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	
1	5	Inlet	6.5-9.0	10	10	50	10	5	2	230
			7.3	172	130	360	11.6	9.8	9.0	-
		Outlet	7.5	8	7	36	0.8	1.7	0.7	91
		OLMS	7.49	6.20	6.10	28.70	-	2.49	-	-
Total 5										

Meeting the Standards.

Mishra

I/C Water Laboratory

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/339/2342

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	25	Inlet	7.3	192	140	384	12.4	8.9	7.9		Not meeting the Standard wrt TSS, BOD & fecal coliform.	
		Outlet	7.1	18	16	28	1.6	1.7	1.2	9500		
		OLMS	6.64	23.60	18.90	65.47	-	19.12	-	-		
Total 25												

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/340/2743

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	10 Ph-1	Inlet	6.5-9.0	10	10	50	10	5	2	230	Not meeting the standards wrt TSS, BOD & Fecal Coliform
		Outlet	7.1	160	155	352	13.6	10.9	10.3		
		Outlet	7.4	17	11	48	1.6	3.4	1.2	1500	
		OLMS	8.33	15.42	10.28	43.69	-	15.42	-	-	
2	15 Ph-2	Inlet	7.4	174	130	384	11.6	12.4	12.0		Meeting the Standards.
		Outlet	7.2	7	7	32	2	2.7	0.8	120	
		OLMS	8.35	5.42	5.91	22.41	-	2.95	-	-	
		Total 20									

Murika

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/341/2344

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks		
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml			
1	9	Inlet	7.3	160	120	388	10	11.6	5	17.7	7.3	-	Meeting the Standards.
		Outlet	7.1	5	4	36	2	3.7	0.7	91			
		OLMS	7.62	11.5	9.18	24.9	-	1.7	-	-			
Total 9													

I/C Water Laboratory

N. Mishra

Dr. MANDETA MOITRA

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/342/2745

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	1	Inlet	7.5	152	135	356	10.8	11.5	8.0	-	Meeting the Standards.	
		Outlet	7.4	3	3	20	1.6	2.3	0.8	79		
		OLMS	7.55	1.06	2.39	9.58	-	0.54	-	-		
Total 1												

I/C Water Laboratory

Dr NANDITA MOITRA

Scientist-D

M. M. M. M.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/2131/2246

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I,II (2.2)	Inlet	7.6	194	150	400	12	11.9	10.0		Meeting the Standards.
		Outlet	7.2	8	7	44	2	1.2	1.7	150	
		OLMS	7.02	5.99	7.39	28.71	-	5.54			
Total 2.2											

M. K. Mittal

I/C Water Laboratory

Dr. NANDIYA MOITRA

Secretary



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/344/2247

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	Phase-I & II (15)	Inlet	7.2	172	135	316	16.4	11.2	12.1	0	Meeting the Standards.
		Outlet	7.3	9	7	24	1.6	1.6	0.8	110	
		OLMS	7.59	6.59	4.12	22.36	-	0.21	-	-	
Total 15											

I/C Water Laboratory

Mika



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/345/2748

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 10.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-I & II (2.2)	Inlet	7.2	172	135	316	16.4	11.2	12.1	-	Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform
		Outlet	7.3	17	13	64	2.4	3.2	0.6	1800	
		OLMS	7.6	3.78	4.11	18.00	-	1.86	-	-	
Total 2.2											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/346/2349

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 11.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
1	Ph-I, II (20)	Inlet	7.8	10	10	50	10	5	2	230	Meeting the standards.
		Outlet	7.5	9	8	32	1.6	2.0	0.6	130	
		OLMS	7.70	6.61	4.86	23.49	-	1.80	-	-	
		Inlet	7.6	228	170	408	10	14.6	12.2	-	
2	Ph-III (10)	Outlet	7.5	8	6	36	1.2	2.7	0.8	180	Meeting the standards.
		OLMS	7.51	8.10	6.75	27.01	-	1.62	-	-	
		Total 30									

Murika
I/C Water Laboratory
Dr. MANDEVA AGRIYA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number: DPCC/W/STP/25-26/347/2750

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 11.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	70 MGD	Inlet	7.9	188	135	368	8.8	9.6	8.5		Meeting the standards.
		Outlet	7.7	6	5	24	0.8	3.4	0.3	79	
		OLMS	7.62	5.89	3.72	35.49	-	1.86	-	-	
Total 70											

M. W. K.
I/C Water Laboratory
Dr. NANDINI MONTANA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/3481/2751

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	124 MGD	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.
		7.8	216	180	352	13.2	10.7	8.0	-		
		Outlet	7.6	7	8	28	1.6	3.4	0.8	150	
		OLMS	8.80	8.61	6.99	36.85	-	2.42	-		
Total 124											

Mukta

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/349/2752

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	30	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards
			7.9	182	145	376	12.4	12.6	10.4		
		Outlet	7.2	6	4	20	0.8	3.8	0.7	110	
		OLMS	7.68	5.30	6.75	28.01	-	1.40	-	-	
Total 30											

M. K. Sharma

I/C Water Laboratory

Dr. NANDITA MOITRA

Signature



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/1859/2753

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
16		Inlet	7.8	216	180	352	13.2	10.7	8.0		Meeting the Standards.	
		Outlet	7.5	9	6	24	1.2	4.5	1.3	180		
		OLMS	7.59	11.01	7.83	36.71	-	4.40	-	-		
Total 16												

I/C Water Laboratory

Mukherjee

Dr. NANDITA KUMAR
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocnms.nic.in>)



Report Number: DPCC/W/STP/25-26/851/9754

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	0.66	Inlet	-	10	10	50	10	5	2	230	Sample was not taken due to under rehabilitation.
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

I/C Water Laboratory

D. NANDIYA MOITRA

Signature

Murita



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/352/2755

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 17.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks	
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml		
1	10	Inlet	6.5-9.0	10	10	50	10	11.2	11.1	8.8	-	Meeting the standards.
		Outlet	7.9	164	125	328	1.2	2.7	0.6	84		
		OLMS	7.1	7	6	40	-	1.17	-	-		
Total 10			7.68	7.42	5.83	26.50	-	1.17	-	-		

Mandira

I/C Water Laboratory

Dr. NANDITA MOITRA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/353/2756

Dated: 18/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	Ph-I(40)	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the standards	
		Inlet	7.6	152	140	376	10.8	12.3	8.7			
		Outlet	7.3	6	4	28	0.8	2.4	0.7	140		
		OLMS	7.62	7.43	6.20	32.00	-	1.81				
2	Ph-II(40)	Inlet	7.2	162	150	340	9.6	10.2	9.7		Meeting the standards	
		Outlet	7.9	8	7	32	1.2	2.8	0.5	170		
		OLMS	7.34	8.71	6.34	39.60	-	4.49				
		Total 80										

I/C Water Laboratory

Murika

Dr. NARENDRA KOTHA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocems.nic.in>)



Report Number DPCC/W/STP/25-26/354/2757

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

Dated 13/04/2026

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	15	Inlet	7.6	184	165	308	13.6	12.4	12.1		meeting the standards
		Outlet	7.4	9	5	40	1.2	3.4	0.4	210	
		OLMS	7.51	8.5	7.67	37.26	-	4.23	-	-	
Total 15											OLMS was non operational

Misha

I/C Water Laboratory

Dr. MANJIV KOTIA

Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocemms.nic.in>)



Report Number: DPCC/W/STP/25-26/2551/2758

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters									Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml		
1	60	Inlet	6.5-9.0	10	10	50	10	5	2	230	Meeting the Standards.	
			7.3	200	135	296	12.8	12.8	5.6	-		
		Outlet	7.1	8	6	44	0.8	2.5	0.2	170		
		OLMS	7.77	8.25	7.98	30.69	-	2.84	-	-		
Total 60												

I/C Water Laboratory

Mike

D. NANDITA MOITRA

Secretary



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/1356/2759

Dated 13/6/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	20	Inlet	7.8	184	160	352	12.8	13.5	8.1	-	Meeting the Standards.
		Outlet	7.5	7	5	28	1.2	2.1	0.3	120	
		OLMS	6.64	8.66	6.18	41.65	-	3.06	-	-	
Total 20											

I/C Water Laboratory

I. S. MANDYALHOTRA

20/03/2026

M. K. K.



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/3574 2760

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	60		6.5-9.0	10	10	50	10	5	2	230	Meeting the standards.
		Inlet	7.7	184	155	368	12.4	9.4	7.0		
		Outlet	7.3	8	6	20	1.6	3.2	0.6	76	
		OLMS	7.99	7.8	6.3	26.8	-	3.6	-	-	
2	20	Outlet	7.6	9	8	32	1.2	1.8	0.5	130	Meeting the standards.
		OLMS	7.7	7.5	4.8	26.00	-	3.9	-	-	
Total 60											

M. Kishore

I/C Water Laboratory

D. NANDYIA MOITRA
Scientist-D



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/2761

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 18.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
1	12 (MGD)	Inlet	7.5	196	140	396	10.8	10.6	6.7	230	Meeting the standards.
		Outlet	7.1	8	6	28	0.8	2.4	0.3	150	
		OLMS	8.12	8.4	7.09	34.12	-	3.03	-	-	
Total 12											

I/C Water Laboratory
Dr. MANDITA MOITRA
Scientist-D

M. Moitra



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocommis.nic.in>)



Report Number: DPCC/W/STP/25-26/359/9762

Dated 13/04/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF MARCH-2026

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.03.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
1	Ph-IV (45)	Inlet	7.6	168	135	372	10.4	10.8	8.8		Meeting the Standards.
		Outlet	7.2	8	7	36	1.2	2.7	0.4	95	
		OLMS	7.52	8.09	7.89	31.9	-	4.5	-	-	
Total 45											

N.M. Mitta

I/C Water Laboratory

Dr. NANDITA MOITTA

Scientist-D