



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/304/2660/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.2	138	125	308	10.8	10.5	9.7		Meeting the standards.
		Outlet	7.5	8	7	36	1.2	2.4	0.6	120	
		OLMS	7.16	4.80	3.53	17.05	-	1.46	-	-	
2	Ph-III (10)	Inlet	7.1	170	140	404	17.2	9.9	9.6		Meeting the standards.
		Outlet	7.3	9	8	32	1.2	2.3	2.7	180	
		OLMS	8.17	6.16	5.13	20.54	-	1.23			
Total 30											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/302/2659/16.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.5	180	160	360	12	10.9	10.9		Meeting the standards.
		Outlet	7.2	7	6	24	0.8	3.4	1.0	220	
		OLMS	6.83	6.21	3.50	28.81	-	1.14	-	-	
Total 70											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/303/2658 / 6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.4	182	130	348	13.6	12.4	7.4		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.1	5	4	20	1.6	2.7	0.8	430	
		OLMS	7.00	4.29	4.02	18.96	-	1.90	-	-	
Total 2.2											

Mike

I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/304/2657/16.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and Results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.3	192	140	324	11.2	9.4	5.6		Meeting the Standards.
		Outlet	7.1	7	6	24	1.6	3.1	0.6	150	
		OLMS	7.39	6.66	4.40	22.45	-	0.10	-	-	
Total 15											

Mishra
I I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/305/2656/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.4	180	150	344	9.2	10.5	7.4		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.2	6	4	24	1.2	1.5	1.4	350	
		OLMS	7.02	5.99	7.39	28.71	-	5.54			
Total 2.2											

N. Mitha

I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/304 2655/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.1	148	125	360	13.6	12.0	7.5		Meeting the Standards.
		Outlet	7.4	2	2	8	0.4	1.7	0.8	76	
		OLMS	7.47	0.89	2.27	7.95	-	0.39	-	-	
Total 1											

M. Mike

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/307/2654/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/ 100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.3	156	125	360	11.2	10.5	4.2		Meeting the Standards.
		Outlet	7.1	4	5	32	1.2	2.3	0.9	110	
		OLMS	7.73	7.88	6.22	17.05	-	1.08	-	-	
Total 9											

N. Kishore
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/308/2653/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.2	176	130	336	12.8	9.4	8.6		Meeting the Standards.
		Outlet	7.4	8	5	28	1.6	3.1	1.3	210	
		OLMS	7.57	5.8	3.20	23.4	-	3.4	-	-	
2	Ph-II & III (25+10)	Outlet	7.1	6	5	28	0.8	0.9	2.4	170	Meeting the Standards.
		OLMS	7.51	7.8	5.5	31.5	-	5.87	-	-	
Total 45											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/309/2652/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.6	182	145	360	9.6	11.5	7.9		Meeting the Standards.
		Outlet	7.2	9	7	36	0.8	2.7	1.2	140	
		OLMS	7.49	8.40	7.20	31.60	-	3.65	-	-	
Total 45											

I/C Water Laboratory

Scientist B /Analyst

**DELHI POLLUTION CONTROL COMMITTEE**

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/310/2651/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.3	144	130	384	9.6	12.4	7.9		Meeting the Standards.
		Outlet	7.1	7	8	28	1.2	3.8	1.2	95	
		OLMS	8.15	7.01	5.69	30.00	-	1.97	-	-	
Total 124											

N. Mittal
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: **DPCC/W/STP/25-26/311/2650/6.7.26**

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	16	Inlet	7.3	144	130	384	9.6	12.4	7.9		Not meeting the Standards wrt Fecal coliform.
		Outlet	7.2	8	7	32	1.6	2.7	0.8	350	
		OLMS	8.01	8.86	6.30	29.54	-	3.54	-	-	
Total 16											

N. Mittal
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/31212649 / 6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.1	186	155	424	8.8	10.9	10.3		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.2	8	6	24	0.8	3.4	2.4	280	
		OLMS	8.21	5.77	7.04	28.39	-	1.16	-	-	
Total 30											

M. Mita
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/313/2648/16.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	-	-	-	-	-	-	-	-	Sample was not taken due to under rehabilitation of STP
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/314/2647 / 6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 13.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.5	166	135	372	10.8	11.5	8.0		Meeting the standards.
		Outlet	7.4	7	6	36	1.6	2.3	0.8	79	
		OLMS	814	7.16	5.64	24.30	-	1.79	-	-	
Total 10											

N. Mike
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/35/2646/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.6	194	150	416	12	11.9	10.0		Not meeting the Standard wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.2	17	14	68	2	1.2	1.7	8400	
		OLMS	7.88	24.90	19.95	69.08	-	20.17	-	-	
Total 25											

M. M. M. M.
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: **DPCC/W/STP/25-26/316/2645/6.2.26**

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.1	164	125	344	12	16.8	10.0		Not meeting the standards wrt TSS, BOD & Fecal Coliform
		Outlet	7.4	15	12	44	1.2	3.8	1.4	1100	
		OLMS	7.99	14.97	11.18	37.26	-	16.56	-	-	
2	10 Ph-2	Inlet	7.2	172	140	332	16.4	11.2	12.1		Meeting the Standards.
		Outlet	7.3	8	6	32	2.4	3.2	0.6	150	
		OLMS	7.91	5.35	4.92	23.38	-	2.46	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/317/2644/16.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 16.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	7.1	186	155	428	16.8	9.9	11.0	-	Meeting the standards.
		Outlet	7.5	7	6	24	1.6	1.7	1.0	170	
		OLMS	11.62	6.20	3.00	19.80	-	4.91	-	-	
Total 7											

N. White
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommms.nic.in>)



Report Number: DPCC/W/STP/25-26/318/2643/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.5	204	180	468	13.2	11.9	10.8		Not meeting the standards wrt TSS, BOD,COD & Fecal Coliform.
		Outlet	7.3	17	15	64	3.2	4.0	1.1	15000	
		OLMS	7.98	14.42	12.39	42.64	-	5.45	-	-	
2	3	Inlet	7.2	188	160	416	9.2	11.9	9.8		Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.3	19	14	48	2.4	1.2	0.9	9500	
		OLMS	7.88	8.30	10.71	47.04	-	3.78	-	-	
Total 5.2											

N. Mishra
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/319/2642/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	216	190	432	12	11.5	9.4		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	14	16	56	1.6	3.4	1.4	18000	
		OLMS	7.84	17.97	13.38	51.62	-	3.34	-	-	
Total 5											

M. M. M. M.
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/320/2641/16.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.8	182	170	428	12.4	10.9	7.2		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	17	12	48	2.4	3.5	1.3	24000	
		OLMS	8.07	16.13	10.44	47.06	-	5.04	-	-	
Total 15											

N. Mittal
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/321/ 2640/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Pappankalan Ph- I (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.1	188	135	368	13.6	10.5	12.4		Meeting the standards.
		Outlet	7.6	8	6	24	1.2	2.4	1.0	140	
		OLMS	8.02	8.97	6.39	24.55	-	2.06	-	-	
Total 20											

White
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/322/2639 / 6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.1	188	135	368	13.6	10.5	12.4		Meeting the standards.
		Outlet	7.5	6	5	28	0.8	0.9	0.6	110	
		OLMS	8.19	6.05	6.49	32.17	-	1.94	-	-	
Total 20											

M. M. M. M.
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccommms.nic.in>)



Report Number DPCC/W/STP/25-26/323/2638/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 23.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.9	164	125	364	11.2	10.3	4.7		Meeting the Standards.
		Outlet	7.2	7	6	32	1.2	1.3	0.6	95	
		OLMS	8.03	9.30	6.20	31.40	-	2.31	-	-	
Total 5											

Mishra
I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/324/2637/6.3.26

Dated:

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 24.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.5	162	150	384	9.6	9.3	5.7		Meeting the standards
		Outlet	7.8	8	7	36	1.2	1.7	1.0	110	
		OLMS	7.62	7.43	6.20	32.00	-	1.81			
2	Ph-II(40)	Inlet	7.7	152	140	344	10.8	12.3	7.4		Not meeting the Standard w.r.t. fecal coliform.
		Outlet	7.3	6	4	24	0.8	2.8	1.3	540	
		OLMS	8.15	7.89	5.74	35.85	-	4.78			
Total 80											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number DPCC/W/STP/25-26/325/26.26/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 24.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.6	184	165	408	13.6	11.5	9.4		meeting the standards
		Outlet	7.2	9	5	28	1.2	2.7	1.6	170	
		OLMS	8.25	7.87	6.77	27.88	-	2.28	-	-	
Total 15											

M. Mite

I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/326/ ~~6326~~ 2625/ 6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.2	200	125	356	12.8	13.5	10.5		Not meeting the Standard w.r.t. fecal coliform.
		Outlet	7.6	8	6	32	0.8	1.8	1.9	430	
		OLMS	8.29	7.71	6.34	26.54	-	4.15	-	-	
2	20	Outlet	7.7	7	5	28	1.2	3.4	1.4	130	Meeting the standards.
		OLMS	8.66	7.15	5.43	22.01	-	3.67	-	-	
		Total 60									

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/327/2634/6.2.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12 (MGD)	Inlet	7.3	156	140	356	12.4	9.4	8.0		Meeting the standards.
		Outlet	7.1	8	6	32	1.6	2.5	1.3	180	
		OLMS	7.62	7.28	6.26	32.61	-	1.08	-	-	
Total 12											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/328 2633 / 6.3.26


Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.1	168	135	372	14	10.6	13.5		Meeting the Standards.
		Outlet	7.4	9	8	48	1.2	3.2	1.4	140	
		OLMS	7.95	9.44	7.95	44.16	-	3.91	-	-	
Total 40											


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/329/2632/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Nilothi New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 25.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/l) 10	BOD (mg/l) 10	COD (mg/l) 50	Oil & Grease (mg/l) 10	Ammonical Nitrogen (mg/l) 5	Dissolved Phosphate as P(mg/l) 2	Fecal Coliform MPN/100ml 230	
1	20	Inlet	7.3	208	140	384	10.8	12.3	10.6		Meeting the Standards.
		Outlet	7.2	8	7	40	1.6	3.1	1.4	120	
		OLMS	7.98	9.87	6.88	44.44	-	3.29	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/330/2631/6.3.26

Dated

ANALYSIS REPORT OF STP FOR THE MONTH OF FEBRUARY-2026

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 26.02.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	-	-	-	-	-	-	-	-	Sample was not collected due to maintenance work under process by DJB
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 5											

Nhite
I/C Water Laboratory

[Signature]
Scientist B /Analyst