



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/27/2561

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Mehrauli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.5	194	150	412	10.8	10.5	11.3		Not meeting the standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.6	16	14	76	2	2.4	1.1	21000	
		OLMS	7.17	8.74	6.82	36.01	-	2.90	-	-	
Total 15											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/272/2562

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Vasant Kunj
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	2.2	Inlet	7.5	184	165	440	17.2	9.9	9.4		Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.3	12	11	44	2.4	3.8	1.4	8100	
		OLMS	6.67	8.39	7.42	26.49	-	4.30	-	-	
2	3	Inlet	7.2	208	170	424	16	10.9	10.3		Not meeting the standards wrt TSS, BOD & Fecal Coliform.
		Outlet	7.3	13	12	48	2.8	3.4	2.4	16000	
		OLMS	6.63	7.84	6.11	30.14	-	3.10	-	-	
Total 5.2											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/23/ 2563

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Ghitorini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 02.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.6	256	155	388	17.6	12.4	12.4		Not meeting the Standards wrt TSS, BOD, COD & Fecal Coliform.
		Outlet	7.2	19	17	64	1.6	2.7	1.0	17000	
		OLMS	7.18	10.98	6.93	32.95	-	2.70	-	-	
Total 5											

Shukla

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/244 2364

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Kapasahera
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 03.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results.

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.8	198	145	408	11.2	9.4	11.2		Not meeting the Standard wrt. Fecal coliform.
		Outlet	7.5	10	8	40	1.6	3.1	1.2	580	
		OLMS	7.56	13.25	6.38	44.16	-	3.20	-	-	
Total 5											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/275/ 2565

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Pappankalan Ph- I (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.1	264	115	388	12	10.6	8.7		Meeting the standards.
		Outlet	7.6	9	8	28	1.6	3.2	0.6	180	
		OLMS	7.01	8.77	6.17	27.62	-	1.76	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/276/ 2566

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Pappankalan Ph-II (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	20	Inlet	7.1	264	115	388	12	10.6	8.7		Meeting the standards.
		Outlet	7.5	7	6	20	0.4	3.1	0.7	120	
		OLMS	6.93	5.62	6.21	30.64	-	1.05	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number DPCC/W/STP/25-26/277/ 2567

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Najafgarh
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 05.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	5	Inlet	7.8	184	130	348	13.6	11.9	9.4		Meeting the Standards.
		Outlet	7.2	8	7	32	1.2	2.4	1.1	81	
		OLMS	6.98	9.10	6.10	29.70	-	1.97	-	-	
Total 5											

1/

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/278/ 2568

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
	16	Inlet	7.5	154	145	428	11.6	11.0	4.2		Not meeting the Standards wrt Fecal coliform.
		Outlet	7.4	7	6	28	1.6	1.4	1.1	380	
		OLMS	7.3	4.88	6	27.62	-	1.0	-	-	
Total 16											

Shukla

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/279/ 2569

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Molarband (Mini STP)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	0.66	Inlet	7.2	184	195	412	10.8	10.7	6.9		Not meeting the standard wrt TSS, BOD & Fecal Coliform.
		Outlet	7.4	14	12	40	1.6	2.7	1.2	44000	
		OLMS	7.32	8.26	8.42	30.12	-	3.16	-	-	
Total 0.66											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



LIFE
Lifestyle for
Environment

Report Number: DPCC/W/STP/25-26/2801 2570

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Okhla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	124 MGD	Inlet	7.6	148	140	388	17.6	9.7	7.4		Meeting the Standards.
		Outlet	7.4	8	7	36	0.8	4.1	1.1	140	
		OLMS	6.80	6.11	4.97	26.17	-	1.72	-	-	
Total 124											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/28/2571

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Okhla New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 08.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	30	Inlet	7.3	156	150	396	11.2	11.5	6.9		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.1	7	6	28	1.6	3.2	0.6	310.	
		OLMS	7.30	4.88	6.41	27.62	-	1.02	-	-	
Total 30											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/282/ 2572

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Narela
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 09.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10	Inlet	7.3	170	150	388	10.4	10.5	9.4		Not meeting the standards wrt Fecal coliform.
		Outlet	7.4	8	7	28	1.2	1.9	0.7	170	
		OLMS	6.59	5.94	4.68	20.16	-	1.84	-	-	
Total 10											

Shukla

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/283/2573

Dated: 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Rithala
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I(40)	Inlet	7.5	156	140	308	13.6	11.9	6.6		Meeting the standards
		Outlet	7.8	7	6	24	1.6	1.4	0.8	120	
		OLMS	6.83	6.04	4.83	22.13	-	1.41	-	-	
2	Ph-II(40)	Inlet	7.7	160	145	336	12	10.5	7.4		Meeting the standards
		Outlet	7.3	7	5	28	1.2	0.9	0.7	140	
		OLMS	6.60	7.25	5.39	24.18	-	3.72	-	-	
Total 80											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number DPCC/W/STP/25-26/284 / 2574

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Rohini
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	15	Inlet	7.3	192	170	428	15.6	10.3	4.7		meeting the standards
		Outlet	7.2	8	7	24	1.6	2.7	0.6	180	
		OLMS	-	-	-	-	-	-	-	-	
Total 15											OLMS was non operational

Shukla

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/285/2575

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Kondli
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I (10)	Inlet	7.4	160	110	312	11.2	10.5	9.6		Meeting the Standards.
		Outlet	7.7	9	7	32	1.2	2.1	0.9	190	
		OLMS	7.79	10.08	6.3	23.2	-	3.15	-	-	
2	Ph-II & III (25+10)	Outlet	7.8	7	8	36	0.8	1.2	1.7	130	Meeting the Standards.
		OLMS	7.51	6.90	7.40	34.50	-	0.74	-	-	
Total 45											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/286 / 2576

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 12.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-IV (45)	Inlet	7.1	198	125	372	12.4	9.7	5.2		Meeting the Standards.
		Outlet	7.2	8	8	44	0.8	2.9	1.6	190	
		OLMS	7.49	8.30	7.30	30.20	-	3.19	-	-	
Total 45											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/287/ 2577

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Fecal Coliform MPN/100ml	Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)		
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I,II (20)	Inlet	7.4	216	130	416	12.8	12.4	12.4		Meeting the standards.
		Outlet	7.3	7	6	24	1.6	3.4	1.0	160	
		OLMS	7.24	4.34	3.19	15.41	-	1.25	-	-	
2	Ph-III (10)	Inlet	7.1	208	165	428	16	10.9	10.3		Meeting the standards.
		Outlet	7.7	8	7	36	1.6	2.7	2.4	130	
		OLMS	6.56	5.51	4.59	18.38	-	1.10	-	-	
Total 30											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Report Number: DPCC/W/STP/25-26/288/2578

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Coronation Pillar
2. Sampling location : Inlet and outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	70 MGD	Inlet	7.9	168	140	396	11.2	10.7	5.9		Meeting the standards.
		Outlet	7.7	9	8	28	0.8	2.1	1.7	110	
		OLMS	6.55	7.12	4.46	38.49	-	1.09	-	-	
Total 70											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/289/2579

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Delhi Gate (Old)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Ph-I & II (2.2)	Inlet	7.4	176	120	384	12	11.2	9.2		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.1	6	5	24	1.2	3.2	1.6	540	
		OLMS	7.60	4.28	4.37	19.31	-	1.19	-	-	
Total 2.2											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/290/2580

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Delhi Gate (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I & II (15)	Inlet	7.2	152	140	360	16.4	13.0	5.4		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.6	8	6	28	1.2	2.1	0.7	330	
		OLMS	7.50	6.60	5.01	22.62	-	1.57	-	-	
Total 15											

Shashi
I I/C Water Laboratory

[Signature]
Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Dated 30/01/2026

Report Number: DPCC/W/STP/25-26/29/2581

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : SEN Nursing Home (SNH)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	Phase-I,II (2.2)	Inlet	7.5	196	125	352	11.2	9.8	8.3		Not meeting the Standards wrt. Fecal coliform.
		Outlet	7.3	7	5	32	0.8	1.6	1.8	560	
		OLMS	7.25	8.03	7.17	28.01	-	3.78	-	-	
Total 2.2											

[Signature]

I/C Water Laboratory

[Signature]

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/292/2582

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Chilla
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results:											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	9	Inlet	7.1	172	115	372	13.6	9.3	8.7		Meeting the Standards.
		Outlet	7.6	5	4	24	0.8	3.2	0.6	140	
		OLMS	8.06	6.75	5.31	14.60	-	1.06	-	-	
Total 9											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Dated 30/01/2026

Report Number: DPCC/W/STP/25-26/293/ 2583

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Akshardham
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 15.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	1	Inlet	7.3	154	110	328	10.4	10.5	8.5		Meeting the Standards.
		Outlet	7.5	2	2	12	0.4	1.5	0.7	95	
		OLMS	7.55	0.87	2.23	7.80	-	0.36	-	-	
Total 1											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/294/2584

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Keshopur
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	60	Inlet	7.2	184	125	364	11.2	9.4	8.4		Meeting the standards.
		Outlet	7.6	7	6	32	1.6	3.5	0.9	120	
		OLMS	7.85	7.82	6.35	27.11	-	3.35	-	-	
2	20	Outlet	7.7	8	6	28	0.8	3.0	1.7	170	Meeting the standards.
		OLMS	7.78	7.05	5.41	21.56	-	3.02	-	-	
Total 60											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Report Number: DPCC/W/STP/25-26/295/ 2585

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Keshopur STP (New)
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

S. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	12 (MGD)	Inlet	7.9	152	130	348	33.6	11.9	9.4		Meeting the standards.
		Outlet	7.2	6	7	40	1.2	4.0	1.1	180	
		OLMS	7.51	7.44	5.15	30.52	-	1.31	-	-	
Total 12											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for Environment

Dated 30/01/2026

Report Number: DPCC/W/STP/25-26/296/ 2586

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Nilothi
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	40	Inlet	7.1	164	145	364	15.2	10.5	12.2		Meeting the Standards.
		Outlet	7.4	8	7	44	1.6	3.4	1.6	210	
		OLMS	7.82	9.13	8	77.8		1.9			
Total 40											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/297 **2587**

Dated **30/01/2026**

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Niloti New
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	20	Inlet	7.3	196	150	396	11.2	11.5	6.9		Meeting the Standards.
		Outlet	7.2	7	6	32	1.2	3.3	1.1	81	
		OLMS	6.86	7.37	5	36.84	-	2.8	-	-	
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)




Report Number: DPCC/W/STP/25-26/298 / 2588

Dated 30/01/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Yamuna Vihar Ph-III
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

5. Parameters analyzed and results											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	25	Inlet	7.3	236	165	428	13.6	10.9	10.3		Not meeting the Standard wrt TSS, BOD, COD & fecal coliform.
		Outlet	7.6	15	13	60	2.4	2.6	1.2	1700	
		OLMS	7.68	20.61	16.51	57.18	-	16.69	-	-	
Total 25											


I/C Water Laboratory


Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccomms.nic.in>)



Dated 30/01/2026

Report Number: DPCC/W/STP/25-26/299/ 2589

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Yamuna Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 19.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results:

5. Parameters analyzed and results:											
Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	10 Ph-1	Inlet	7.9	160	145	372	14.8	11.2	6.4		Not meeting the standards wrt TSS, BOD & Fecal Coliform
		Outlet	7.7	13	14	64	2.8	3.2	1.0	4300	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non-functional.
2	10 Ph-2	Inlet	7.3	182	140	348	12	16.8	8.5		Meeting the Standards.
		Outlet	7.7	7	5	36	1.2	3.8	0.8	210	
		OLMS	7.73	5.21	4.17	22.59		2.09			
Total 20											

I/C Water Laboratory

Scientist B /Analyst



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)



Report Number: DPCC/W/STP/25-26/300/2590

Dated 30/01/2025

ANALYSIS REPORT OF STP FOR THE MONTH OF JANUARY-2026

1. Name of STP : Sonia Vihar
2. Sampling location : Inlet and Outlet of STP
3. Date of sampling : 20.01.2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P(mg/l)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1	7	Inlet	7.6	216	135	408	17.6	12.4	12.4		Meeting the standards.
		Outlet	7.2	6	5	28	1.6	2.8	1.0	160	
		OLMS	9.56	6.20	3.10	21.10	-	3.62	-	-	
Total 7											

I/C Water Laboratory

Scientist B /Analyst