DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

LiFE Lifestyle for Environment

Report Number: DPCC/W/STP/26-27/151/ 14 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Coronation Pillar**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 03/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase - I & II (20)	Inlet	7.7	196	150	312	13.2	10	11.5	-	Meeting the standards
		Outlet	7.4	8	6	28	0.8	3.4	0.8	130	
		OLMS	7.46	7.56	5.9	24.64	-	1.43	-	-	
2.	Phase - III (10)	Inlet	7.3	200	152.5	424	10.8	11.5	9.5	-	Meeting the standards
		Outlet	7.6	7	4	20	1.2	2.7	0.7	120	
		OLMS	7.45	7.63	5.77	22.10	-	1.27	-	-	
Total 30											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/152/15 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Coronation Pillar (70 MGD)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 03/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	70	Inlet	7.5	182	166	376	11.2	14.6	7.8	-	Meeting the standards
		Outlet	7.8	8	7	44	1.6	2.9	0.9	180	
		OLMS	6.96	6.22	5.65	25.15	-	1.89	-	-	
Total 70											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/153/16 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Rohini**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 03/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	15	Inlet	7.3	210	115	324	12	11.4	10.6	-	Meeting the standards
		Outlet	7.4	9	6	36	0.4	3	0.6	110	
		OLMS	7.30	8.59	7.11	37.60	-	2.42	-	-	
Total 15											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/154/17 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Rithala**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 03/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase I (40)	Inlet	7.4	146	122	384	15.2	1	10	-	Meeting the standards
		Outlet	7.3	9	8	48	2	3.3	0.7	150	
		OLMS	7.36	7.96	6.82	32.44	-	4.22	-	-	
2.	Phase II (40)	Inlet	7.4	186	125	348	12	2.5	11.5	-	Meeting the standards
		Outlet	7.5	8	7	24	1.6	3	0.9	140	
		OLMS	7.58	9.1	7.37	29.86	-	1.4	-	-	
Total 80											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/155/18 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Pappankalan (Old)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 08/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	20	Inlet	7.5	204	126	388	13.2	14.7	9.9	-	Meeting the standards
		Outlet	7.1	6	5	36	0.8	2.3	0.5	180	
		OLMS	7.67	8.65	6.32	27.71	-	1.86	-	-	
Total 20											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/156|19 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Pappankalan (New)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 08/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	20	Inlet	7.5	200	165	388	12.8	11.6	9.9	-	Meeting the standards
		Outlet	7.6	8	7	32	1.6	3.1	0.3	110	
		OLMS	7.46	5.94	5.11	28.26	-	1.80	-	-	
Total 20											

N Mitra

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

LiFE Lifestyle for Environment

Report Number: DPCC/W/STP/26-27/157/20 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Najafgarh**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 08/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	5	Inlet	7.7	194	220	344	10.4	9.3	8.9	-	Meeting the standards
		Outlet	7.4	8	6	48	2	1.4	0.5	72	
		OLMS	7.31	6.90	5.90	28.10	-	2.02	-	-	
Total 5											

N Mitra

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/158/21 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Sonia Vihar**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	7	Inlet	7.8	180	145	328	13.2	11.1	9.1	-	Meeting the standards
		Outlet	7.2	8	5	24	1.6	1.3	0.5	140	
		OLMS	7.6	7.3	3.5	24.7	-	3.5	-	-	
Total 7											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/159/22 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Yamuna Vihar(Phase – III)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	25	Inlet	7.4	296	133	408	14.8	11	9.3	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.3	109	42	144	3.2	1.5	1.6	64000	
		OLMS	7.33	27.35	18.70	80.06	-	29.07	-	-	
Total 25											

N Mitra
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

LiFE Lifestyle for Environment

Report Number: DPCC/W/STP/26-27/160/23 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Yamuna Vihar**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase I (10)	Inlet	7.6	194	152.5	308	13.2	10.8	15.6	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.9	81	48	104	2.4	2.2	1.5	18000	
		OLMS	7.33	27.35	18.70	80.06	-	29.07	-	-	
2.	Phase II (15)	Inlet	7.6	170	151	352	12	13	9	-	Meeting the standards
		Outlet	7.2	7	6	40	1.6	2.7	0.6	130	
		OLMS	7.55	5.32	4.01	17.68	-	4.18	-	-	
Total 25											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/161/24 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **OKHLA (124 MGD)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	124	Inlet	7.7	194	146	368	15.2	11.6	12.3	-	Meeting the standards
		Outlet	7.2	9	7	36	1.2	2.7	1.6	120	
		OLMS	7.20	6.57	5.63	25.67	-	2.82	-	-	
Total 124											

N Mitra

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/162 /25 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Okhla (16 MGD)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	16	Inlet	7.5	218	170	388	15.2	11.4	13.8	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.3	48	26	64	2	3.2	1.8	1500	
		OLMS	7.59	9.04	7.88	35.01	-	4.67	-	-	
Total 16											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/163 /26 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Okhla (30 MGD)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 09/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	30	Inlet	7.6	228	150	388	14.8	11.2	7.7	-	Meeting the standards
		Outlet	7.4	7	6	28	0.8	2.8	0.8	140	
		OLMS	7.21	4.74	5.40	27.96	-	1.58	-	-	
Total 30											

N Mitra

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/164/27 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Narela**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 10/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	10	Inlet	7.6	192	124	360	10.8	11.5	1.6	-	Meeting the standards
		Outlet	7.4	5	4	48	1.2	1.3	0.9	79	
		OLMS	7.46	5.78	4.42	23.32	-	2.16	-	-	
Total 10											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/165/28 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Delhi Gate (Old)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	Phase – I (2.2)	Inlet	7.5	186	171	364	11.2	11.1	7.4	-	Meeting the standards
		Outlet	7.3	9	7	36	1.6	2.4	1.4	170	
		OLMS	7.51	21.00	4.09	6.16	-	2.10	-	-	
Total 2.2											

NMitra

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/166/29 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Delhi Gate (New)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	Phase – II (15)	Inlet	7.6	174	136	324	14.8	13.6	9.6	-	Meeting the standards
		Outlet	7.2	8	6	36	0.4	1.4	0.9	180	
		OLMS	7.9	22.5	6.7	0.25	-	4.68	-	-	
Total 15											

N Moitra

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/167 /30 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Sen Nursing Home (SNH)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	2.2	Inlet	7.7	212	167	392	12	10.7	12.8	-	Meeting the standards
		Outlet	7.3	8	5	48	2	3.2	0.9	210	
		OLMS	7.52	28.65	4.55	7.15	-	2.64	-	-	
Total 2.2											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/168 131 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Akshardham**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	1	Inlet	7.4	194	163	316	11.6	8.9	9.6	-	Meeting the standards
		Outlet	7.2	4	2	32	2	3.3	1.2	72	
		OLMS	7.50	7.35	1.00	0.33	-	0.96	-	-	
Total 1											

Mitra

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/169/32 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Chilla**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	9	Inlet	7.5	198	175	356	11.2	13.9	12.4	-	Meeting the standard
		Outlet	7.3	8	5	46	1.2	3.6	1.8	120	
		OLMS	7.72	29.90	7.54	9.06	-	2.45	-	-	
Total 9											

N Mitra

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/170 /33 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Kondli**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase-I (10)	Inlet	7.7	216	158	320	12.4	13	12.7	-	Meeting the standards
		Outlet	7.3	8	6	40	1.6	2.7	0.7	220	
		OLMS	7.55	5.60	3.90	24.30	-	1.44	-	-	
2.	Phase-II & III (25+10)	Inlet	7.6	214	180	312	12.8	11.7	11.7	-	Meeting the standards
		Outlet	7.3	6	4	44	0.4	4.4	0.9	170	
		OLMS	7.52	9.40	8.30	34	-	3.67	-	-	
Total 45											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/171 | 34 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Kondli (New)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase - IV (45)	Inlet	7.6	196	130	408	14.8	11	12	-	Meeting the standards
		Outlet	7.3	9	8	24	0.8	3.8	0.8	190	
		OLMS	7.46	25.38	5.92	8.46	-	4.23	-	-	
Total 45											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/172/35 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Keshopur**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase –II (20)	Inlet	7.3	298	210	356	13.2	11	13.1	-	Meeting the standards
		Outlet	7.4	7	5	28	1.2	3.1	0.7	140	
		OLMS	7.51	6.93	5.16	20.49	-	1.82	-	-	
2.	Phase – III (60)	Inlet	7.4	296	200	348	13.2	11	11.1	-	Meeting the standards
		Outlet	7.5	5	4	28	1.2	1.6	0.5	94	
		OLMS	6.68	7.76	6.35	20.57	-	2.28	-	-	
Total 80											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/173/36 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Keshopur (New)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase - I (12)	Inlet	7.7	220	207	400	12	9.2	11.3	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.2	28	14	84	1.6	1.5	1	260	
		OLMS	7.62	9.85	8.31	40.03	-	2.73	-	-	
Total 12											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/174 137 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Nilothi (Old)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase – I (60)	Inlet	7.7	178	141	364	10.4	13.6	0.8	-	Meeting the standards
		Outlet	7.4	9	8	28	1.2	3	0.5	160	
		OLMS	7.73	9.02	6.44	38.65	-	1.79	-	-	
Total 60											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/175 | 38 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Nilothi (New)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 14/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase – II (20)	Inlet	7.2	206	160	360	10.4	13.8	19.1	-	Meeting the standards
		Outlet	7.4	7	5	36	1.6	3.8	0.7	110	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non operational
Total 20											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/176/39 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Kapashera**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 17/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	5	Inlet	7.3	196	140	432	12	10	12.9	-	Meeting the standards
		Outlet	7.6	9	6	40	1.6	1	0.7	170	
		OLMS	7.35	5.25	6.27	36.75	-	2.09	-	-	
Total 5											

NMoitra

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/177/40 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Vasant Kunj**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 17/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	Phase – I (2.2)	Inlet	-	-	-	-	-	-	-	-	Sample was not taken due to rehabilitation of STP
		Outlet	-	-	-		-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
2.	Phase – II (3)	Inlet	7.7	228	164	424	14	14.3	13.1	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.1	46	25	92	2	4.7	1.8	8100	
		OLMS	7.63	7.72	9.23	50.64	-	4.17	-	-	
Total 5.2											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/178/41 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Ghitorni**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 17/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	5	Inlet	7.5	222	175	432	13.6	13.6	9.4	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.2	43	24	68	2	4.8	1.1	17000	
		OLMS	-	-	-	-	-	-	-	-	OLMS was non operational
Total 5											

NMoitra
I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/179 | 42 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Mehrauli**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 17/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH 6.5-9.0	TSS (mg/L) 10	BOD (mg/L) 10	COD (mg/L) 50	Oil & Grease (mg/L) 10	Amonical Nitrogen (mg/L) 5	Dissolved Phosphate as P (mg/L) 2	Fecal Coliform MPN/100ml 230	
1.	5	Inlet	7.2	194	182	352	11.6	11.3	10.6	-	Not meeting the standard w.r.t. TSS, BOD, COD & Fecal Coliform
		Outlet	7.5	36	26	64	1.6	3.3	1.3	11000	
		OLMS	7.7	25.22	15.82	71.64	-	8.03	-	-	
Total 5											

I/C Water Laboratory
Dr. NANDITA MOITRA
Scientist-D

DELHI POLLUTION CONTROL COMMITTEE
Department of Environment, Government of N.C.T. of Delhi
4th & 5th Floor, ISBT Building, Kashmere Gate, Delhi 110006
Visit us at: https://dpcc.delhi.gov.in

Report Number: DPCC/W/STP/26-27/180 | 43 **Dated:** 06/10/2026

ANALYSIS REPORT OF STP FOR THE MONTH OF SEPTEMBER – 2026

1. Name of STP : **Molar Band (mini STP)**
2. Sampling location : Inlet & Outlet of STP
3. Date of sampling : 17/09/2026
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/L)	BOD (mg/L)	COD (mg/L)	Oil & Grease (mg/L)	Amonical Nitrogen (mg/L)	Dissolved Phosphate as P (mg/L)	Fecal Coliform MPN/100ml	
			6.5-9.0	10	10	50	10	5	2	230	
1.	0.66	Inlet	-	-	-	-	-	-	-	-	Sample was not taken due to rehabilitation of STP
		Outlet	-	-	-	-	-	-	-	-	
		OLMS	-	-	-	-	-	-	-	-	
Total 0.66											

I/C Water Laboratory

Dr. NANDITA MOITRA
Scientist-D