

	DELHI POLLUTION CONTROL COMMITTEE DEPARTMENT OF ENVIRONMENT (GOVT. OF NCT OF DELHI) 3rd FLOOR, BLOCK-I, DMRC IT PARK BUILDING, SHASTRI PARK, DELHI-53 (visit us at website : http://dpcc.delhigovt.nic.in/)	
--	--	---

DPCC/(10)(02)(03)/Leg-25 | 5318

Date: 28/03/2025

To,

M/s The Ryan Vatika,
 Khasra No-12/12, Old Delhi,
 Gurgaon Road, Near Police Station,
 Kapashera, New Delhi-110037

Subject:- Show Cause Notice for closure under section 33 (A) of the Water (Prevention and Control of Pollution) Act, 1974 and under section 31 (A) of the Air (Prevention and Control of Pollution) Act, 1981 as amended till date.

Whereas, Central Pollution Control Board has delegated all its powers and functions under the Air (Prevention and Control of Pollution) Act, 1981 and Water (Prevention and Control of Pollution) Act, 1974, as amended to date, in respect of Union Territory of Delhi to Delhi Pollution Control Committee (DPCC) vide Notification dated 15.03.1991.

And whereas, the whole Union Territory of Delhi has been declared as an Air Pollution Control area, under sub section (1) of section 19 of the Air (Prevention and Control of Pollution) Act, 1981, as amended to date, vide Notification of Ministry of Environment & Forest, Govt. of India, No. GSR 106 (E) Dated 20.02.1987.

And whereas, as per the mandatory provisions u/s 21 of the Air (Prevention and Control of Pollution) Act, 1981, no person without the previous consent of the State Pollution Control Board (DPCC in case of Delhi) shall establish or operate any industrial plant in an Air Pollution Control Area.

And whereas, as per the mandatory provisions u/s 25/26 of the Water (Prevention and Control of Pollution) Act, 1974, no person without the previous consent of DPCC shall Establish or take any steps to establish any industry, operation or process or any treatment and disposal system or any extension or addition thereto, which is likely to discharge sewage or trade effluent into a stream or well or sewer or on land, bring into use any new or altered outlet for the discharge of sewage or begin to make any new discharge of sewage.

And whereas, inspection of M/s The Ryan Vatika, Khasra No-12/12, Old Delhi, Gurgaon Road, Near Police Station, Kapashera, New Delhi-110037 (hereinafter referred as "Addressee") was carried out by officials of DPCC on 18.03.2025 and found engaged in the running of Banquet Hall/Party Lawn.



The observations made during the inspection are as under:

1) This Banquet Hall/Party Lawn is operating without obtaining Consent from DPCC having capacity of 300-500 persons per function.

(2) Unit representative, Sh. Manoj Kumar informed that no treatment plant is installed in this banquet for the treatment of Waste Water generated in the unit.

(3) Compliance wrt Rule 4 of SWM Rules, 2016 not observed in the unit. No segregation of Biodegradable, Non- biodegradable waste and domestic hazardous waste in separate bins observed at the time of inspection.

Now therefore, in view of the above, the Competent Authority in DPCC in exercise of powers conferred upon Delhi Pollution Control Committee, u/s 33(A) of Water (Prevention and Control of Pollution) Act, 1974 and u/s 31(A) of Air (Prevention and Control of Pollution) Act, 1981 as amended to date, following **proposed directions** are issued:-

1. That the addressee unit shall be directed to stop operations of the unit with immediate effect.
2. That the concerned SDM shall be directed to ensure the effective closure of the addressee unit with immediate effect.
3. That the concerned authority in BSES Rajdhani Power Ltd shall be directed to disconnect the electricity supply to the addressee unit with immediate effect.
4. That the concerned authority in Delhi Jal Board shall be directed to disconnect the water supply to the addressee unit with immediate effect.

Hence, by way of this notice, you are hereby given an opportunity to submit your reply as to why the aforesaid proposed directions should not be confirmed. Your reply should reach to this office within 15 days from date of service of this notice, failing which it shall be assumed that you have nothing to say in this regard and the competent authority of DPCC shall be free to take action as proposed above. This shall also be treated as an opportunity of being heard.

This issues as per the approval of Chairman, DPCC.



Incharge, CMC-II

Email ID: bmsreddy.dpcc@delhi.gov.in

Dr. B.M.S. Reddy
Senior Environmental Engineer
Delhi Pollution Control Committee
4th & 5th Floor, ISBT Building,
Kashmere Gate, Delhi, Delhi-110006