

By Speed Post/email

	DELHI POLLUTION CONTROL COMMITTEE DEPARTMENT OF ENVIRONMENT (GOVT. OF NCT OF DELHI) 3rd FLOOR, BLOCK-I, DMRC IT PARK BUILDING, SHASTRI PARK, DELHI-53 (visit us at website : http://dpcc.delhigovt.nic.in/)	
---	--	---

DPCC/(10)(02)(03)/Leg-25 /5307

Date: 28/03/2025

To,

M/s Spara Corporation Private Limited,
 G-1, Pushpanjali Farms,
 Dwarka Link Road,
 Bijwasan, Delhi-110037

Subject:- Show Cause Notice for revocation/withdrawal of Consent to Operate under Water (Prevention and Control of Pollution) Act, 1974, as amended to date and Air (Prevention and Control of Pollution) Act, 1981

Whereas, Central Pollution Control Board has delegated all its powers and functions under the Air (Prevention and Control of Pollution) Act, 1981 and Water (Prevention and Control of Pollution) Act, 1974, as amended to date, in respect of Union Territory of Delhi to Delhi Pollution Control Committee (DPCC) vide Notification dated 15.03.1991.

And whereas, the whole Union Territory of Delhi has been declared as an Air Pollution Control area, under sub section (1) of section 19 of the Air (Prevention and Control of Pollution) Act, 1981, as amended to date, vide Notification of Ministry of Environment & Forest, Govt. of India, No. GSR 106 (E) Dated 20.02.1987.

And whereas, as per the mandatory provisions u/s 21 of the Air (Prevention and Control of Pollution) Act, 1981, no person without the previous consent of the State Pollution Control Board (DPCC in case of Delhi) shall establish or operate any industrial plant in an Air Pollution Control Area.

And whereas, as per the mandatory provisions u/s 25/26 of the Water (Prevention and Control of Pollution) Act, 1974, no person without the previous consent of DPCC shall Establish or take any steps to establish any industry, operation or process or any treatment and disposal system or any extension or addition thereto, which is likely to discharge sewage or trade effluent into a stream or well or sewer or on land, bring into use any new or altered outlet for the discharge of sewage or begin to make any new discharge of sewage.

And whereas, inspection of **M/s Spara Corporation Private Limited, G-1, Pushpanjali Farms, Dwarka Link Road, Bijwasan, Delhi-110037** (hereinafter referred as "Addressee") was carried out by officials of DPCC on 28.02.2025 and found engaged in the running of Banquet Hall/Party Lawn. The observations made during the inspection are as under:

- 1) The Sewage Treatment plant for the treatment of wastewater not found in working condition. At the time of inspection operator of plant was unable to start the plant. No

- wet sludge/dry sludge observed in sludge drying beds indicating non operation of STP.
Logbook of the STP not properly maintained.
- 2) Treated effluent from the clear water tank was found in yellowish in colour (photo attached), clearly indicating fresh sewage coming out of plant without any treatment.
 - 3) 2 Diesel generator sets of 125KVA and 200 KVA observed in the premises and found non-compliant wrt CAQM directions.
 - 4) Compliance wrt Rule 4 of SWM Rules, 2016 not observed in the unit. No segregation of Biodegradable, Non- biodegradable waste and domestic hazardous waste in separate bins observed at the time of inspection.

Now therefore, in view of the above, the Competent Authority in DPCC, has proposed to revoke/withdraw the consent to operate issued to the addressee unit as per section 27 of Water (Prevention and Control of Pollution) Act, 1974, as amended to date and section 21 of Air (Prevention and Control of Pollution) Act, 1981 amended to date.

Hence, by way of this notice, the addressee unit is hereby given an opportunity to submit its reply as to why the consent issued earlier should not be revoked/withdrawn in view of the non-compliance (observed by the DPCC officials on 28.02.2025) w.r.t certain terms and conditions laid down/stipulated thereon. Your reply, if any should reach to this office within 15 days from date of service of this notice, failing which it shall be assumed that you have nothing to say in this regard and the DPCC shall be free to take action as proposed above. This shall also be treated as an opportunity of being heard.

This issues as per the approval of Chairman, DPCC.



Incharge, CMC-II

Email ID: bmsreddy.dpcc@delhi.gov.in

Dr. B.M.S. Reddy
Senior Environmental Engineer
Delhi Pollution Control Committee
4th & 5th Floor, ISBT Building,
Kashmere Gate, Delhi, Delhi-110006