

	DELHI POLLUTION CONTROL COMMITTEE DEPARTMENT OF ENVIRONMENT (GOVT. OF NCT OF DELHI) 3rd FLOOR, BLOCK-I, DMRC IT PARK BUILDING, SHASTRI PARK, DELHI-53 (visit us at website : http://dpcc.delhigovt.nic.in/)	
---	--	---

DPCC-K018/1/2025-CMC2/06

Date: 02/04/2025

To,

M/s JMM Finvest Pvt. Ltd,
Plot -5, City-Center, Sector 12,
Dwarka, New Delhi-110075.

Subject:- Show Cause Notice for closure under section 33 (A) of the Water (Prevention and Control of Pollution) Act, 1974 and under section 31 (A) of the Air (Prevention and Control of Pollution) Act, 1981 as amended till date.

Whereas, Central Pollution Control Board has delegated all its powers and functions under the Air (Prevention and Control of Pollution) Act, 1981 and Water (Prevention and Control of Pollution) Act, 1974, as amended to date, in respect of Union Territory of Delhi to Delhi Pollution Control Committee (DPCC) vide Notification dated 15.03.1991.

And whereas, the whole Union Territory of Delhi has been declared as an Air Pollution Control area, under sub section (1) of section 19 of the Air (Prevention and Control of Pollution) Act, 1981, as amended to date, vide Notification of Ministry of Environment & Forest, Govt. of India, No. GSR 106 (E) Dated 20.02.1987.

And whereas, as per the mandatory provisions u/s 21 of the Air (Prevention and Control of Pollution) Act, 1981, no person without the previous consent of the State Pollution Control Board (DPCC in case of Delhi) shall establish or operate any industrial plant in an Air Pollution Control Area.

And whereas, as per the mandatory provisions u/s 25/26 of the Water (Prevention and Control of Pollution) Act, 1974, no person without the previous consent of DPCC shall Establish or take any steps to establish any industry, operation or process or any treatment and disposal system or any extension or addition thereto, which is likely to discharge sewage or trade effluent into a stream or well or sewer or on land, bring into use any new or altered outlet for the discharge of sewage or begin to make any new discharge of sewage.

And whereas, inspection of M/s JMM Finvest Pvt. Ltd, Plot -5, City-Center, Sector-12, Dwarka, New Delhi-110075 (hereinafter referred as "Addressee") was carried out by officials of DPCC on 12.03.2025.

The observations made during the inspection are as under:

- 1) It was observed that the Sewage treatment plant is installed but many of its units (Filters, MBBR, Filter press etc.) are not in operational condition which ultimately creates high septic conditions with severe pungent smell.
- 2) No dry/wet sludge found in or near sludge drying bed.

Handwritten signature


- 3) Untreated sewage is being directly discharged into public sewer during inspection.
- 4) Four D.G sets (500KV, 500KV, 500KV and 225KV) are found under the ownership of the unit. Out of which one number of DG set(500KV) is being operated every month which also had found without having any RECD/Emission control device, also the DG model is not meeting CPCB IV complaint.
- 5) Unit has obtained auto renew consent on 16-06-2021 which is valid up to 15-06-2026.
- 6) Unit has informed during the inspection that 850kg per day of solid waste is being generated in the premises.
- 7) No records (1. Total quantum of solid waste generation 2. Bio-degradable waste generation 3 Non-Biodegradable Waste generation 4. Domestic Hazardous Waste generation) are being maintained by the unit .
- 8) No segregation of waste is being practised as per the SWM rules 2016.
- 9) On-site processing facility(Composter machine) found non-functional during inspection and no record/log book provided for the same.
- 10) No facility is observed for the disposal of Domestic Hazardous Waste by the unit.
- 11) No management and disposal of C&D waste, Horticulture & Garden Waste and Sanitary Waste are being practised by the unit as observed during the inspection as per the SWM Rules 2016.

Now therefore, in view of the above, the Competent Authority in DPCC in exercise of powers conferred upon Delhi Pollution Control Committee, u/s 33(A) of Water (Prevention and Control of Pollution) Act, 1974 and u/s 31(A) of Air (Prevention and Control of Pollution) Act, 1981 as amended to date, following **proposed directions** are issued:-

1. That the addressee unit shall be directed to stop operations of the unit with immediate effect.
2. That the concerned SDM shall be directed to ensure the effective closure of the addressee unit with immediate effect.
3. That the concerned authority in BSES Rajdhani Power Ltd shall be directed to disconnect the electricity supply to the addressee unit with immediate effect.
4. That the concerned authority in Delhi Jal Board shall be directed to disconnect the water supply to the addressee unit with immediate effect.

Hence, by way of this notice, you are hereby given an opportunity to submit your reply as to why the aforesaid proposed directions should not be confirmed. Your reply should reach to this office within 15 days from date of service of this notice, failing which it shall be assumed that you have nothing to say in this regard and the competent authority of DPCC shall be free to take action as proposed above. This shall also be treated as an opportunity of being heard.

This issues as per the approval of Chairman, DPCC.



Incharge, CMC-II
Email ID: bmsreddy.dpcc@delhi.gov.in