

By Speed Post

 DPCC	DELHI POLLUTION CONTROL COMMITTEE DEPARTMENT OF ENVIRONMENTAL, (GOVT. OF NCT OF DELHI) 3rd FLOOR, BLOCK-1, DMRC IT PARK, SHASTRI PARK DELHI-110053 visit us at : http://dpcc.delhigovt.nic.in	 LIFE Lifestyle for Environment
--	---	---

F. No. DPCC/J023/9/2025/CMC1/2441-43 Date: 25/09/25

To,

M/s Fortune Park East Delhi (Hotel)
Plot D Community Centre, Vivek Vihar,
Opp. IP University (East Delhi Campus),
Near Yamuna Sports Complex, New Delhi-110092
Email: khanejaaman@yahoo.co.in

Subject: Regarding the submission of a proper notarized affidavit indicating the actual number of days of operation of both DG sets, along with a copy of the complete logbook for both DG sets, duly signed and stamped

Ref: CAQM Sealing Direction No. 945/DG dated 07.05.2025

Whereas, for regulated use of DG sets the CAQM has issued Direction No. 73 dated 02.06.2023, revised Direction No. 76 dated 29.09.2023 and an amendment dated 11.12.2024 and for adopting the prescribed schedule for all sectors in NCR including Industrial, Commercial, Residential and Office establishments etc.

And whereas, the addressee unit/ entity was inspected by flying squad constituted by CAQM on 20.03.2025 and during inspection, two DG Set of 625 kVA & 380 kVA capacity was found non-compliant w.r.t Direction No. 76 dated 29.09.2023.

And whereas, Sealing Direction No. 945/DG dated 07.05.2025 was issued to you (the addressee) by CAQM with the direction to DPCC to seal the non-compliant DG Set with immediate effect, impose and realize appropriate Environmental Compensation (EC) charges, in accordance to the Standard Schedule for EC charges dated 06.02.2024 issued by the Commission for such non-compliant DG Set(s) considering the total number of days these DG set(s) were operated beyond 01.10.2023 and the date of compliance of non-complaint DG sets, as per the log books / established records for operation of such DG set(s).

And whereas, in compliance with the said sealing directions issued by CAQM, DPCC officials inspected the site on 27.05.2025 and found the both DG set of capacity 625 kVA & 380 kVA installed with dual fuel kit.

And whereas, DPCC issued Show Cause Notice for imposition of EC dated 17.06.2025 to you (the addressee) to inform DPCC about actual no. of days of operation of the non-compliant DG set w.e.f. 01.10.2023 till date of compliance of non-compliant DG Set.


And whereas, you (the addressee) submitted your representation dated 02.08.2025, which has been reviewed and found to be incomplete. The affidavit

submitted by you (the addressee) fails to specifically mention the actual days of operation or usage of the DG sets. Furthermore, the logbook for the 380 KVA DG set lacks the necessary signature and stamp, and the logbook for the 625 KVA DG set has not been submitted.

Therefore, you are directed to inform DPCC about the actual number of days/hours of operation of non-compliant DG Set(s) w.e.f. 01.10.2023 to the date of compliance of CAQM Direction No.76/date of inspection by DPCC. Your reply should be substantiated with a documentary proof alongwith copy of complete logbook / established records (duly signed and stamped by the authorized person/authority of the unit for operation of both DG set (s) and a notarized affidavit in this regard. In the Affidavit, the details of logbook must be separately endorsed in clear terms that the DG Set(s) has been operated for the hours/ days mentioned in the logbook of DG Set(s).

Your reply should reach in this office within 15 days of issue of this letter failing which EC (Environmental Compensation) as per aforesaid EC schedule dated 01.01.2025 of CAQM from 01.10.2023 to the date of actual compliance of CAQM Direction No. 76 /date of installation of RECD/Duel fuel kit shall be imposed upon you without any further reference.

This is being issued in the compliance of CAQM directions and with the approval of the Competent Authority in DPCC.


M.S. RAWAT
SEE, CMC-I

Copy to:

- ✓ 1. Incharge IT Cell, with a request for uploading on DPCC website.
2. Master File