

F. No. DPCC/J023/3/2025/CMC1/DPCC/ 661 - 67

Date: 20/06/2025

To,

M/s Croma Group  
(Mr. Khurshid Aalam, Store Manager)  
C-53, Vikas Marg, Preet Vihar,  
New Delhi-110092  
Email: preetvihar-sm.9889@croma.com

**Subject: Directions for imposition of Environmental Compensation.**

**Ref: Sealing Direction No. 801/DG dated 03.02.2025 issued by CAQM.**

Whereas, for regulated use of DG sets the CAQM has issued Direction No.73 dated 02.06.2023, revised Direction No. 76 dated 29.09.2023 and an amendment dated 11.12.2024 and for adopting the prescribed schedule for all sectors in NCR including Industrial, Commercial, Residential and Office establishments etc.

And whereas, the addressee unit/ entity was inspected by flying squad constituted by CAQM on 12.12.2024 and during inspection, 1 DG Set of 62.5 kVA capacity was/were found in your premises non-compliant w.r.t. Direction No. 76 dated 29.09.2023.

And whereas, Show Cause Notice followed by Sealing Direction No. 801/DG dated 03.02.2025 was issued to you (the addressee) by CAQM with the direction to DPCC to seal the non-compliant DG Set with immediate effect, impose and realize appropriate Environmental Compensation (EC) charges, in accordance to the Standard Schedule for EC charges dated 06.02.2024 issued by the Commission for such non-compliant DG Set(s) considering the total number of days these DG set(s) were operated beyond 01.10.2023 and the date of sealing, as per the log books / established records for operation of such DG set(s).

And whereas, in compliance with the said sealing directions issued by CAQM, DPCC officials inspected the site on 19.02.2025 and sealed the said non-compliant DG Set on the spot.

And whereas, DPCC issued Show Cause Notice for imposition of EC dated 25.03.2025 to you (the addressee) to inform DPCC about actual no. of days of operation of the non-compliant DG set w.e.f. 01.10.2023 till 19.02.2025 date of sealing of the non-compliant DG Set.

And whereas, no reply has been received in this office in this regard/reply received and found unsatisfactory.

And whereas, in accordance to the Standard Schedule for EC dated 01.01.2025 issued by the Commission, for each day of violation, **\* Rate of EC Charges per day of operation of the non-compliant DG Set shall be levied from 01.10.2023 onwards are as follows:**

1. Rs. 7,500 for DG Sets between 20 kW - 125 kW capacity
2. Rs. 15,000 for DG Sets > 125 kW but < 800 kW capacity
3. Rs. 25,000 for DG Sets of 800 kW or higher capacity

And whereas, CAQM vide its letter dated 31.01.2025 has given concurrence that EC shall be levied considering the total number of days for which non-complying DG set(s) were

operated after 01.10.2023 to date of closure directions issued by DPCC/removal of non-compliant DG set/compliance of CAQM direction No.76 as amended. Further maintenance of log book for operation of DG set is mandatory and according to the actual operation of such DG set(s) you are hereby directed to deposit Environmental Compensation substantiating with the **verified/signed copy of log book (copy must be attached)** as given in the **Table-A** below along with notarized affidavit about the correctness of the statement:

| S. no. | No. of DG Set (X) | DG Set capacity | No. of days of operation of non-compliant DG set (N) | * Rate of EC/day (R) | Total EC in Rs.(XxNxR ) |
|--------|-------------------|-----------------|------------------------------------------------------|----------------------|-------------------------|
|        |                   |                 |                                                      |                      |                         |

**OR**

In the absence of logbook/established record of non-compliant DG set(s) operations, the operation of DG set is considered from 01.10.2023 till 19.02.2025,i.e. date of sealing of the non-compliant DG Set, and you are hereby directed to deposit Environmental Compensation as per the calculation/formulae given in the **Table-B** below:

| S. no. | No. of DG Set (X) | DG Set capacity | No. of days of operation of DG set (N) | *Rate of EC/day (R) | Total EC in Rs. (XxNxR ) |
|--------|-------------------|-----------------|----------------------------------------|---------------------|--------------------------|
|        |                   |                 |                                        |                     |                          |


**Where,**

**N** = No. of days from 01.10.2023 to date of sealing of the non- compliant DG Set i.e. 19.02.2025.

**R** = Rate of EC Charges per day of operation of the non-compliant DG Set as indicated above.

**Now therefore,** you are hereby directed to deposit Environmental Compensation (EC) of an amount as per the **Table-A OR Table-B** mentioned above in the form of DD, in favour of DPCC within 15 days from issuance of this direction/order failing which shall be taken as per law. Failure to deposit the EC amount will attract action for recovery of the same as arrears of land revenue by the concerned SDM. Further, the DG set(s) will be de-sealed with the approval of CAQM once the applicable EC is deposited by the unit/entity in DPCC.

This is being issued in the compliance of CAQM directions and with the approval of the Competent Authority in DPCC.

  
**M.S. Rawat**  
**SEE, CMC-I**

(Email: msrawat.dpcc@nic.in)

**Copy to:**

1. Incharge IT Cell, with a request for uploading on DPCC website.
2. Master file CMC-I.