

STATE LEVEL ENVIRONMENT IMPACT ASSESSMENT AUTHORITY - DELHI
OFFICE OF DELHI POLLUTION CONTROL COMMITTEE
4TH FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-6
VISIT US AT : [HTTP://DPCC.DELHIGOV.T.NIC.IN](http://DPCC.DELHIGOV.T.NIC.IN)

F.No.98/DPCC/SEIAA-SEAC/10/1156


Dated: 02/07/2014

CORRIGENDUM

As per the approval of the SEIAA, Delhi, Environmental Clearance for the "Proposed Additional Building Complex for the Supreme Court of India adjoining Pragati Maidan, New Delhi" was issued on 05.01.2011. In the said EC on the request of the Project proponent and as per the recommendation of SEAC the Authority is pleased to replace the Specific condition no. 5 of Operational Phase of the EC as under

"Diesel based generator sets for power backup is allowed. The DG sets should be subjected to periodic noise and stack monitoring in consultation with DPCC. Clearance from AAI should be obtained for stack height of DG set".

All terms & conditions shall remain same as mentioned in the EC granted vide letter no. F.No. 98/DPCC/SEIAA-SEAC/10/1590-1594 dated 05.01.2011



(Sandeep Mishra)

Member Secretary (SEIAA)

To:

1. Sh. Kaushal Kumar Mathur, Chairman (SEIAA), 4, Defence Enclave, Vikas Marg, Delhi - 110092.
2. Dr. Mukesh Khare, Member (SEIAA), Civil Engineering Department, Block-IV, Indian Institute of Technology(IIT), New Delhi-110016

Copy to:-

1. Additional Director/Conservator of Forests, Ministry of Environment & Forests, Regional Office (NZ), Bays No.24-25, Sector 31 A, Dakshin Marg, Chandigarh - 160030.
2. Sr. Scientist (IT) – for necessary action with respect to website of SEIAA/SEAC.
3. PS to Chairman, DPCC – for information.
4. Project file.

3658/DPCC/SEAC/10/1156

02/07/14
M. Ananta